## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date: 16-Oct-16 Till now the maximum generation is : - 9036 MW 21:00 Hrs on 30-Jun-16 The Summary of Yester 15-Oct-16 Today's Actual Min Gen. & Probable Gen. & Demand Generation & Demand Hour Min. Gen. at Evening Peak Generation 8568.0 MW Hour 19:00 Max Generation 9255 E.P. Demand (at gen end) 8700.0 Hour 19:00 Max Demand (Evening) 9000 Maximum Generation 8568.0 MW Hour 19:00 Reserve (Generation end) 255 Total Gen. (MKWH) 167.3 System L/ Factor 81.38% Load Shed 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 7.867 Export from East grid to West grid :- Maximum -150 MW at 10:00 Energy Import from West grid to East grid :- Maximum MW Energy at Water Level of Kaptai Lake at 16-Oct-16 107.43 Ft.( MSL ) Actual: Rule curve : 108.58 Ft.(MSL) Gas Consumed: Total 1020.59 MMCFD. Oil Consumed (PDB): HSD : FO Cost of the Consumed Fuel (F Gas Tk77.586.325 Coal Tk7.968.551 : Tk369,830,690 Total: Tk455,385,566 Load Shedding & Other Information Area Today Yesterday Rates of Shedding Estimated Demand (S/S end) Estimated Shedding (S/S end) MW MW MW (On Estimated Demand) Dhaka 18:45-20:30 3360 Chittagong Area 0 0:00 940 Khulna Area 0:00 957 Raishahi Area 0 0.00 921 Comilla Area 0 0:00 690 Mymensingh Are 0 0.00 523 0 Sylhet Area 0:00 339 Rarisal Area 0 0:00 183 Rangpur Area 30 18:45-20:30 511 Total 8424 119 Information of the Generating Units under shut dow n. Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/201(13) Ghorasal Unit-4 (13/10/2016) 2) Chittagong ST: Unit-1 11) Sylhet 20 MW GT 3) Ashuganj ST: Unit- 1 12) Kaptai Unit-5 4) Khulna ST 110 MW (04/11/2014) 5) Ghorasal Unit-5 6) Bhola GT-2 & ST. 7) Baghabari 100 MW 8) Haripur SBU GT- 3 14) Barapukuria: unit-2(13/10/2016) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Comments on Power Interruption Description a) Ishurdi-Ghorasal 230 kV Ckt-1 was under shut down from 08:01 to 17:18 for A/M. b) Bottail 132/33 kV T1 & T2 transformers tripped at 09:51 from 33 kV side due to PT burst of About 54 MW pow er interruption occurred under Bottail S/S areas 33/11 kV transformer showing inst E/F and were switched on 09:56. from 09:51 to 09:56. c) Chapainaw abganj 132/33 kV T3 transformer was under shut down from 09:29 to 16:50 for A/M. d) Khulna© 230/132 kV T2 transformer was under shut down from 08:32 to 17:21 for A/M. e) After maintenance Ashuganj 225 MW CCPP GT was synchronized at 12:48. f) Mongla 132/33 kV T1 was under shut down from 11:11 to 11:42 for red hot maintenance. g) Barisal(S) 132/33 kV T1 transformer was under shut down from 11:40 to 15:19 due to air compressor leaks About 10 MW power interruption occurred under Barisal S/S area at 132kV side breaker. from 11:40 to 15:19. h) Bottail-Bheramara 132 kV Ckt-2 was under shut down from 15:07 to 15:23 for breaker inspection at bottail end. i) Bheramara HVDC 230 kV bus-2 is shut down since 05:18 (16/10/2016) for project work. j) Bogra-Naogaon 132 kV Ckt-2 was under shut down from 07:44 to 08:42(16/10/2016) due to red hot maint of CT loop at Bogra end k) Ishurdi-Ghorasal 230 kV Ckt-1 is shut down since 07:50 (16/10/2016) for A/M. Sub Divisional Engineer Executive Engineer Superintendent Engineer

Network Operation Division

Load Dispatch Circle

Network Operation Division