POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date 25-Oct-16 Till now the maximum generation is 9036 MW The Summary of Yest 24-Oct-16 Generation Day Peak Generation 7024.0 MW 21:00 Hrs Today's Actual Min Gen. & Probable Gen. & Deman 6 Generation & Demand MW 12:00 Evening Peak Generatic E.P. Demand (at gen en Maximum Generation 8676.0 MW 19:00 Max Generation 9202 Max Demand (Evening) : Reserve (Generation end) 8676.0 MM 19:00 8750 8676.0 MW 19:00 452 Total Gen. (MKWH) 169.2 System L/ Factor 81.26% Load Shed Export from East grid to West grid :- Ma ε 17:00 7.867 Energy Import from West grid to East grid :- Ma Water Level of Kaptai L; 25-Oct-16 MW Energy Rule curve: 108.30 Ft.(MSL) Actual: 107.24 Ft.(MSL) Gas Consumed Total Oil Consumed (PDB): HSD FO Cost of the Consumed F Gas Coal Tk76.066.554 Tk15,663,669 Oil : Tk281,868,544 Total : Tk373,598,767 Load Shedding & Other Information Area Yesterday Today Estimated Shedding (S/S en Rates of Shedding MW (On Estimated Dema Estimated Demand (S/S end) (On Estimated Demand Dhaka 0:00 3256 Chittagong Are Khulna Area 0 0:00 910 924 Rajshahi Area 0 0:00 891 Comilla Area Mymensingh 0:00 670 508 Sylhet Area Barisal Area 327 178 0 0:00 Rangpur Area 0 0:00 495 Total 8159 Information of the Generating Units under shut down Forced Shut-Down Planned Shut- Down 1) Ghorasal ST: Unit-6 (18/0 12) Ghorasal Unit-4 (13/10/2016) Nil 2) Kaptai Unit-5 13) Chandpur CCPP ST 3) Ashuganj ST: Unit-1,2 14) Tongi GT 4) Khulna ST 110 MW (04/1 15) Chitagong ST Unit-2 16) Khulna 230 MW 5) Ghorasal Unit-5 6) Khulna 230 MW 7) Baghabari 100 MW 8) Haripur SBU GT-3 11) Sylhet 20 MW GT Additional Information of Machines, lines, Interruption / Forced Load shed etc. Comments on Power Interruption a) Halishahar-Khulshi 132 kV Ckt-2 was under shut down from 08:48 to 15:48 for A/M b) Rampura 132 kV Bus-1 was under shut down from 08:49 to 17:37 for A/M c) Chandpur 132/33 kV T2 transformer was under shut down from 08:49 to 17:37 for A/M. d) Ghorasal-Ashuganj (S) 230 kV Ckt-2 tripped at 12:55 from both sides showing dist.relay and was switched on at 13:53. e) After maintenance Rajshahi 132/33 kV T-3 transformer was switched on at 14:03. f) Barisal-Bhandaria 132 kV Ckt was under shut down from 15:40 to 16:32 for red hot maintenance at B-Phase isolator of Barisal end. g) Kaptai-Madunaghat 132 kV Ckt-2 was under shut down from 15:09 to 17:16 for B-Phase I About 20 MW power interruption occurred under Madunaghat works at Kaptai end and was switched on at 17:16. h) After maintenance Hathazari 132/33 kV T-1 transformer switched on at 14:40. from 15:09 to 17:16. i) After maintenance Khulna ® - Khulna 225 MW Ckt-1 & 2 were switched on at 16:42 & 16:54 respectively j) After maintenance Goalpara - Khulna 225 MW Ckt was switched on at 16:50. k), Bheramara-Bottail 132 kV Ckt-2 was under shut down from 07:20 to 08:45 (25/10/2016) for red hot maintenance) Barisal 132/33 kV T-1 transformer was shut down at 07:31 (25/10/2016) for A/M.

Executive Engineer

Network Operation Division

Superintendent Engineer

Load Dispatch Circle

Sub Divisional Engineer

Network Operation Division