POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date: 11-Dec-16 Till now the maximum generation is :- 9036 MW 21:00 Hrs on 30-Jun-16 Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yester Generation & Demand 10-Dec-16 Evening Peak Generation 7267.0 MW Hour 19:00 Max Generation 8311 E.P. Demand (at gen end) 7267.0 Hour 19:00 Max Demand (Evening) 7600 Maximum Generation 7267.0 MW Hour 19:00 Reserve (Generation end) 711 Total Gen. (MKWH) System L/ Factor 128.3 73.59% Load Shed EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 7.867 Export from East grid to West grid :- Maximum -510 MW at 15:00 Energy Import from West grid to East grid :- Maximum Energy Water Level of Kaptai Lake at 11-Dec-16 Actual:) Rule Curv Ft.(MSL) Rule curve : 0.00 Ft.(MSL) Gas Consumed: Total 865.34 MMCFD. Oil Consumed (PDB): HSD : FO Cost of the Consumed Fuel (F Gas Tk62.173.778 Coal Tk15.585.545 : Tk228,077,711 Total: Tk305,837,034 Load Shedding & Other Information Area Yesterday Today Rates of Shedding Estimated Demand (S/S end) Estimated Shedding (S/S end) MW MW MW (On Estimated Demand) Dhaka 0:00 Chittagong Area 0 0:00 779 0:00 775 Raishahi Area Λ 0.00 755 579 Comilla Area 0:00 Mymensingh Are 0 0.00 441 272 Sylhet Area 0 0:00 Barisal Area 0 0.00 154 Rangpur Area 0 0:00 426 Total 6965 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down 1) Ghorasal ST: Unit-6 (18/07/201(10) Ghorasal Unit-2 11) Sylhet 150 MW GT Nil 2) Kaptai Unit-5 3) Ashuganj ST: Unit- 1 12) Sikalbaha Peaking GT 4) Khulna ST 110 MW (04/11/2014 13) Siddhirgonj GT: Unit-1,2 5) Ghorasal Unit-5 14) Shahjibazar (Energyprima) 6) Baghabari 100 MW 15) Bheramara Interconnector(HVDC) 7) Haripur SBU GT- 3 16) Sikalbaha ST 8) Fenchugonj CCPP-2 9) Chittagong Unit-1 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Comments on Power Interruption Description a) Bhulta-Haripur 132 kV Ckt was under shut down from 08:26 to 13:20 for A/M. b) Panchaghar-Thakurgaon 132 kV Ckt was under shut down from 08:05 to 16:18 for A/M. c) Barisal(Old)-Barisal GT 132 kV Ckt was under shut down from 08:31 to 16:25 for A/M. d) Jessore-Jhenidah 132 kV Ckt-2 was under shut down from 08:34 to 16:43 for A/M. e) Madanganj-Munshiganj 132 kV Ckt-1 was under shut down from 09:06 to 15:43 for A/M. f) Hasnabad-Shvampur 132 kV Ckt was under shut down from 08:32 to 16:53 for A/M. g) Aminbazar-Agargaon 230 kV Ckt-1 was under shut down from 09:41 to 16:41 for A/M. h) Jamalpur 132/33 kV T-1 transformer was under shut down from 09:11 to 16:50 for A/M. i) Ashuganj-Kishorganj 132 kV Ckt-2 was under shut down from 08:24 to 16:50 for A/M. j) Maniknagar-Bangabhaban 132 kV Ckt-1 was under shut down from 08:30 to 15:26 for A/M. k) Madunaghat-Khulshi 132 kV Ckt-2 was under shut down from 09:23 to 11:32 for A/M. I) Sonargaon 132 kV Bus coupler was under shut down from 08:26 to 11:36 for maintenance. m) Bogra-Sirajganj 132 kV Ckt-2 was under shut down from 08:20 to 15:40 for A/M. n) Hathazari-Feni 132 kV Ckt-1 was under shut down from 09:25 to 17:00 for maintenance. o) Mymensing 132/33 kV T-1 & T-2 transformers tripped at 07:28(11/12/16) due to CT burst a About 48 MW power interruption occurred under Mymensing S/S area and was switched on at 07:48(11/12/16).At the same time Mymensing RPCL-202 MW alse from 07:28 to 07:48(11/12/16). synchronized at 07:44(11/12/16). p) Panchaghar-Thakurgaon 132 kV Ckt is under shut down at 07:46(11/12/16) for A/M.

Executive Engineer

Network Operation Division

Superintendent Engineer

Load Dispatch Circle

Sub Divisional Engineer

Network Operation Division