

DAILY REPORT

Page -1

Till now the maximum generation is :- 9036 MW

21:00

Hrs on 30-Jun-16

Reporting Date : 29-Dec-16

The Summary of Yesterday 28-Dec-16 Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation	: 5667.0	MW	Hour : 12:00	Min. Gen. at	5:00	4243	MW
Evening Peak Generation	: 7495.0	MW	Hour : 19:00	Max Generation	:	8689	MW
E.P. Demand (at gen end)	: 7495.0	MW	Hour : 19:00	Max Demand (Evening)	:	7550	MW
Maximum Generation	: 7495.0	MW	Hour : 19:00	Reserve (Generation end)	:	1139	MW
Total Gen. (MkWh)	: 133.6	System L/ Factor	: 74.27%	Load Shed	:	0	MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :-	Maximum	-285	MW	at	11:00	Energy	7.867	MKWHR.
Import from West grid to East grid :-	Maximum	-	MW	at	-	Energy	-	MKWHR.

Water Level of Kaptai Lake at 29-Dec-16

Actual : 101.17 Ft.(MSL) , Rule curve : 103.30 Ft.(MSL)

Gas Consumed : Total	817.59	MMCFD.	Oil Consumed (PDB) :	HSD	:	Liter
				FO	:	Liter

Cost of the Consumed Fuel (F	Gas	:	Tk61,331,276	Oil	:	Tk217,796,967	Total	:	Tk292,799,781
	Coal	:	Tk13,671,537						

Load Shedding & Other Information

Area	Yesterday		Estimated Demand (S/S end)	Today		Rates of Shedding (On Estimated Demand)
	MW			Estimated Shedding (S/S end)		
			MW	MW		
Dhaka	0	0:00	2784	-	-	
Chittagong Area	0	0:00	779	-	-	
Khulna Area	0	0:00	775	-	-	
Rajshahi Area	0	0:00	755	-	-	
Comilla Area	0	0:00	579	-	-	
Mymensingh Area	0	0:00	441	-	-	
Sylhet Area	0	0:00	272	-	-	
Barisal Area	0	0:00	154	-	-	
Rangpur Area	0	0:00	426	-	-	
Total	0		6965	0		

Information of the Generating Units under shut down n.

Planned Shut- Down n	Forced Shut- Down n
Nil	1) Ghorasal ST: Unit-6 (18/07/2016) 2) Kaptai Unit-2 & 5 3) Ashuganj ST: Unit- 1 4) Khulna ST 110 MW (04/11/2014) 5) Ghorasal Unit-5 6) Baghabari 100 MW 7) Haripur SBU GT- 1,2,3 8) Fenchugonj CCGP-2 9) Chittagong Unit-1 10) Ghorasal Unit-1 11) Sylhet 150 MW GT 12) Sikabaha Peaking GT 13) Sikabaha ST 14) Shahjibazar(Energyprima) 15) Shahjibazar GT: Unit- 8, 9 16) Siddhirganj 210 MW(24/12/16) 17) Barapukuria ST: Unit-2
Additional Information of Machines, lines, Interruption / Forced Load shed etc.	

Description	Comments on Power Interruption
a) Hathazari-Raozan 230 kV Ckt-2 w as under shut down n from 09:20 to 2:24 for A/M. b) Chandpur 132 kV bus-1 w as under shut down n from 09:21 to 20:35 for A/M. c) New Tongi-Tongi 132 kV Ckt-2 w as under shut down n from 09:26 to 3:20 for A/M. d) Mymensingh-Kishoreganj 132 kV Ckt-1 w as shut down n at 08:22 for A/M and is still under shut down n. e) Jamalpur 132/33 kV T4 transformer w as under shut down n from 08:40 to 5:09 for A/M. f) Savar-Aminbazar 132 kV Ckt-2 w as under shut down n from 08:08 to 16:59 for A/M. g) Madanganj-Munshiganj 132 kV Ckt-1 w as under shut down n from 09:39 to 16:33 for A/M. h) Shyampur 132/33 kV T2 transformer w as under shut down n from 09:17 to 15:24 for A/M. i) Hasnabad-Meghnaghat 230 kV Ckt-2 w as under shut down n from 08:48 to 17:14 for A/M. j) Shahjibazar-Sreemongal 132 kV Ckt-1 w as under shut down n from 08:21 to 15:07 for A/M. k) Ghorasal-Ishurdi 230 kV Ckt-2 w as under shut down n from 08:27 to 17:29 for A/M. l) Uttara 132/33 kV T2 transformer w as under shut down n from 08:20 to 17:08 for A/M. m) Madanganj 132/33 kV T2 transformer w as under shut down n from 09:20 to 15:16 for A/M. n) Mirpur-Aminbazar 132 kV Ckt-1 w as under shut down n from 09:13 to 16:39 for A/M. o) Bogra-Sirajganj 132 kV Ckt-1 w as under shut down n from 08:12 to 15:59 for A/M. p) Saidpur-Rangpur 132 kV Ckt-2 w as under shut down n from 09:10 to 16:10 for A/M. q) Ishurdi 230 kV bus-2 w as under shut down n from 08:35 to 11:59 for A/M. r) Faridpur-Madaripur 132 kV Ckt-2 w as under shut down n from 08:47 to 16:17 for A/M. s) Rampura 230/132 kV T-2 transformer w as under shut down n from 14:23 to 15:15 for A/M. t) After maintenance Sirajganj CCGP w as synchronized at 15:14. u) Barapukuria Unit-2 tripped at 17:22 due to flame out. v) Shahjibazar 330 MW CCGP GT-2 w as shut down n at 19:33 for maintenance work. w) Ghorasal-Ishurdi 230 kV Ckt-1 tripped at 04:25 (29/12/2016) from both end show ing DR2H, LZ96 relay and w as sw itched on at 05:14 (29/12/2016). x) Hasnabad-Meghnaghat 230 kV Ckt-2 tripped at 04:41 (29/12/2016) from both end showing dist. relay and w as sw itched on at 07:43 (29/12/2016). y) Ghorasal-Ishurdi 230 kV Ckt-2 tripped at 06:02 (29/12/2016) from both end showing dist.relay and w as sw itched on at 06:34 (29/12/2016). z) Kishoreganj 132/33 kV T2 transformer tripped at 01:55 (29/12/2016) showing O/C relay and w as sw itched on at 02:33 (29/12/2016). aa) Hasnabad-Aminbazar 230 kV Ckt-1 w as shut down n at 07:44 (29/12/2016) for A/M. ab) Ghorasal-Ishurdi 230 kV Ckt-1 tripped at 04:25 (29/12/2016) from both end showing DR2H, LZ96 relay and w as sw itched on at 05:14 (29/12/2016). ac) Hasnabad-Meghnaghat 230 kV Ckt-2 tripped at 04:41 (29/12/2016) from both end showing dist.relay and w as sw itched on at 07:43 (29/12/2016). ad) Ghorasal-Ishurdi 230 kV Ckt-2 tripped at 06:02 (29/12/2016) from both end showing dist.relay and w as sw itched on at 06:34 (29/12/2016). ae) Kishoreganj 132/33 kV T2 transformer tripped at 01:55 (29/12/2016) showing O/C relay and w as sw itched on at 02:33 (29/12/2016). af) Hasnabad-Aminbazar 230 kV Ckt-1 w as shut down n at 07:44 (29/12/2016) for A/M.	About 18 MW power interruption occurred under Kishoreganj S/S area from 01:55 to 02:33 (29/12/2016).

Sub Divisional Engineer
Network Operation DivisionExecutive Engineer
Network Operation DivisionSuperintendent Engineer
Load Dispatch Circle