		P	OWER GRID COMPANY OF BANGLADE	SH LTD.			
			NATIONAL LOAD DESPATCH CENT	ER			
DAILY REPORT							
					Reporting Date :	17-Feb-17	
			9036 MW Generation & Demand	21:00	Hrs on 30-Jun-16 Today's Actual Min Gen. & Proba	able Con & Demand	
Day Peak Generat		16-Feb-17 6773.0	MW	12:00	Min. Gen. at 5:00	5174	
Evening Peak Ger		7849.0	MW	19:00	Max Generation :	8456	
E.P. Demand (at g		7849.0	MW	19:00	Max Demand (Evening) :	7300	
Maximum Genera		7849.0	MW	19:00	Reserve (Generation end)	2556 0	
Total Gen. (MKWI	7) :	151.8 EXPORT /	System L/ Factor : IMPORT THROUGH EAST-WEST INT	80.61%	Load Shed :	0	
Export from East	grid to West g				t 17:00 Energy	7.867	
Import from West	grid to East g	rid :- Maximum	-	MW a	t - Energy	-	
		of Kaptai Lake a		04.00			
Actual :	95.72	Ft.(MSL),	Rule cu	ve: 94.90	Ft.( MSL )		
Gas Consumed :	Total	845.83	MMCFD.	Oil Consum	ned (PDB):		
	HSD :						
					FO :		
Cost of the Consu	med Fuel (F	Gas Coal		Oil	: Tk392,683,614 Total :	Tr 460 084 405	
Coal : Tk7,616,998 Oil : Tk392,683,614 Total : Tk460,984,495							
Load Shedding & Other Information							
Area Yesterday		terday	Estimated Demond (0/0 1)		Today		
	MW		Estimated Demand (S/S end) MW		Estimated Shedding (S/S end) MW	Rates of Shedding (On Estimated Demand)	
Dhaka	0	0:00	2679		-	-	
Chittagong Area	0	0:00	749		-	-	
Khulna Area	0	0:00	742		-	-	
Rajshahi Area	0	0:00	724		-	-	
Comilla Area Mymensingh Area	0	0:00 0:00	559 426		-	-	
Sylhet Area	Ö	0:00	260		-	_	
Barisal Area	0	0:00	149		-	-	
Rangpur Area	0	0:00	411		-	-	
<b>T</b> . ( . )							
Total	0		6699		0		
	Informa	ation of the Gen	erating Units under shut down.				
Planned Shut- Down Forced Shut- Down							
1) Ghorasal ST: Unit-6 (18/07/2010 10) Sikalbaha Peaking GT							
	Nil 2) Kaptai Unit-2 & 5 11) Ghorasal Unit-4(30/01/17)   2) Abutati Unit-2 & 5 11) Ghorasal Unit-4(30/01/17) 11						
					j ST: Unit- 1, 2 & GT-2 12)Thakurgad		
					4) Khulna ST 110 MW (04/11/2014 13) Sikalbaha ST 5) Ghorasal Unit-1,5 14) Baqhabari-71 MW		
				6) Baghaba	, , ,		
					7) Haripur SBU GT- 1,3		
				· ·	8) Summit Bibiana- 2		
9) Chit					Chittagong Unit-1 & 2		
Additional Information of Machines, lines, Interruption / Forced Load shed etc.							
Auditional monnation of machines, mes, menupuon / Forced Load siled etc.							
Description					Comments on Power Interruption		
a) Gopalganj 132/33 kV T2 transformer was under shut down from 08:04 to 10:55 102/17/2017 for maintenance work.							
b) Madaripur 132/33 kV T2 transformer was under shut down from 09:46 to 10:52 for red hot maintenance work.							
· ·							
c) Khulna (S)-Gallamari 132 kV Ckt-2 was under shut down from 09:04 to 15:23 for maintenance work. d) Kallyanpur 132/33 kV T1 transformer was under shut down from 11:16 to 13:12 for A/M.							
e) Jessore 132/33 kV T1,T2 & T3 transformers tripped at 12:56 showing inst. E/F rel About 88 MW power interruption occurred under Jessore S/S areas							
13:10. from 12:56 to 13:10.							
f) Khulna (S)-Khulna © 132 kV Ckt-1 tripped at 13:10 showing back-up protection and was switched on at 13:24.							
g) Jessore-Jhenidah 132 kV Ckt-2 tripped at 13:09 from Jhenidah end showing dist.relay and was switched on at							
13:20.							
h) KPCL-1 & KP	CL-2 tripped	d at 13:10 sho	wing E/F relay at both plants and were	e synchronized	at 13:17 & 13:38		
respectively.							
i) Sylhet 150 MW tripped at 12:57 showing high frequency and was synchronized at 15:23.							
j) Bibiyana-Kaliakoir 400 kV Ckt-1 was under shut down from 08:10 to 23:54 for maintenance work at Bibiyana end.							
k) Faridpur 132/33 kV T-2 transformer was under shut down from 16:34 to 17:25 for red hot maintenance work.							
I) Shahjibazar 330 MW CCPP GT-1 & 2 were shut down at 23:04 for maintenance work.							
m) Ghorasal Max GT-1 & 2 tripped at 23:06 due to gas supply problem.							
n) Ashuganj Unit-5 tripped at 01:41 (17/02/2017) due to communication server failure and was synchronized at							
05:35 (17/02/2017).							
o) Hathazari 132 kV Bus-2 was under shut down from 06:59 to 08:22 (17/02/2017) for A/M.							
p) Joydevpur 132/33 kV T-3 transformer was shut down at 07:37 for A/M.							
$p_{1}$ objection to $p_{1}$ objection to the solution of the was sheen at $0.37$ to $p_{1}$ with							
Sub Divisional Engineer Executive Engineer Superintendent Engineer							
Network Operation Division			Network Operation Division		Load Dispatch Circle		