## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

Reporting Date: 9036 MW 21:00 Hrs Till now the maximum generation is: -30-Jun-16 on Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterda 28-Feb-17 Day Peak Generation 6906.0 12:00 Min. Gen. at 5:00 Evening Peak Generation 7952.0 MW Н 19:30 Max Generation 9596 E.P. Demand (at gen end) : 7952.0 MW 19:30 Max Demand (Evening) 8200 Maximum Generation 7952.0 MW 19:30 Reserve (Generation end) 2696 Total Gen. (MKWH) System L/ Factor 81.46% Load Shed 0

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum -430 MW at 17:00 Energy 7.867 Import from West grid to East grid :- Maximum MW at Energy

Water Level of Kaptai Lake at 1-Mar-17 Actual: 93.40 Ft.(MSL)

HSD

1-Mar-17

Gas Consumed: Total 895.27 MMCFD. Oil Consumed (PDB):

FO

Cost of the Consumed Fuel (F Gas Tk64,268,091

Tk8,906,025 : Tk319,750,177 Total: Tk392,924,292

Rule curve :

93.00

Ft.( MSL )

## Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	3071	-	-
Chittagong Area	0	0:00	859	-	-
Khulna Area	0	0:00	865	-	-
Rajshahi Area	0	0:00	838	-	-
Comilla Area	0	0:00	634	-	-
Mymensingh Area	0	0:00	482	-	-
Sylhet Area	0	0:00	306	-	-
Barisal Area	0	0:00	168	-	-
Rangpur Area	0	0:00	468	-	-
Total	0		7691	0	

Information of the Generating Units under shut down.

Planned Shut- Down	Forced Shut- Down
	1) Ghorasal ST: Unit-6 (18/07/2010 10) Baghabari-71 MW
Nil	2) Kaptai Unit-2 & 5
	3) Ashuganj ST: Unit- 1,
	4) Khulna ST 110 MW (04/11/2014)
	5) Ghorasal Unit-2,5
	6) Baghabari 100 MW
	7) Haripur SBU GT- 1,3
	8) Chittagong Unit-1 & 2
	9)Thakurgaon (RZ)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description **Comments on Power Interruption** 

- a) Rampura-Haripur 230 kV Ckt-1 was under shut down from 18:43 to 22:09 due to red hot at R-phase wave trap.
- b) After maintenance Barapukuria Unit-1 was synchronized at 18:09 and tripped at 00:24(01/03/2017) due to

hydro coupler fault in feed pump and was synchronized at 03:40.

- c) Mymensingh RPCL ST was synchronized at 18:05.
- d) Ashugani South ST was synchronized at 19:35.
- e) Shahjibazar 330 MW GT1 tripped at 05:38 (01/03/2017) due to gas valve problem and was synchronized at 06:38.
- f) Chandpur 150 MW CCPP was shut down at 05:49 (01/03/2017) for air filter changing.
- g) Sirajganj 225 MW was shut down at 06:41 (01/03/2017) for air filter changing.

Sub Divisional Engineer Network Operation Division

**Executive Engineer Network Operation Division**  Superintendent Engineer **Load Dispatch Circle**