

QF-LDC-08
Page -1

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 882 MW (21:00) of load shed was imposed over the whole areas of the national grid .
b) Due to low gas pressure RPCL (210 MW) and Tongi (105 MW) were limited to 107 MW and 70 MW respectively.	
c) After maintenance Khulna-60MW was synchronized at 13:52.	
d) Ashuganj CCGP ST tripped at 16:53 due to tripping of CW pump & GT-1 was forced shut down at 17:09 due to non closing of damper and was synchronized at 20:18(GT-1).	
e) Ghorasal RPP was shut down at 14:58 due to tripping of Ghorasal 132/33 KV T1 transformer and was synchronized at 15:48.	
f) Shahjibazar RPP tripped at 16:30 showing bus bar signal alarm and was synchronized at 16:35.	
g) Baghabari WMPP #1 tripped at 00:39(01/12/10) due to inlet manifold diff. pressure and was synchronized at 06:03(01/12/10).	
h)Kaptai #3 tripped at 03:20(01/12/10) due to roto E/F.	
i) Comilla(N) - Hathazari 230 KV line-2 tripped at 10:31 showing E/F & dist. Protection relays and was sitched on at 10:44.	
j) Chandpur - Chowmohani 132 KV line-1& 2 tripped at 10:41 showing dist & E/F relays and was switched on at 11:03.	
k) Barisal - Madaripur 132 KV line-1 & 2 tripped at 11:45 showing E/F relays and was switched on at 11:50.	
l) Ghorasal - Joydebpur 132 KV line-2 was shut down at 09:52 due to annual maintenance and was switched on at 14:47.	
m) Kishorganj 132/33 KV T3 transformer was shut down at 08:42 due to annual maintenance and was switched on at 14:05.	
	Due to generation shortage, about 50 MW (09:00) of load shed has been running since morning (01/12/10) over the whole area.

Deputy / Asstt. Manager
Network Operation Division

Manager
Network Operation Division

Deputy General Manager
Load Despatch Circle