POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date : 9-Mar-17 Till now the maximum generation is : - 9036 MW 21:00 Hrs on 30-Jun-16 Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yester 8-Mar-17 Generation & Demand Min. Gen. at Evening Peak Generation 7390.0 MW Hour 19:30 Max Generation 9560 E.P. Demand (at gen end) 7401.0 Hour 20:00 Max Demand (Evening) 8300 Maximum Generation 7390.0 MW Hour 19:30 Reserve (Generation end) 1260 Total Gen. (MKWH) 174.3 System L/ Factor Load Shed 98.25% 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 7.867 -260 MW at 15:00 Energy Import from West grid to East grid :- Maximum Energy at Water Level of Kaptai Lake at 9-Mar-17 91.72 Ft.(MSL) Actual: Rule curve : 92.02 Ft.(MSL) Gas Consumed: Total 898.88 MMCFD. Oil Consumed (PDB): HSD : FO Cost of the Consumed Fuel (F Gas Tk76,771,298 Coal Tk14,921,496 : Tk315,003,425 Total : Tk406,696,219 Load Shedding & Other Information Area Yesterday Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW (On Estimated Demand) Dhaka 0 0:00 3100 0:00 Chittagong Area Khulna Area 0 0:00 875 0 0:00 Rajshahi Area Comilla Area 0 0:00 640 0:00 486 Mymensingh Are Sylhet Area 0 0:00 309 0:00 Barisal Area 170 Rangpur Area 0 0:00 473 Total 7766 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/201(10) Baghabari-71 MW 2) Kaptai Unit-2 & 5 11) Sikalbaha ST 3) Ashuganj ST: Unit- 1,2 12) Sikalbaha Peaking GT 4) Khulna ST 110 MW (04/11/2014 13) Ghorasal ST: Unit-3 5) Ghorasal Unit-2,5 14) Tongi GT 6) Baghabari 100 MW 7) Haripur SBU GT- 1,3 8) Chittagong Unit-1, 2 9)Thakurgaon (RZ) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Baraulia-Abul Khair 132 kV Ckt was under shut down from 10:10 to 13:55 for maintenance work at Abulkhair S/S end b) Khulshi-Abulkhaair 132 kV Ckt was under shut down from 10:10 to 13:50 for maintenance work at Abulkhair S/S end. c) Saidour-Purbasadipur 132 kV Ckt-2 was under shut down from 09:08 to 09:42 due to red hot at bus side isolator Y-phase d) Goalpara S/S-NWPGCL 132 kV Ckt was under shut down from 10:36 to 16:57 for maintenance work at NWPGCL end. e) Sikalbaha GT was synchronized at 11:32. f) Fenchuganj S/S 132/33 kV TR2 transformer was under shut down from 09:44 to 16:56 for maintenance work g) Tongi 132/33 kV T1 & T2 transformers tripped at 13:07 from 33 kV sides showing O/C & E/F and were switched on at 13:18. About 20MW power interruption occurred under Tongi S/S area from 13:07 to 13:18. h) After maintenance Ashuganj 225 MW ST was synchronized at 09:43. i) Bottail 132/33 kV T1 & T2 transformers tripped at 08:44 from 33 kV sides showing inst. E/F and were switched on at 08:50. About 56MW power interruption occurred under Bottail S/S area from 08:44 to 08:50. j) Comilla(N)-Feni 132 kV Ckt-2 tripped at 14:11 from both sides showing dist.C, Z2 at Comilla(N) end and dist C,SOTF at Feni end and was switched on at 22:55.Again tripped at 00:56(09/03/2017) showing dist b-phase at Comilla(N) end & dist Z2, b-phase at Feni end k) Ashuganj(N) CCPP 450 MW was shut down at 19:26 for test purpose.) Shahjibazar 330MW CCPP GT-2 & ST tripped at 01:00(09/03/2017) showing Hazardous gas detected trip and GT-2 was synchronized at 05:25.

Executive Engineer

Network Operation Division

Superintendent Engineer

Load Dispatch Circle

Sub Divisional Engineer

Network Operation Division