POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date : 24-Mar-17 9036 MW Till now the maximum generation is: 21:00 Hrs on 30-Jun-16 Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterda Generation & Demand Day Peak Generation Evening Peak Generation 7059 N Hour 12:00 Min. Gen. at Max Generation 5749 MW 9452 8507.0 Hour 19:30 E.P. Demand (at gen end) 8507.0 MW Hour 19:30 Max Demand (Evening) 8000 Maximum Generation 8507.0 MW Hour 19:30 Reserve (Generation end) 1452 Total Gen. (MKWH) System L/ Factor : 8 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 80.08% 163.5 Export from East grid to West grid :- Maximum 7.867 Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake a 24-Mar-17 Energy 90.20 Ft.(MSL) Rule curve : 89.64 Ft.(MSL) Gas Consumed: Total 973.87 MMCFD. Oil Consumed (PDB): HSD FO Tk66.592.692 Cost of the Consumed Fuel (Gas Total: Tk405,964,921 Coal Oil : Tk324,372,602 **Load Shedding & Other Information** Area Yesterday Today Estimated Demand (S/S end) d Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) 3005 Dhaka 0:00 0:00 Chittagong Area 0 840 845 Khulna Area Rajshahi Area 0 0:00 819 0 Comilla Area 0:00 621 Mymensingh A 0:00 473 Sylhet Area 298 0 0:00 Barisal Area 0:00 165 Rangpur Area 0 0:00 459 7525 Total Information of the Generating Units under shut down. Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/201 10) Baghabari-71 MW 11) Sikalbaha ST 2) Kaptai Unit-2 & 5 3) Ashuganj ST: Unit- 1, 12) Sikalbaha Peaking GT 4) Khulna ST 110 MW (04/11/201 13) Ghorasal ST: Unit-1 5) Ghorasal Unit-5 14) Siddhirganj GT-1 & 2 6) Baghabari 100 MW 14) Tongi GT 15) Fenchuganj GT-1 & STG-1

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

b) Hasnabad 132/33 kV T1 transformer was under shut down from 11:39 to 14:07 for red hot maintenance at

c) Hasnabad 230/132 kV T02 was under shut down from 14:38 to 15:45 due to the temperature at 132 kV B-Phase

f) After maintenance Ashuganj Unit-3 was synchronized at 21:53. g) Fenchuganj GT-1 & STG-1 were shut down at 06:26 & 06:20 respectively (24/03/2017) for changing radiator skid.

Executive Engineer

Network Operation Division

a) Kallyanpur 132 kV Bus was under shut down from 10:39 to 12:37 for A/M.

d) After maintenance Ashuganj 225 MW CCPP GT was synchronized at 19:17.
e) After maintenance Haripur-Sonargaon 132 kV Ckt-1 & 2 were switched on at 21:11.

Description

R-Phase of 132 kV CT.

CT connector was high.

Sub Divisional Engineer

Network Operation Division

8) Chittagong Unit-2 9)Thakurgaon (RZ)

Comments on Power Interruption

Superintendent Engineer

Load Dispatch Circle