POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER OF-LDC-08 DAILY REPORT Page -1 Reporting Date 1-Jun-17 Till now the maximum generation is 9471 MW 22:00 Hrs on 27-May-17 Today's Actual Min Gen. & Probable 31-May-17 The Summary of Yesterda Generation & Demand Hour 12:00 Day Peak Generation 8015.0 MW Min. Gen. at 7:00 6213 MW Evening Peak Generation 8241.0 MW 19:30 Max Generation 10170 Hour MW E.P. Demand (at gen end) 8241.0 MW Hour 19:30 Max Demand (Evening) 9000 MW Maximum Generation 8295.0 MW Hour 14:00 Reserve (Generation end) 1170 MW System L/ Factor Total Gen. (MKWH) 184.6 92.29% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 7.867 MKWHR. 20 at 18:30 Energy Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 1-Jun-17 MW MKWHR. Actual : 75.94 Ft.(MSL) Rule curve : 76.00 Ft.(MSL.) 1055.19 MMCFD. Gas Consumed : Total Oil Consumed (PDB): HSD FO Liter Tk80,009,786 Cost of the Consumed Fuel (I Gas Coal Tk6,913,889 Tk384,739,559 Total: Tk471,663,234 Load Shedding & Other Information Area Yesterday Today Estimated Shedding (S/S end) Rates of Shedding Estimated Demand (S/S end) MW MW MW (On Estimated Demand) 3108 1071 0:00 0 Chittagong Area 0:00 0 0% Khulna Area 0 0:00 868 n 0% Rajshahi Area 0 0% 0:00 830 0 Comilla Area n 0.00 828 n 0% 0% 0 0:00 677 Mymensingh Are Sylhet Area Barisal Area 0 0:00 279 0 0% 177 Rangpur Area 0 0:00 512 0 0% 8350 Total Information of the Generating Units under shut down Forced Shut-Down Planned Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010 8) Haripur SBU-3 9) Chandpur CCPP 2) Kaptai Unit- 5 3) Khulna ST 110 MW (04/11/2014) 10) Ashuganj Unit-4 4) Ghorasal Unit-1,5 11) Barapukuria Unit-1 4) Ghorasal Unit-1,5 5) Baghabari 100 MW 6) Tongi GT 7) Chittagong Unit-1 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Comments on Power Interruption Description a) Mymensingh RPCL ST tripped at 08:09 due to voltages fluctuation and was synchronized at 13:56 b) Ashuganj(S) 450 MW CCPP ST tripped at 10:57 due to tripping of condensate pump. c) Hathazari 132/33 kV T2 transformer was under shut down from 12:45 to 13:05 due to ground connector loose. d) Sikalbaha-Shahmirpur 132 kV Ckt-1 was under shut down from 12:54 to 13:25 due to red hot at R-phase line isolator of Sikalbaha end. e) Ghorashal 100MW(Aggreko) tripped at 13:25 due to internal fault and was synchronized at 14:52. f) Ishurdi-Pabna 132 kV Ckt tripped at 19:04 from Ishurdi end showing Az.42 & 21s and was switched About 30 MW Power interruption occurred under Pabna S/S area from 19:04 to 19:12 g) Comilla(N)-Shahjibazar 230 kV Ckt-1 tripped at 18:58 from Comilla(N) end showing gen trip & M-21 and was switched on at 19:04. h) Hasnabad-Lalbagh 132 kV Ckt tripped at 19:48 from Hasnabad end showing dist A-phase & Z2 and was switched on at 19:58. i) Ashuganj-iishoreganj 132 kV Ckt-1 tripped at 17:58 from both ends showing dist-A at both ends and was switched on at 18:15. i) Ashugani B/C close at 18:12. k) After maintenance Ashuganj(S) 450 MW ST synchronized at 18:17. 1) Tongi 132/33 kV T1 & T2 transformers tripped at 19:44 showing O/C due to 33 kV DESCO feeder fa About 80 MW Power interruption occurred under Tongi S/S area were switched on at 19:57 & 20:58 respectively. from 19:44 to 19:57. n) Barisal-Patuakhali 132 kV Ckt tripped at 20:19 showing O/C and was switched on at 20:46. About 47 MW Power interruption occurred under Patuakhali S/S area from 20:19 to 20:46. n) Ashuganj-Ghorasal 132 kV Ckt-1 & 2 tripped at 21:03 from both end showing dist-A at Ashuganj end and remote protection.ZAC & 8B4 at Ghorasal end and were switched on at 22:11. o) Ashuganj ST Unit-3 tripped at 21:56 due to CW pump tripped and was synchronized at 03:02(01/06/2017). p) Kaptai-Madunaghat 132 kV Ckt-2 tripped at 02:36(01/06/2017) showing dist protection at both ends About 14 MW Power interruption occurred under Chandraghona S/S area switched on at 02:40. from 02:36 to 02:40(01/06/2017). q) Sikalbaha 225 MW GT tripped at 03:46 (01/06/2017) due to CB open and was synchronized at 07:32. r) Shahjibazar 132/33 kV TR2 transformer tripped at 16:02 and was switched on at 22:10. s) Bhola 225 MW & Summit Barisal P/S tripped at 06:36 (01/06/2017) due to grid trouble and Summit Barisal was synchronized at 06:58 t) Barisal-Bhandaria 132 kV Ckt-1 & 2 tripped at 06:36(01/06/2017) from Barisal end showing inst O/C About 80 MW Power interruption occurred under Bhandaria S/S area were switched on at 08:34. from 02:36 to 08:34(01/06/2017). u) Faridour-Madariour 132 kV Ckt-1& 2 tripped at 06:36 (01/06/2017) from Faridour end showing dist (About 200 MW Power interruption occurred under Faridour, Madariour & Barisal S/S area and were switched on at 06:51 & 06:52 respectively. from 02:36 to v) Madaripur-Barisal 132 kV Ckt-1 & 2 tripped at 06:36 (01/06/2017) from Madaripur end showing dist Z2 & E/F and from 02:36 to 06:51(01/05/2017). were switched on at 06:54 & 06:55 respectively. x) Madaripur-Gopalganj 132 kV Ckt tripped at 06:36 (01/06/2017) from Madaripur end showing DRETW and was switched on at 07:05.

Executive Engineer

Network Operation Division

Superintendent Enginee

Load Dispatch Circle

Page 1 of 7

Sub Divisional Engineer

Network Operation Division