POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

Reporting Date 9-Jun-17 Till now the maximum generation is: 9479 MW 21:00 Hrs on 7-Jun-17 The Summary of Yesterda Today's Actual Min Gen. & Probable Gen. & Demand 8-Jun-17 Generation & Demand Day Peak Generation 8549.0 12:00 7240 MW Min. Gen. at 7:00 **Evening Peak Generation** 9111.0 MM 21:00 Max Generation 9882 9111.0 MW E.P. Demand (at gen end) 21:00 Max Demand (Evening) 9700 Maximum Generation 9329.0 MW 1:00 Reserve (Generation end) 182 Total Gen. (MKWH) 207.5 System L/ Factor 92.67% Load Shed 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Oil Consumed (PDB):

Export from East grid to West grid :- Maximum -20 MW at 14:00 Energy 7 867 Import from West grid to East grid :- Maximum MW at Energy

Water Level of Kaptai Lake at 9-Jun-17

1052.61

Gas Consumed : Total

Ft.(MSL) 78.08 Ft.(MSL) 86.57 Rule curve :

HSD FO

Cost of the Consumed Fuel (Gas Tk84,307,176 Tk7,226,381 Coal

: Tk616,774,422 Total: Tk708,307,980

Load Shedding & Other Information

MMCFD.

Area	Yesterday			Today		
	MW		Estimated Demand (S/S end) MW	Estimated Shedding (S/S end) MW	Rates of Shedding (On Estimated Demand)	
Dhaka	0	0:00	3371	0	0%	
Chittagong Area	0	0:00	1163	0	0%	
Khulna Area	0	0:00	950	0	0%	
Rajshahi Area Comilla Area Mymensingh Are	0 0 0	0:00 0:00 0:00	904 895 731	0 0 0	0% 0% 0%	
Sylhet Area	0	0:00	307	0	0%	
Barisal Area	0	0:00	191	0	0%	
Rangpur Area	0	0:00	554	0	0%	
Total	0		9066	0		

Information of the Generating Units under shut down.

Forced Shut- Down Planned Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010 8) Haripur SBU-3 Nil 2) Kaptai Unit- 5 9) Sikalbaha ST 3) Khulna ST 110 MW (04/11/2014 10) Barapukuria ST: Unit-2 4) Ghorasal Unit-5 11) Ashugani ST: Unit- 2 5) Baghabari 100 MW 13) Ashuganj ST: Unit- 2 6) Tongi GT 7) Chittagong Unit-1

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description **Comments on Power Interruption**

- a) Chandpur 132/33 kV T1 transformer was under shut down from 08:40 to 09:4 About 24 MW power interruption occurred under Chandpur S/S area from 08:40 to 09:40.
- b) Shahjibazar 330 MW CCPP tripped at 11:23 due to low gas pressure and was synchronized at 02:36 (09/06/2017).
- c) Faridpur-Madaripur 132 kV Ckt-1 tripped at 16:08 from Faridpur end showing without any relay and was switched on at 16:19.
- d) Faridpur-Madaripur 132 kV Ckt-2 tripped at 16:08 showing E/F relay and was switched on at 16:19.
- e) Madaripur-Barisal 132 kV Ckt-1 & 2 tripped at 16:08 from Madaripur end showing E/F relay and were switched on at 16:20 & 16:32
- f) Madaripur-Gopalganj 132 kV Ckt tripped at 16:08 from Madaripur end showing DTEW relay and was switched on at 16:24. g) Barisal-Bhandaria 132 kV Ckt tripped at 16:08 from Barisal end showing inst.E/F relay and was switched on at 16:21.

At the same time Bhola CCPP, Barisal Summit 110 MW, Faridpur 54 MW pov About 212 MW power interruption occurred under Barisal (S), Madaripur, Gopalganj,

- h) After maintenance Shahjibazar 330 MW CCPP GT-2 synchronized at 02:36 (& Patuakhali S/S areas from 16:08 to 16:19.
- i) Haripur AES 360 MW was shut down at 04:06 (09/06/2017) due to HRGS tube maintenance.
- j) Bheramara-Bottail 132 kV Ckt-1 was shut down at 06:09 (09/06/2017) for development work. k) Ishurdi-Bheramara 132 kV Ckt-1 was shut down at 06:06 (09/06/2017) for development work.
- I) Bheramara 132 kV A bus was shut down at 06:13 (09/06/2017) for development work.
- m) Khulna (S)-Satkhira 132 kV Ckt-1 was shut down at 06:12 (09/06/2017) for development work.
- n) Aminbazar-Kaliakoir 230 kV Ckt-1 & 2 opened from Aminbazar end at 06:26 (09/06/2017).
- Tongi-Kaliakoir 230 kV Ckt-1 & 2 were switched on at 06:30 (09/06/2017).
- p) Tongi-Kabirpur 132 kV Ckt-1 & 2 opened from Kabirpur end at 06:46 (09/06/2017).
- q) Rampura-Haripur 230 kV Ckt-1 & 2 opened from Haripur end at 07:07 (09/06/2017).
- r) Tongi-Ghorasal 230 kV Ckt-1 & 2 opened from Tongi end at 07:15 (09/06/2017).
- s) Bheramara 360 MW CCPP GT tripped at 07:47 (09/06/2017) due to control system failure.
- t) Comilla (N)-Feni 132 kV Ckt-1 & 2 tripped at 23:34 from Comilla (N) end showing dist.relay and were switched on at 23:46.

Sub Divisional Engineer **Executive Engineer** Superintendent Engineer **Network Operation Division Network Operation Division Load Dispatch Circle** Page 1 of 7