POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER QF-LDC-08 DAILY REPORT Page -1 Reporting Date : 7-Jun-17 6-Jul-17 Till now the maximum generation is: 9479 MW 21:00 Hrs The Summary of Yesterda 5-Jul-17 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 7298 0 MW Hour 12:00 Min. Gen. at 7:00 6375 ΜW MW Evening Peak Generation 8897 0 MW Hour: 19:30 Max Generation 9975 E.P. Demand (at gen end) : MW 8897.0 MW Hour: 19:30 Max Demand (Evening): 9000 Maximum Generation Reserve(Generation end) MW 8897.0 MW Hour : 19:30 975 Total Gen. (MKWH) System L/ Factor 84.13% Load Shed MW EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR MKWHR. Export from East grid to West grid :- Maximum -10 MW at 10:00 Energy 7.867 MKWHR. Import from West grid to East grid :- Maximum MW at Energy Water Level of Kaptai Lake at 6-Jul-17 104.22 Ft.(MSL) Rule curve : 84.80 Ft.(MSL) 1022 70 MMCFD Oil Consumed (PDB): Gas Consumed : Total HSD : Liter FO Liter Cost of the Consumed Fuel (Gas Tk66,150,021 Coal Tk13,514,896 : Tk427,405,672 Total: Tk507,070,589 Load Shedding & Other Information Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka 0:00 3091 0 0 0% Chittagong Area 0:00 1065 0% 0 0 0:00 Khulna Area 0 862 0 0% Rajshahi Area 0 0:00 825 0 0% Comilla Area 0 0:00 824 0 0% Mymensingh Are 0 0:00 673 0 0% Sylhet Area 0:00 278 0% 0 0 Barisal Area 0:00 176 0% 0 0 Rangpur Area 509 0 Total 0 8303 0 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down 1) Ghorasal ST: Unit-6 (18/07 8) Haripur GT: Unit-1 9) Sikalbaha ST & GT 2) Kaptai Unit- 5 3) Khulna ST 110 MW (04/11 10) Ashuganj # 3 4) Ghorasal Unit-5 11) Rangpur GT 5) Baghabari 100 MW 6) Tongi GT 7) Chittagong Unit-1 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Comments on Power Interruption Description a) Summit Meghnaghat GT-1 & ST were synchronized at 11:46 & 18:18 respectively. b) Ashugani (S) STG was synchronized at 13:04. c) Halishahar 132/33 kV T3 transformer was under shut down from 19:45 to 21:45 due to red hot maintenance at 33 kV CT. d) Bogra-Natore 132 kV Ckt-1 & 2 were shut down at 06:15(06/07/2017) for development wok. e) Chandpur CCPP STG tripped at 04:44 (06/07/2017) due to Boiler drum pressure high.

f) Madunaghat 132/33 kV T1 transformer was shut down at 07:05 (06/07/2017) for red hot maintenance at 33 kV B-phase

Executive Engineer

Network Operation Division

Superintendent Engineer

Load Dispatch Circle

isolator

Sub Divisional Engineer

Network Operation Division