

**QF-LDC-08**  
**Page -1**

21:00 Hrs on 7-Jun-17

### EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Water Level of Kaptai Lake at 15-Jul-17

Oil Consumed (PDB) :

### Load Shedding & Other Information

Information of the Generating Units under shut down.

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description	Comments on Power Interruption
<p>a) Sirajganj-Ashuganj 230 kV Ckt-1 was under shut down from 09:40 to 11:09 for maintenance work.</p> <p>b) Comilla (N) 132/33 kV T4 transformer was under shut down from 11:02 to 11:53 for red hot maintenance.</p> <p>c) Hasnabad-Lalbag 132 kV Ckt was under shut down from 20:09 to 21:43 for red hot maintenance.</p> <p>d) After maintenance Ashuganj North GT was synchronized at 22:45.</p> <p>e) Bogra-Natore 132 kV Ckt-1 was shut down at 06:06 (15/07/2017) for maintenance work.</p>	
<p><b>Sub Divisional Engineer</b> <b>Network Operation Division</b></p>	<p><b>Executive Engineer</b> <b>Network Operation Division</b></p>
	<p><b>Superintendent Engineer</b> <b>Load Dispatch Circle</b></p>