

## Page -1

7-Jun-17

Hrs		On	7-Jul-17
Today's Actual Min Gen & Probable Gen & Demand			

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

67

Rule curve :

---

: Tk510.416.309

### Load Shedding & Other Information

Information of the Generating Units under shut down.

Forced Shut-Down

8) Haripur GT: Unit-1

9) Sikalhaha ST & peaking

10) Ashugani # 3

11) Ghorasal Unit-4

12) Baranukuria # 2

13) Khulna 225 MM

7) Chittagong Unit-1

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

### Comments on Power Interruption

About 36 MW power interruption occurred under Haliashahar S/S areas from 08:33 to 18:34.

at Kabirpur end

e) Barisal-Bhandaria 132 kV Ckt tripped at 12:32 showing dist at Barisal end and was switched on at 12:44

q) Satkhira 132/33 kV T1 transformer tripped at 11:58 due to 33 kV feeder fault and was switched on at 12:05.

About 15 MW power interruption occurred under Satkhira S/S areas from 11:58 to 12:05.

i) Barisal-Bhola 230 kV Ckt-1 tripped at 14:47 showing dist & line to neutral fault and was switched on at 15:38.

j) Madaripur 132/33 kV T1 (New) transformer was switched on at 14:37.

k)Ghorasal 230/132 kV AT2 transformer was under shut down from 23:43 to 01:02(30/07/2017) due to oil leakage

at 230 kV CB.

1) Ashuganj(N) CCPP was shut down at 23:58 for offline compressor cleaning.

m) Kabirpur-Kaliakoir 132 kV Ckt-2 was under shut down from 05:46 to 06:52 (30/07/2017) for red hot

maintenance at R-phase T-connector at Kabirpur end.

n) Bheramara-Ishurdi 132 kV Ckt-1 was shut down at 06:25(30/07/2017) for project

o) Bheramara 132 kV bus-A was shut down at 06:40(30/07/2017) for project work.

**Superintendent Engineer**  
**Load Dispatch Circle**