POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER OF-LDC-08 DAILY REPORT Page -1 Reporting Date : 10-Aug-17 Till now the maximum generation is 9479 MW Hrs 7-Jun-17 Gen. & Demand The Summary of Yesterda 9-Aug-17 Generation & Demand Today's Actual Min Gen. & Probable 12:00 Hour Day Peak Generation 8088.0 MW Min. Gen. at 7:00 7172 MW Evening Peak Generation 9037.0 Hour Max Generation 10054 MW E.P. Demand (at gen end) 9037.0 MW Hour 19:30 Max Demand (Evening) 10000 MW Maximum Generation Total Gen. (MKWH) 9037.0 MW Hour 10:30 Reserve(Generation end) 54 MW System L/ Factor 196.6 90.65% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 7.867 MKWHR. at 15:00 Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 10-Aug-17 MW Energy MKWHR 105.75 Ft.(MSL) Rule curve : 91.88 Ft.(MSL) Gas Consumed : Total 986.89 MMCFD. Oil Consumed (PDB): HSD Liter FO Tk65,459,199 Cost of the Consumed Fuel (I Gas Coal Tk14,101,206 Tk571,896,340 Total: Tk651,456,745 Load Shedding & Other Information Area Yesterday Today Estimated Shedding (S/S end) Estimated Demand (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka Chittagong Area 0:00 3460 1193 0% 0% 0 0:00 0 Khulna Area 0 0:00 978 0 0% Rajshahi Area 0:00 929 0 0% Comilla Area n 0.00 918 n 0% 0 749 0% Mymensingh Are 0:00 Sylhet Area Barisal Area 0 0:00 317 0 0% 195 Rangpur Area 0 0:00 568 0 0% Total 9307 Information of the Generating Units under shut down Planned Shut- Down Forced Shut-Down 1) Ghorasal ST: Unit-6 (18/07 8) Haripur GT: Unit-1 Nil 2) Kaptai Unit- 5 9) Sikalbaha ST & peaking 3) Khulna ST 110 MW (04/11 10) Ashuganj #2,3 4) Ghorasal Unit-5 11) Ghorasal Unit-2 5) Baghabari 100 MW & 71 MW 6) Tongi GT 7) Chittagong Unit-1,2 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Comments on Power Interruption Description a) Sirajganj 225 MW CCPP GT Unit-2 was synchronized at 09:29. b) Barisal (N) 230/132 kV T01 transformer tripped at 10:55 showing PRD relay and was switched on at 16:02. c) AES Meghnaghat 450 CCPP GT-1 was synchronized at 12:53. d) Bheramara-Faridpur 132 kV Ckt-2 was under shut down from 15:11 to 16:20 due to SCADA maintenance. e) Bheramara-Faridpur 132 kV Ckt-1 was under shut down from 16:27 to 16:54 due to SCADA maintenance. f) Tangail all 33 kV incoming CBs tripped at 17:08 due to Bhuapur 33 kV feeder problé About 110 MW power interruption occurred under Mymensingh S/S area at 17:15. from 17:08 to 17:15. g) Kushiara 163 MW GT was synchronized at 15:15. h) Mymensingh RPCL G1-1 & G1-2 were synchronized at 17:15. i) Tangail all 33 kV incoming CBs tripped at 20:52 due to B-Phase CT of capacitor ba About 110 MW power interruption occurred under Mymensingh S/S area switched on at 21:03. At the same time Mymensingh RPCL tripped. from 20:52 to 21:03. j) Mymensingh RPCL GT-1 & GT-2 were synchronized at 21:20. k) Kusniara 103 MW GT was snut down at 23:08 for the preparation of performance test. I) Bogra-Polasnoari 132 KV CKt-2 was snut down at U5:34 (10/08/2017) for development work.

m) Rangpur-Palashbari 132 kV Ckt-1 was shut down at 05:35 (10/08/2017) due to limit load of other lines.

Executive Engineer

Network Operation Division

Superintendent Engineer

Load Dispatch Circle

Sub Divisional Engineer

Network Operation Division