			POWER GRID COMPANY OF BANGLADESH	LTD.					
			NATIONAL LOAD DESPATCH CENTER						QF-LDC-0
			DAILY REPORT						Page -1
						Reporting		17	_
Till now the ma The Summary o		ration is : - 12-Aug-17	9479 MW Generation & Demand	21:		on 7-Jun- ctual Min Gen. & P		omand	
Day Peak Genera		6658.0	MW	Hou 12:00	Min. Gen.	at 7:0	0 6149	MW	
Evening Peak Ge		179.0	MW	Hou 20:00			10040		
E.P. Demand (at Maximum Gener		8752.0 8752.0	MW MW	Hou 20:00 Hou 20:00		and (Evening) : seneration end)	9800 240	MW MW	
Total Gen. (MKW		170.5	System L/ Factor :	81.18%			0	MW	
		E	EXPORT/IMPORT THROUGH EAST-WEST INTERC			•	-		
Export from East of					at 9:00		nergy 7.867		
Import from West	Vater Level of			MW	at -		nergy -	MKWHI	R.
Actual :	107.77 F	t.(MSL),	Rule	curve : 92.84	Ft.( MSL	.)			
Gas Consumed :	l otal	977.58	MMCFD.	Oil Cons	umed (PDB):	HSD		Liter	
						FO		Liter	
Cost of the Consu	med Fuel		: Tk60,776,952	Oil	· TI222 003	0.010 T	tal : TI207 494	460	
		Coal	: Tk13,710,590	OII	: Tk322,993	), 3 i 3 i 1 (	otal : Tk397,481,	<del>-1</del> 00	
	Lo	ad Shedding	& Other Information						
					<b>-</b>				
Area	Yeste	uay	Estimated Demand (S/S end)		Today Estimated	Shedding (S/S en	d) Rates of S	Sheddina	
	MW		MW			MW		ted Demand)	
Dhaka	0	0:00	3427			0			
Chittagong Area	0	0:00 0:00	1182 967			0			
Khulna Area Rajshahi Area	0	0:00	920			0			
Comilla Area	0	0:00	910			0			
Mymensingh Are	0	0:00	743			0	0%		
Sylhet Area	0	0:00	313			0	0%		
Barisal Area	0	0:00	194			0	0%		
Rangpur Area	0	0:00	563			0	0%		
Total	0		9219			0			
			<b>V2.10</b>						
	Informat	on of the Ge	nerating Units under shut down.						
	Planned Shut	- Down		Forced S	Shut- Down				
				1) Ghoras	sal ST: Unit-6	(18/07/201 8) Har			
Nil				2) Kaptai	i Unit- 5	9) Sika	Ibaha ST & peaki	ng	
						(04/11/201 10) Ash			
					sal Unit-5		nuganj 450 MW (N	orth)	
						& 71 MW 12) Gh	iorasal Unit-4		
				6) Tongi					
				7) Crittag	gong Unit-1				
	Additional Info	ormation of N	Machines, lines, Interruption / Forced Load shed et	c.					
			Description			Comm	ents on Power Int	terruntion	
			Description .			Commi	citis off tower in	ciraption	
a) Tongi (New) 33	kV breaker of	132/33 kV T	1 transformer burst at 11:07 at the same time			interruption occurre			
132/33 kV T2 t	ransformer als	tripped an	d T2 was switched on at 12:01.	from 11:0	07 to 12:01 ar	nd 50 MW power in	terruption has bee	n running.	
			r was under shut down from 09:19 to 12:36 due to DO						
			hut down from 13:05 to 14:17 for red hot maintenance	ce at Comilla(S) S/	S end.				
c) Feni-Comilla(N	CCPP GT wa	s synchronize	ed at 13:24 and was shut down at 15:20.					. 0/0	
c) Feni-Comilla(N d) Sirajganj (new)	2/33 kV T2 tra	ınsformer wa	s under shut down from 16:16 to 17:54 for facilitate t	ne maint About 20	) MW power in 16 to 17:54.	iterruption occurred	under I ongi (New	) S/S area	
c) Feni-Comilla(N d) Sirajganj(new) e) Tongi(New) 13		neformer wa	s under shut down from 06:40 to 07:32 (13/08/2017)		10 10 17:54.				
c) Feni-Comilla(N d) Sirajganj (new) e) Tongi (New) 13: work of T1.	2/33 W/ T2 +~	naomiei was	sunder shut down from 00.40 to 07.32 (13/08/2017)	ioi mannenance					
c) Feni-Comilla(N d) Sirajganj (new) e) Tongi (New) 13 work of T1. f) Kishoreganj 132									
c) Feni-Comilla(N d) Sirajganj (new) e) Tongi (New) 13 work of T1. f) Kishoreganj 132 work on 33 kV si	de bus loop.	at 05:11 due	to axial shift tripped.						
c) Feni-Comilla(N d) Sirajganj (new) e) Tongi (New) 13 work of T1. f) Kishoreganj 132 work on 33 kV si	de bus loop.	at 05:11 due	to axial shift tripped.						
c) Feni-Comilla(N d) Sirajganj (new) e) Tongi (New) 13 work of T1. f) Kishoreganj 132 work on 33 kV si	de bus loop.	at 05:11 due	to axial shift tripped.						
c) Feni-Comilla(N d) Sirajganj (new) e) Tongi (New) 13 work of T1. f) Kishoreganj 132 work on 33 kV si	de bus loop.	at 05:11 due	to axial shift tripped.						
c) Feni-Comilla(N d) Sirajganj (new) e) Tongi (New) 13: work of T1. f) Ki shoreganj 132 work on 33 kV si	de bus loop.	at 05:11 due	to axial shift tripped.						
c) Feni-Comilla(N d) Sirajganj (new) e) Tongi (New) 13: work of T1. f) Ki shoreganj 132 work on 33 kV si	de bus loop. Init-4 tripped al Engineer		to axial shift tripped.  Executive Engineer  Network Operation Division				ent Engineer oatch Circle		