## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER

QF-LDC-08

DAILY REPORT Page -1 Reporting Date : 7-Jun-17 14-Sep-17 Till now the maximum generation is : 9479 MW 21:00 Hrs The Summary of Yesterda 13-Sep-17 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 7934 0 MW Hour 12:00 Min. Gen. at 7:00 7027 ΜW Evening Peak Generation 9049 0 MW Hour: 21:00 Max Generation 9752 MW E.P. Demand (at gen end) : MW 9049.0 MW Hour: 21:00 Max Demand (Evening): 9700 Maximum Generation Reserve(Generation end) MW 9049.0 MW Hour : 22:00 52 Total Gen. (MKWH) System L/ Factor 89.48% Load Shed MW 194.3 EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MKWHR. -160 MW at 10:00 Energy 7.867 MKWHR. Import from West grid to East grid :- Maximum MW at Energy Water Level of Kaptai Lake at 14-Sep-17 108.42 Ft.(MSL) 101.99 Ft.( MSL ) Rule curve : 1022 82 Gas Consumed : Total MMCFD Oil Consumed (PDB):

Cost of the Consumed Fuel ( Gas : Tk72,607,195

Coal : Tk11,288,781

HSD : Liter FO : Liter

Total: Tk644,118,771

## Load Shedding & Other Information

Area	Yesterday			Today	
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
MW			MW	MW	(On Estimated Demand)
Dhaka	0	0:00	3397	0	0%
Chittagong Area	0	0:00	1172	0	0%
Khulna Area	0	0:00	958	0	0%
Rajshahi Area	0	0:00	911	0	0%
Comilla Area	0	0:00	902	0	0%
Mymensingh Are	0	0:00	736	0	0%
Sylhet Area	0	0:00	310	0	0%
Barisal Area	0	0:00	192	0	0%
Rangpur Area	0	0:00	558	0	0%
Total	0		9136	0	

: Tk560,222,795

Information of the Generating Units under shut down.

Planned Shut- Down

1) Ashuganj # 3
10) Meghnaghat CCPP

2) Kaptai Unit- 5
11) Sikalbaha Peaking GT
3) Khulna ST 110 MW (04/11 12) Santahar Peaking
4) Ghorasal Unit-3,5
5) Baghabari 100 MW
6) Tongi GT
7) Chittagong Unit-1,2
8) Sikalbaha ST
9)Baghabari GT

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Comments on Power Interruption

- a) Barapukuria Unit-1 tripped at 14:50 showing voltage fluctuation and was synchronized at 19:42.
- b) Sreemongal-Fenchuganj S/S 132 kV Ckt-1 & 2 tripped at 01:50 (14/09/2017) showing dist.relay and were synchronized at 02:29 & 02:32 respectively.

At the same time Shahjibazar Prima, Fenchuganj EPL were also tripped.

- c) Bheramara 132 kV (New S/S) bus B was shut down at 07:04 (14/09/2017) for development work.
- d) Satkhira 132/33 kV T2 transformer was under shut down from 07:14 to 08:40 (14/0 About 7 MW power interruption occurred under Satkhira S/S area from 07:14 to 08:40 (14/09/2017).
- e) Gopalganj 132/33 kV T2 transformer was under shut down from 07:14 to 10:54 (14/About 14 MW power interruption occurred under Gopalganj S/S area at 33 kV C1 terminal.
- f) Tongi 132/33 kV T2 transformer was shut down at 07:47 (14/09/2017) for red hot maintenance.

Sub Divisional Engineer Executive Engineer Superintendent Engineer
Network Operation Division Network Operation Division Load Dispatch Circle