POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER QF-LDC-08 DAILY REPORT Page -1 Reporting Date 29-Sep-17 9479 MW Till now the maximum generation is: 21:00 Hrs 7-Jun-17 Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterda 28-Sep-17 Generation & Demand Day Peak Generation 11:00 8614.2 Min. Gen. at 7:00 5051 **Evening Peak Generation** 8910 N MM 19:30 Max Generation 9932 MW MW E.P. Demand (at gen end) 8910.0 MW 19:30 Max Demand (Evening) 9000 Maximum Generation MW 19:30 932 MW 8910.0 Reserve(Generation end) Total Gen. (MKWH) 200.3 System L/ Factor 93.66% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 70 MW at 17:00 Energy 7 867 MKWHR. Energy MKWHR Import from West grid to East grid :- Maximum MW at Water Level of Kaptai Lake at 29-Sep-17 Ft.(MSL) 105.52 108.73 Rule curve : Ft.(MSL) Gas Consumed : Total 980.39 MMCFD. Oil Consumed (PDB): HSD Liter FO Liter Cost of the Consumed Fuel (Gas Tk79,767,121 Tk9,179,457 : Tk565,205,393 Total : Tk654,151,971 **Load Shedding & Other Information** Yesterday Area Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MM MW (On Estimated Demand) Dhaka 0 0:00 3159 0 0% 0:00 1089 0% Chittagong Area 0 0 Khulna Area 0:00 884 0 0% 0 Rajshahi Area 0 0:00 844 0 0% Comilla Area 0:00 841 0 0% Mymensingh Are n 0.00 687 n 0% Svlhet Area 0 0:00 285 0 0% Barisal Area 0:00 179 0 0% 0 Rangpur Area 0 0:00 520 0 0% Total 8488 0 Information of the Generating Units under shut down Planned Shut- Down Forced Shut- Down 1)Ashuganj CCPP(South) 10) Ashuganj-225 MW. Nil 2) Kaptai Unit- 5 3) Khulna ST 110 MW (04/11/2014) 4) Ghorasal Unit-2,5 5) Baghabari 100 MW 6) Tongi GT 7) Chittagong Unit-1,2 8) Sikalbaha ST 9)Baghabari-71 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Comments on Power Interruption Description

- a) Ashuganj-Sirajganj 230 kV Ckt-1 was shut down at 09:20 due to development work.
- b) Aminbazar-Kaliakoir 230 kV Ckt-1 was under shut down from 09:46 to 17:15 for development work.
- c) Mymensingh 132/33 kV T2 transformer was under shut down from 10:25 to 11:35 due to high temperature of 132 kV,Y-Phase isolator.
- d) Comilla (N) 132/33 kV T3 transformer was under shut down from 11:25 to 14:35 for 33 kV cable replacement work.
- e) After maintenance Barapukuria Unit-2 was synchronized at 12:25.
- f) Faridpur-Bheramara 132 kV Ckt-2 tripped at 13:13 showing dist.relay and was switched on at 15:19.
- g) Goalpara 132/33 kV T6 transformer tripped at 11:30 from both sides s About 20 MW power interruption occurred under Goalpara S/S area from 11:30 to 11:35.
- h) Goalpara-Bagerhat 132 kV Ckt-1 & 2 tripped at 13:50 from Goalpara About 33 MW power interruption occurred under Bagerhat & Mongla S/S areas at 14:07. At the same time KPCL-1 & 2 were tripped. from 13:50 to 14:07.
- I) Barisal-Patuaknali 132 кV Скт tripped at 14:24 due to conductor torn al About 28 MW power interruption occurred under Patuakhali S/S area from 14:24 to 17:13.

- j) Munshiganj 132/33 kV T2 transformer was under shut down from 15:34 About 20 MW power interruption occurred under Munshiganj S/S area from 15:34 to 16:21.
- k) Khulshi-AK steel 132 kV Ckt was under shut down from 16:16 to 16:37 due to MCB replacement work at Khulshi end.
- Baghabari-Ishurdi 230 kV Ckt-2 was switched on at 17:33.
- m) Ashuganj (S) 450 MW was forced shut down at 21:35 due to exhaust temperature high.
- n) Ashuganj-Kishoreganj 132 kV Ckt-1 tripped at 00:53 (29/09/2017) showing dist.relay and was switched on at 01:54 (29/09/2017).
- o) Matuail-Haripur 132 kV Ckt tripped at 01:35 (29/09/2017) showing E/F relay at Matuail end and was switched on at 01:44 (29/09/2017).
- p) Ullon-Haripur 132 kV Ckt tripped at 01:43 (29/09/2017) showing dist.relay and was switched on at (29/09/2017).
- g) Shyampur 132/33 kV GT-2 transformer tripped at 03:38 (29/09/2017) About 20 MW power interruption occurred under Shyampur S/S area under maintenance. from 03:38(29/09/2017) to till now.

Sub Divisional Engineer Executive Engineer Superintendent Engineer Network Operation Division Network Operation Division Load Dispatch Circle