POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER QF-LDC-08 DAILY REPORT Page -1 Reporting Date 8-Oct-17 Till now the maximum generation is : 9479 MW 21:00 Hrs on 7-Jun-17 Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterda 7-Oct-17 Generation & Demand Day Peak Generation 7602.7 12:00 MW MW Min. Gen. at 7:00 6838 **Evening Peak Generation** 9428.0 MM 20:00 Max Generation 10033 MW MW 9428.0 MW E.P. Demand (at gen end) 20:00 Max Demand (Evening) 9900 Maximum Generation 9428.0 MW 20:00 Reserve(Generation end) 133 MW Total Gen. (MKWH) System L/ Factor 86.02% 194.6 Load Shed 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR at 17:00 MKWHR. Export from East grid to West grid :- Maximum 0 MW Energy 7.867 MKWHR Import from West grid to East grid :- Maximum MW at Energy Water Level of Kaptai Lake at 8-Oct-17 108.78 Ft.(MSL) 106.63 Rule curve Ft.(MSL) Gas Consumed : Total 1053.06 MMCFD. Oil Consumed (PDB): HSD Liter FO Liter Cost of the Consumed Fuel (Gas Tk65,703,115 Tk6,445,148 : Tk493,861,464 Total: Tk566,009,727 Coal **Load Shedding & Other Information** Yesterday Area Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka 0 0:00 3447 0 0% 1189 Chittagong Area 0:00 0% 0 0 Khulna Area 0:00 974 0 0% 0 Rajshahi Area 0 0:00 926 0 0% Comilla Area 0:00 915 0 0% Mymensingh Are n 0.00 747 n 0% Svlhet Area 0 0:00 315 0 0% 0% Barisal Area 0:00 195 0 0 Rangpur Area 0 0:00 566 0 Total 9274 0 Information of the Generating Units under shut down. Forced Shut- Down Planned Shut- Down 1) Bhola-225 MW ST 10) Ashuganj#2 & 3 11) Ghorasal Max 2) Kaptai Unit- 5 Nil 1 12) Siddirganj-210 MW ST 3) Khulna ST 110 MW (04/1 4) Ghorasal Unit-2,4,5 13) Sikalbaha GT 5) Baghabari 100 MW 6) Tongi GT 7) Chittagong Unit-1,2 8) Sikalbaha ST 9)Baghabari-71 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. **Comments on Power Interruption** Description a) Chapainawabganj 132/33 kV T3 transformer was under shut down from 08:10 to 16:42 for A/M. b) Kishoreganj 132/33 kV T1 transformer was under shut down from 12:52 to About 20 MW power interruption occurred under Kishoreganj S/S area from 12:52 to 13:22. c) Kishoreganj 132/33 kV T3 transformer was under shut down from 09:48 to 13:20 for red hot maintenance. d) Sylhet -Chattak 132 kV Ckt-1 tripped at 07:52 showing dist A-phase and was switched on at 08:03. e) Sirajganj CCPP Unit-2 GT was synchronized at 14:13 for test purpose and was shut down at 18:05. f) Joydevpur 132/33 kV T4(New) transformer was switched on at 14:34. g) After maintenance Haripur-Rampura 230 kV Ckt-2 was switched on at 15:20. n) Sylhet 150 MW G1 tripped at 22:41 due to gas problem and was synchronized at 23:51. i) After maintenance Barapukuria ST Unit-2 was synchronized at 04:05(08/10/2017). j) Savar 33 kV bus was under shut down from 06:13 to 08:18 (08/10/2017) fd About 70 MW power interruption occurred under Savar S/S area from 06:13 to 08:18 (08/10/2017). K) Kallakoir 400/132 kV TR2 transformer was under shut down from 05:46 to 07:59 (08/10/17) due to red not at Y-phase CT busning. I) Mymensingn 132/33 kV TT, T2 & T3 transformers were under shut down ti About 96 MW power interruption occurred under Mymensingh S/S area

- 1) Mymensingn 132/33 KV 11,12 & 13 transformers were under snut down transformers before under Mymensingh S/S area B-phase bus coupler isolator.

 About 96 MW power interruption occurred under Mymensingh S/S area from 06:21 to 07:18 (08/10/2017).
- m) Ashuganj-Sirajganj 230 kV Ckt-1 was shut down since 07:44 (08/10/2017) for development work.
- n) Barisal 230/132 kV T1 transformer was shut down since 07:26 (08/10/2017) for A/M.

Sub Divisional Engineer Network Operation Division Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle