

QF-LDC-08  
Page -1

### EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Cost of the Consumed Fuel (PDB) :	Gas	:	Tk56.627.625		Oil	:	Tk16.165.196		Total	:	Tk72.792.821
-----------------------------------	-----	---	--------------	--	-----	---	--------------	--	-------	---	--------------

Area	Yesterday			Today			
	Actual Shedding (s/s end)			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	MW	fro	to				
Dhaka	203	(19:00-05:40, gen. shortage)		1622	-	-	
Chittagong Area	114	(19:00-05:20, gen. shortage)		481	60	12%	
Khulna Area	107	(19:00-05:40, gen. shortage)		454	56	12%	
Rajshahi Area	73	(19:00-05:40, gen. shortage)		332	41	12%	
Comilla Area	56	(19:00-05:10, gen. shortage)		245	30	12%	
Mymensing Area	49	(19:00-05:10, gen. shortage)		219	27	12%	
Sylhet Area	34	(19:00-05:05, gen. shortage)		149	18	12%	
Barisal Area	13	(19:00-05:40, gen. shortage)		80	10	13%	
Rangpur Area	44	(19:00-05:40, gen. shortage)		188	23	12%	
<b>Total</b>	<b>693</b>	<b>20:00</b>		<b>3770</b>	<b>265</b>		

Planned Shut-Down	Forced Shut-Down
1) Khulna 60 MW (05/07/06)	8) Baghabari GT-2(02/07/09)
	9) Ashugani CCPP ST (02/09/09)
	10) Westmont -1 (02/09/09)
2) Shajibazar- 2 (13/07/08)	
3) Shajibazar-4 (18/10/08)	
4) Khulna 110 (31/03/09)	
5) RPCL GT-4 (06/06/09)	
6) RPCL GT-2 (30/08/10)	
7) Sikalbaha ST (02/09/09)	

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 693 MW (20:00) of load shed was imposed over the whole area of the national grid .
b) Due to gas limitation, Raozan (360 MW), Tongi GT (105 MW), RPCL (105 MW), MPL (450 MW) and HPL (360 MW) were limited to 240 MW ,40 MW,106 MW,430 MW and 263 MW respectively.	
c) Due to gas limitation, Shahjibazar - 4 & 5, Haripur SBU GT- 2 & 3 (64 MW) were under shut down.	
d) Sylhet GT 20 MW was under shut down from 15:02 to 20:38 due to NLDC project work.	
e) Haripur NEPC tripped at 20:32 due to low gas pressure and was synchronized at 23:51.	
f) After maintenance, Ashuganj CCPG GT -1 was synchronized at 23:00.	
g) Jessore - Noapara 132 KV line -1 and Sylhet - Chatak 132 KV line -2 were under NLDC project work from 09:15 to 15:23 and 09:25 to 10:48 respectively.	
h) Hasnabad - Meghnaghat 230 KV line -1 was under shut down from 09:20 to 22:08 due to changing of upper bus. Again line -2 is under shut down since 07:57 (04/09/09) due to the same reason.	
i) Rampura 132 KV bus -I was shut down at 09:34 due to project work.	
j) Comilla (N) - Feni 132 KV line -1 ( both end) & 2 ( Feni end) , Feni - Hathazari 132 KV line -1 (Hathazari end) & 2 (both end) and Chandpur - Chowmuhani 132 KV line -1 & 2 ( Chandpur end) tripped at 12:13 showing ' DIST Z1 & 3' , ' DIST Z2', 'DIST C-phase Z3' , 'DIST Z3 , E/F', ' DIST RY Z-1,2,3', ' DIST BC-phase E/F' and ' E/F' respectively and were switched on at 12:56, 12:31, 12:36, 13:08, 12:13 and 12:14 respectively.	Power interruption occurred under Feni (35 MW) and Chowmuhani (37 MW) S/S areas from 12:13 to 12:31.
k) Hasnabad 132/33 KV T1 transformer tripped at 08:07 (04/09/09) showing ' VAJ TC' and was switched on at 09:35 (04/09/09).	

Deputy General Manager  
Load Despatch Circle