POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08
Page -1
Reporting Date: 20-Dec-17

0

Till now the maximum generatic 9507 MW 19:30 Hrs 18-Oct-17 on The Summary of Ye 19-Dec-17 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 5830.2 MW 9:00 Min. Gen. at 5:00 **Evening Peak General** 7889.0 MW 19:00 Max Generation 9646 MW E.P. Demand (at gen ε 7889.0 MW 19:00 Max Demand (Evening) 8000 MW Maximum Generation 7889.0 MW 19:00 Reserve(Generation end) 1646 MW

140.5 System L/ Factor : 74.19% Load Shed

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- -380 MW 16:00 Energy 7.867 MKWHR. Import from West grid to East grid :- - MW - Energy - MKWHR.

Water Level of Kaptai I 20-Dec-17

Total Gen. (MKWH)

Actual: 102.28 Ft.(MSL), Rule curve: 104.20 Ft.(MSL)

Gas Consum Total 852.62 MMCFD. Oil Consumed (PDB):

HSD : Liter FO : Liter

Comments on Power Interruption

Cost of the Consumed Gas: Tk78,126,473

Coal : Tk8,803,901 Oil : Tk211,413,799 Total : Tk298,344,172

Load Shedding & Other Information

Area	,	Yesterday		Today	
		•	Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	2814	0	0%
Chittagong A	0	0:00	969	0	0%
Khulna Area	0	0:00	776	0	0%
Rajshahi Are	0	0:00	747	0	0%
Comilla Area	0	0:00	753	0	0%
Mymensingh	0	0:00	616	0	0%
Sylhet Area	0	0:00	248	0	0%
Barisal Area	0	0:00	161	0	0%
Rangpur Are	0	0:00	465	0	0%
Total	0		7549	0	

Information of the Generating Units under shut down.

Planned Shut- Down	Forced Shut- Down	
	1) Barapukuria ST: Unit-1	10) Ashuganj # 2 & 3
Nil	2) Kaptai Unit- 5	11) Ashuganj North
	3) Khulna (04/11/14)	12) Sirajganj CCPP-1
	4) Ghorasal Unit-1,2,3,7	13) Summit Bibiyana
	5) Baghabari 100 MW	14) Sylhet 150 MW GT
	6) Tongi GT	, ,
	7) Chittagong Unit-1,2	
	8) Sikalbaha GT, ST	
	0) Paghahari 71 MM	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description

- a) Shikalbaha-Dohazari 132 kV Ckt-1 was under shut down from 10:04 to 13:36 for A/M.
- b) Comilla(N)-Meghnaghat 230 kV Ckt-2 was under shut down from 08:32 to 18:03 for A/M.
- c) AKSML-BSRM 230 kV Ckt-2 was under shut down from 08:50 to 15:49 for A/M.
- d) Jamalpur-Mymensing 132 kV Ckt-2 was under shut down from 08:35 to 16:30 for A/M.
- e) Ashuganj-B.Baria 132 kV Ckt-1 was under shut down from 09:15 to 14:31 for A/M.
- f) Shahjibazar-Sreemongal 132 kV Ckt-2 was under shut down from 09:19 to 16:43 for A/M.
- g) Hathazari s/s 132/33 kV T2 transformer was under shut down from 08:36 to 14:29 for A/M.
- h) Bogra-Shirajgonj 132 kV Ckt-1 was under shut down from 08:42 to 16:27 for A/M
- i) Raishahi-Chapainawabdani 132 kV Ckt-1 was under shut down from 09:30 to 14:25 for A/M.
- j) Ishurdi-Ghorashal 230 kV Ckt-1 was under shut down from 08:18 to 17:16 for A/M.
- k) Saidpur-Baropukuria 132 kV Ckt-1 was under shut down from 08:10 to 16:43 for A/M.
- I) Khulna(S)-Khulna(C) 132 kV Ckt-1 was under shut down from 09:12 to 15:47 for A/M.
- m) Barishal-Bhandaria 132 kV (Ckt was under shut down from 08:08 to 16:49 for A/M n) Bheramara HVDC-Khulna(S) 230 kV Ckt-1 was under shut down from 09:45 to 17:22 for A/M
- o) AmnuraS/S-Amnura RPP 132 kV Ckt was under shut down from 08:44 to 12:34 for development work.
- p) Shahjibazar 330 MW GT1 tripped at 11:27 due to tripping of GBC and synchronized at 17:31.
- q) Shahmirpur-Shikalbaha 132 kV Ckt-1 was under shut down from 09:45 to 14:50 for A/M.
- r) After maintenance Sylhet 150 MW GT was synchronized at 18:38.
- s) After maintenance Feni-Hathazari 132 kV Ckt-1 was switched on at 20:45.
- t) After maintenance Bibiyana 400kV Bus-2 was switched on at 15:50.
- u) Amnura 132 kV Bus-1 was shut down at 15:10 due to development work.
- v) Comilla(N)-Chandpur 132 kV Ckt-1 tripped at 03:25(20/12/2017) from Chandpur without operating any relay and switched on at 03:45.
- w) Comilla(N)-Chandpur 132 kV Ckt-2 tripped at 03:25(20/12/2017) from both ends showing Dist. Z-3 at both ends.
- x) Madanganj 132/33 kV T1 transformer tripped at 05:22(20/12/2017) showing Buchholz relay.
- y) Fenchuganj 132/33 kV T1 transformer was shut down at 06:48 due to Redhot at 33 kV, Y phase CT connector.

Sub Divisional Engineer Network Operation Division

Executive Engineer
Network Operation Division

Superintendent Engineer Load Dispatch Circle