POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER, LDC, DHAKA. DAILY REPORT

20:00

Forced load shaded / Interrupted Areas

Oil Consumed (PDB):

MW

QF-LDC-08 Page -1

8819500 KWHR.

KWHR.

Reporting Date : Till now the maximum generation is: - MW at 4266 5 5:00 Hrs The Summary of Yesterday's (10-Sep-09) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 3394 MW Hour 11:00 Min Gen. at **Evening Peak Generation** 3895.5 1/1/1/ Hour 20:00 Max Generation 4105 MW 4550 MW E.P. Demand (at gen end) : 4800.0 MW Hour 20:00 Max Demand Maximum Generation 4007.0 MW Shortage 445 MW Hour 4:00 Total Gen. (MKWH) System L/ Factor 92.35% Load Shed 372 MW 88.17 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

430 MW

Water Level of Kaptai Lake at 6:00 A M of 11-Sep-09 99.68 . 101.30 Ft.(MSL) Actual

MMCFt

Ft.(MSL) Rule curve

> HSD 465062 Liter

Energy

Energy

FO 0 Liter

Cost of the Consumed Fuel (PDB): Gas Tk55 481 281 : Tk18.602.488 Total: Tk74.083.769

Load Shedding & Other Information

750.66

Export from East grid to West grid :- Maximum

Import from West grid to East grid :- Maximum

Description

Gas Consumed: Total

Area	Yesterday Actual Shedding (s/s end)				Today	
				Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	MW	fro	to	MW	MW	(On Estimated Demand)
Dhaka	330	(18:45-02:30, gen.	shortage)	1661	50	3%
Chittagong Area	104	(18:45-02:25, gen.	shortage)	490	74	15%
Khulna Area	81	(18:45-02:45, gen.	shortage)	383	58	15%
Rajshahi Area	71	(18:45-02:05, gen.	shortage)	325	48	15%
Comilla Area	63	(18:45-01:58, gen.	shortage)	289	44	15%
Mymensing Area	49	(18:45-01:55, gen.	shortage)	213	32	15%
Sylhet Area	-	0	-	184	27	15%
Barisal Area	19	(18:45-02:45, gen.	shortage)	82	12	15%
Rangpur Area	40	(18:45-02:05, gen.	shortage)	179	27	15%
Total	757	20:00		3806	372	

Information of the Generating machines under maintenance

Planned Shut- Dowr		Forced Shut-Down	
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	8) Baghabari GT-2(02/07/09)	
	2) Shajibazar- 2 (13/07/08)	9) Ashuganj CCPP ST (04/09/09)	
	3) Shajibazar-4 (18/10/08)	10) WMPL -2 (05/09/09)	
	4) Khulna 110 (31/03/09)	11) Ashuganj unit -1 (10/09/09).	
	5) RPCL GT-4 (06/06/09)		
	6) RPCL GT-2 (30/08/10)		
	7) Sikalbaha ST (02/09/09)		

Additional Information of Machines, lines, Interruption / Forced Load shed etc

a) There was generation shortage in the evening peak hour yesterday. So about 757 MW (20:00) of load shed was imposed over the whole (except Sylhet) area of the national grid.

- b) Due to gas limitation, Raozan (360 MW), Tongi GT (105 MW), RPCL (105 MW), MPL (450 MW) and HPL (360 MW) were limited to 200 MW, 30 MW, 90 MW, 410 MW and 301 MW respectively.
- c) Due to gas limitation, Shahjibazar 4 & 5, Haripur SBU GT-1, 2 & 3 (96 MW) were under shut down.
- d) After maintenance, Shahiibazar GT- 8 was synchronized at 14:13, Again it was shut down at 04:15 (11/09/09) due to maintenance work. It may be synchronized before evening peak hour today
- e) Haripur NEPC tripped at 12:59 due to gas pressure low and was synchronized at 03:27 (11/09/09).
- f) Sylhet 132/33 KV T4 transformer and Haripur 230 KV breaker no 848B & 845B were under NLDC project work from 09:59 to 20:26 and 09:30 to 12:58 respectively.
- g) After NLDC project work, Kabirpur Joydevpur 132 KV line -2 was switched on at 11:56.

Deputy / Asstt. Manager Manager Load Despatch Division Load Despatch Division Deputy General Manager Load Despatch Circle