

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT							QF-LDC-08 Page -1
Till now the maximum generatio <b>9507 MW</b>				<b>19:30</b>	<b>Hrs</b>	<b>on</b>	Reporting Date : 3-Jan-18 <b>18-Oct-17</b>
The Summary of Ye 2-Jan-18		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation	5843.5	MW		9:00	Min. Gen. at	4:00	4483 MW
Evening Peak Generat	7782.0	MW		19:00	Max Generation	:	9960 MW
E.P. Demand (at gen e	7782.0	MW		19:00	Max Demand (Evening)	:	7900 MW
Maximum Generation	7782.0	MW		19:00	Reserve(Generation end)	:	2060 MW
Total Gen. (MKWH)	142.4	System L/ Factor	:	76.22%	Load Shed	:	0 MW
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR							
Export from East grid to West grid :-		80	MW	15:00	Energy	7.867	MKWHR.
Import from West grid to East grid :-		-	MW	-	Energy	-	MKWHR.
Water Level of Kaptai l 3-Jan-18							
Actual : 101.02 Ft.(MSL) ,		Rule curve : 102.62 Ft.( MSL )					
Gas Consum Total		833.71	MMCFD.	Oil Consumed (PDB) :			
				HSD :			Liter
				FO :			Liter
Cost of the Consumed		Gas :	Tk73,632,579				
		Coal :	Tk0	Oil :	Tk112,690,201	Total :	Tk186,322,781
Load Shedding & Other Information							
Area		Yesterday		Today			
		Estimated Demand (S/S end)		Estimated Shedding (S/S end)		Rates of Shedding (On Estimated Demand)	
		MW	MW	MW			
Dhaka	0	0:00	2792	0	0%		
Chittagong A	0	0:00	961	0	0%		
Khulna Area	0	0:00	769	0	0%		
Rajshahi Are	0	0:00	740	0	0%		
Comilla Area	0	0:00	747	0	0%		
Mymensingh	0	0:00	612	0	0%		
Sylhet Area	0	0:00	246	0	0%		
Barisal Area	0	0:00	160	0	0%		
Rangpur Are	0	0:00	462	0	0%		
Total	0		7489	0			
Information of the Generating Units under shut down.							
Planned Shut- Down				Forced Shut- Down			
Nil				1) Barapukuria ST: Unit-1,2 2) Kaptai Unit- 5 3) Khulna : (04/11/14) 4) Ghorasal Unit-1,3,4,7. 5) Baghabari 100 MW 6) Tongi GT 7) Chittagong Unit-1,2 8) Sikalbaha GT, ST 9) Baghabari-71 MW 10) Sirajganj CCPP 1 11) Ashuganj ST: Unit- 2 12) Ashuganj Unit- 3,4 13) Kushiara 163 MW CCPP GT 14) Chandpur CCPP 15) Fenchugonj CCPP-2			
Additional Information of Machines, lines, Interruption / Forced Load shed etc.							
Description				Comments on Power Interruption			
a) Tongi-Ghorasal 230 kV Ckt-2 was under shut down from 08:28 to 17:320 for A/M. b) Meghnaghat-Aminbazar 230 kV Ckt-1 was under shut down from 08:01 to 16:06 for A/M. c) Savar-Aminbazar 230 kV Ckt-2 was under shut down from 09:26 to 17:10 for A/M. d) Dohazari-Cox's 132 kV Ckt-1 was under shut down from 08:07 to 16:36 for A/M. e) Bakulia-Sikalbaha 132 kV Ckt-1 was under shut down from 08:33 to 14:37 for A/M. f) Kulshi-Madunaghat 132 kV Ckt-1 was under shut down from 08:59 to 16:48 for A/M. g) Hathazari-Raozan 230 kV Ckt-2 was under shut down from 08:40 to 16:04 for A/M. h) Fenchuganj S/S-Fenchuganj P/S 132 kV Ckt-1 was under shut down from 09:04 for A/M. i) Bibiyana-Shahjibazar 230 kV Ckt-2 was under shut down from 09:25 to 15:44 for A/M. j) Bibiyana 230 kV bus-2 was under shut down from 09:52 to 13:45 for A/M. k) Shyampur 132/33 kV T1 transformer was under shut down from 10:15 to 17:17 for A/M. l) Chandpur-Chowmohoni 132 kV Ckt-1 was under shut down from 09:50 to 14:10 for CB maintenance. m) Bogra-Natore 132 kV Ckt-2 was under shut down from 08:45 to 15:21 for A/M. n) Ishurdi 132/33 kV T1 transformer was under shut down from 09:28 to 17:58 for A/M. o) Noapara-Jessore 132 kV Ckt-1 was under shut down from 09:18 to 14:56 for A/M. p) Barisal-Bhola 230 kV Ckt-2 was under shut down from 09:24 to 16:53 for A/M. q) Faridpur-Bheramara 132 kV Ckt-1 was under shut down from 08:30 to 15:57 for A/M. r) Haripur-Meghnaghat 230 kV Ckt-1 mid CB was under shut down from 10:20 to 12:58 for oil leakage maintenance. s) Bogra 230/132 kV Ckt-1 tripped at 10:03 showing differential L1 ,L2 and was switched on at 13:54. t) Ashuganj(S)-Ghorasal 230 kV Ckt-1 was under shut down from 13:50 to 17:07 for PT maintenance at Ghorasal end. u) B.Baria-Shahjibazar 132 kV Ckt-2 was under shut down from 09:18 to 13:50 for A/M.. v) Chandpur CCPP ST & GT were under shut down at 15:20 & 15:28 due to diff. pressure high of air filter. w) Bibiyana-Shahjibazar 230 kV Ckt-2 tripped at 18:03 from Bibiyana end showing dist Z1 and was switched on at 19:30. x) Kishoreganj 132/33 kV T3 transformer was under shut down from 21:03 to 21:36 for 33 kV incoming cable joint of CT. y) Shahjibazar-Sreemongal 132 kV Ckt-1 & 2 tripped at 22:04 due to About 177 MW Power interruption occurred under Sylhet zone from both end and were switched on at 22:43 & 22:41 respectively from 22:04 to 22:41. & Sreemongal & Kulaura S/S goes under blackout. For this reason Sylhet 150 MW, Shahjibazar Prima, Fenchuganj (Barakatullah), Shahjahanulla 25 MW,Fenchuganj (Energyprima) ,Hobiganj,Fenchugonj CCPP-2 got tripped.							
Sub Divisional Engineer		Executive Engineer		Superintendent Engineer			
Network Operation Division		Network Operation Division		Load Dispatch Circle			