			POWER GRID COMPAI						
				DESPATCH CENTER	2				QF-LDC-
			DAILY	REPORT					Page
ill now the maxin	mum generatio	on ie · -	9507 MW		19:3	0 Hrs on	Reporting Date : 18-Oct-17	11-Jan-18	
he Summary of \		10-Jan-18	Generation & Demar	ıd	10.0		Gen. & Probable Gen	. & Demand	
ay Peak Generation	n :	5894.2	MW		9:00	Min. Gen. at	5:00	4464	MW
vening Peak Gener		7755.0	MW		19:00	Max Generation	:	9739	MW
.P. Demand (at gen laximum Generatio		7755.0	MW MW		19:00 19:00	Max Demand (Eveni Reserve(Generation		7900 1839	MW
otal Gen. (MKWH)	, . :	7755.0 140.9	System L/ Factor	:	75.69%	Load Shed	rena)	0	MW
otal Coll. (Mitter)			T / IMPORT THROUGH	EAST-WEST INTERC		2000 Onou			
xport from East grid				-60	MW at	15:00	Energy	7.867	MKWHF
nport from West gri			00.44 1 40	<u>- </u>	MW at	-	Energy	-	MKWHF
Actual:		Kaptai Lake at 6:0 Ft.(MSL),	JU 11-Jan-16	Rule curve	: 101.10	Ft.(MSL)			
/ totadi :	100.00	L.(IIIOL) ,		rtaio ourvo		1 t.(IIIO2)			
as Consumed :	Total	841.39	MMCFD.		Oil Consume	ed (PDB):			
							HSD :		Liter
							FO :		Liter
ost of the Consume	ed Fuel (PDB	Gas	: Tk66	,411,079					
oot or the companie	34 1 40. (1 22	Coal		111,007	Oil	: Tk158,164,459	Total :	Tk233,686,545	
	L	oad Shedding &	Other Information						
rea	Vooteral	21/				Today			+-
ıca	Yesterd	<u>-1</u>	Estimated Γ	emand (S/S end)		Today Estimated Shedding	(S/S end)	Rates of Sheddi	ina
	MW			MW			MW	(On Estimated De	
haka	0	0:00		2763			0	0%	
hittagong Area	0	0:00 0:00		951 760			0	0% 0%	
hulna Area ajshahi Area	0	0:00		760 732			0	0%	1
omilla Area	0	0:00		740			0	0%	
lymensingh Area	0	0:00		606			0	0%	
ylhet Area	0	0:00		243			0	0%	
arisal Area angpur Area	0	0:00 0:00		159 457			0	0% 0%	
angpui Area	U	0.00		+51			0	070	
otal	0		7	7411			0		
	Informatio	n of the Generatin	ng Units under shut dow	1.					
	Planned Shut-	Down			Forced Shut	- Down			+
	riamica citat	50				ria ST: Unit-1	10) Sirajganj CC	PP 1	
1	Nil				2) Kaptai Un		11) Ashuganj ST		
					3) Khulna S1		12) Ashuganj Ur		
					4) Ghorasal		13) Kushiara 16:		
					 Baghabar Tongi GT 	100 MW	14) Chandpur C	CPP	
					7) Chittagon	n Unit-1 2			
					8) Sikalbaha				
					9) Baghabar	i-71 MW			
	Additional Info	rmation of Mack	nines, lines, Interruption	/ Forced Load shed	oto				
,	Additional line	mation of wach	mes, mes, menupuoi	77 Orceu Load Sileu (oic.				
		Descrip	otion				Comments on Power	Interruption	
			t down from 09:08 to 14: om 08:57 to 15:25 for A/N						
			ut down from 09:19 to 21						
, manazan rozroo i			shut down from 08:16 to						
) Mymensingh-Netro			ere under shut down from		M.				
) Mymensingh 132/3	400 kV Ckt-1 w	as under shut dov	wn from 09:02 to 16:33 f	or A/M.					1
) Mymensingh 132/3 Bibiyana-Kaliakoir			from 09:08 to 18:08 for A						1
) Mymensingh 132/3 Bibiyana-Kaliakoir) Chatak 132/33 kV	T2 transform		rom 10:15 to 13:15 for A own from 09:25 to 17:07						1
) Mymensingh 132/3 Bibiyana-Kaliakoir) Chatak 132/33 kV) Natore 132/33 kV									
) Mymensingh 132/3 Bibiyana-Kaliakoir) Chatak 132/33 kV) Natore 132/33 kV	kV T02 transfo		down from 09:15 to 12:5						
) Mymensingh 132/3 Bibiyana-Kaliakoir) Chatak 132/33 kV) Natore 132/33 kV Baghabari 230/132 Bheramara-Farido	kV T02 transfo ur 132 kV Ckt-2	was under shut	down from 09:15 to 12:5 m 06:50 to 16:18 for D/V	V.					
) Mymensingh 132/3 Bibiyana-Kaliakoir ı) Chatak 132/33 kV) Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpu) Bogra-Palashbari Bheramara-Faridpu	2 kV T02 transfo ur 132 kV Ckt-2 132 kV Ckt-2 w	was under shut o as shut down fror							1
) Mymensingh 132/3 Bibiyana-Kaliakoir o) Chatak 132/33 kV) Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpu) Bogra-Palashbari Bheramara-Faridpu Bheramara end	2 kV T02 transfo ur 132 kV Ckt-2 132 kV Ckt-2 w ur 132 kV Ckt-1	was under shut of as shut down fror was under shut of	m 06:50 to 16:18 for D/V down from 13:02 to 14:5	9 for armouring at	ISP.				
) Mymensingh 132/3 Bibiyana-Kaliakoir o) Chatak 132/33 kV) Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpu) Bogra-Palashbari Bheramara-Faridpu Bheramara end	2 kV T02 transfo ur 132 kV Ckt-2 132 kV Ckt-2 w ur 132 kV Ckt-1 s2 kV Ckt-2 was	was under shut of as shut down fror was under shut of	m 06:50 to 16:18 for D/V	9 for armouring at	ise				
Mymensingh 132/3 Bibiyana-Kaliakoir- Chatak 132/33 kV Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpu Bogra-Palashbari Bheramara-Faridpu Bheramara end) Sylhet-Chatak 13 line Isolator of Syl Haripur-Meghnagt	2 kV T02 transfo ur 132 kV Ckt-2 132 kV Ckt-2 w ur 132 kV Ckt-1 12 kV Ckt-2 was lhet end . hat 230 kV Ckt-	was under shut on as shut down from was under shut down sunder shut on a under shut down	m 06:50 to 16:18 for D/V down from 13:02 to 14:5	9 for armouring at red hot maint at R pha					
Mymensingh 132/3 Bibiyana-Kaliakola V Chatak 132/33 kV Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpu Bogra-Palashbari Bheramara-Faridpu Bheramara end O Sylhet-Chatak 13. Jine Isolator of Syl Haripur-Meghnagh Meghnaghat end	2 kV T02 transfo ur 132 kV Ckt-2 132 kV Ckt-2 w ur 132 kV Ckt-1 2 kV Ckt-2 was lhet end . hat 230 kV Ckt-	was under shut of as shut down from was under shut of s under shut down 2 was under shut	m 06:50 to 16:18 for D/V down from 13:02 to 14:5 in from 09:28 to 11:18 for t down from 09:18 to 15:3	9 for armouring at red hot maint at R pha 32 for DS maintenance	at	,		· · · · · ·	
Mýmensingh 132/3 Biblyana-Kaliakoir Chatak 132/33 kV Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpu Bogra-Palashbari Bheramara-Faridpu Bheramara end) Sylhet-Chatak 13, line Isolator of Syl Haripur-Meghnagh Meghnaghat end. B Oggra 132/33 kV 1	2 kV T02 transfo ur 132 kV Ckt-2 132 kV Ckt-2 w ur 132 kV Ckt-1 12 kV Ckt-2 was lhet end . hat 230 kV Ckt-1	was under shut of as shut down from was under shut of s under shut down 2 was under shut	m 06:50 to 16:18 for D/V down from 13:02 to 14:5 n from 09:28 to 11:18 for	9 for armouring at red hot maint at R pha 32 for DS maintenance	at About 25 MV		curred under Bogra S/S	S areas	
) Mýmensingh 132/3 Bibiyana-Kaliakoir.) Chatak 132/33 kV) Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpu J Bogra-Palashbari Bheramara end J Sylhet-Chatak 13. line Isolator of Syl Haripur-Meghnagi Meghnaghat end . Bogra 132/33 kV 1 Replacement wor	2 kV T02 transforur 132 kV Ckt-2 the ur 132 kV Ckt-2 was the tend . hat 230 kV Ckt-1. T3 transformer to k.	was under shut of as shut down from was under shut of s under shut down 2 was under shut down was under shut down	m 06:50 to 16:18 for D/V down from 13:02 to 14:5 in from 09:28 to 11:18 for t down from 09:18 to 15:3	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop	at About 25 MV from 09:35		curred under Bogra S/s	S areas	
) Mymensingh 132/3 kV habibiyana-Kaliakoir i Chatak 132/33 kV Natore 132/33 kV Natore 132/33 kV Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpu Bogra-Palashbari Bheramara-Faridpu Bogra-Palashbari Bheramara-Faridpu Bheramara	2 kV T02 transfo ur 132 kV Ckt-2 u 132 kV Ckt-2 wur 132 kV Ckt-1 i2 kV Ckt-2 was lhet end . hat 230 kV Ckt-1 T3 transformer v. t.	was under shut das shut down fror was under shut down for sunder shut down 2 was under shut das under shut dar was under shut dar was under shut	m 06:50 to 16:18 for DN down from 13:02 to 14:5 n from 09:28 to 11:18 for t down from 09:18 to 15:3 lown from 09:35 to 10:56 down from 10:53 to 11:5	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop	at About 25 MV from 09:35		curred under Bogra S/s	S areas	
) Mymensingh 132/i Bibiyana-Kaliakoir. Chatak 132/33 kV Natore 132/33 kV Natore 132/33 kD Baghabari 230/132 Bheramara-Faridpi Bheramara-Faridpi Bheramara-Faridpi Bheramara-Faridpi Bheramara-Faridpi Bheramara-Faridpi Bheramara-Faridpi Bheramara-Faridpi Bheramara-Faridpi Bheramara-Faridpi Bheramara-Faridpi Bheramara-Faridpi Bheramara-Faridpi Boyari 132/33 kV Replacementa Tangail 132/33 kV Tangail 132/33 kV Nathuganji #5 was	2 kV T02 transforur 132 kV Ckt-2 132 kV Ckt-2 vur 132 kV Ckt-1 12 kV Ckt-2 was het end . hat 230 kV Ckt- T3 transformer v. k. T3 transformer i.	was under shut of as shut down fror was under shut of a under shut down 2 was under shut was under shut do r was under shut or at 13:01 due to	m 06:50 to 16:18 for D/V down from 13:02 to 14:5 n from 09:28 to 11:18 for t down from 09:18 to 15:3 lown from 09:35 to 10:56 down from 10:53 to 11:5 o gas pressure low.	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop 38 for CB control circu	at About 25 MV from 09:35		curred under Bogra S/N	S areas	
Mymensingh 132/i Bibiyana-Kalisati C Chatak 132/33 kV Natore 132/33 kV Natore 132/33 kV Bergar-Palashbari Bergar-Palashbari Bheramara-Faridpu Bheramara-Faridpu Haripur-Meghatak 13 Jine Isolator of Syl Haripur-Meghatak 14 Bogra 132/33 kV Replacement wor Tangail 132/33 kV maintenance work Ashuganj #5 was Aminbazar-Meghin.	2 kV T02 transforur 132 kV Ckt-2 132 kV Ckt-2 132 kV Ckt-1 132 kV Ckt-1 12 kV Ckt-2 was lhet end . hat 230 kV Ckt- T3 transformer in k. T3 transformer in k. under shut dow	was under shut of as shut down fror was under shut of a under shut down 2 was under shut was under shut do r was under shut or at 13:01 due to	m 06:50 to 16:18 for DN down from 13:02 to 14:5 n from 09:28 to 11:18 for t down from 09:18 to 15:3 lown from 09:35 to 10:56 down from 10:53 to 11:5	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop 38 for CB control circu	at About 25 MV from 09:35		curred under Bogra S/S	S areas	
) Mymensingh 132/i Bibiyana-Kalishi Chatak 132/33 kV Natore 132/33 kV Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpi Bberamara-Faridpi Bberamara-Faridpi Bberamara-Faridpi Bheramara-Faridpi Bheramara-Faridpi Bheramara end Jo Syhlet-Chatak 13 line Isolator of Syl Haripur-Meghatagi Meghanghat and Bogra 132/33 kV 7 Replacement 132/33 kV 7 Tangai 132/33 kV 7 Raplacement 5 Tangai 132/33 kV 7 Ashugara, # 5 was Aminbazar-Meghn A Shagara-Haghar	2 kV T02 transforur 132 kV Ckt-2 132 kV Ckt-2 132 kV Ckt-2 132 kV Ckt-1 12 kV Ckt-2 was thet end . hat 230 kV Ckt-1 T3 transformer vk. / T3 transformer cunder shut dow aughat 230 kV Cd.	was under shut of as shut down from was under shut of a under shut down 2 was under shut was under shut of a was under shut of	m 06:50 to 16:18 for D/V down from 13:02 to 14:5 n from 09:28 to 11:18 for t down from 09:18 to 15:3 lown from 09:35 to 10:56 down from 10:53 to 11:5 o gas pressure low.	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop 38 for CB control circu tue to Isolator fault	About 25 MV from 09:35		curred under Bogra S/	S areas	
) Mýmensingh 132/3 Bibiyana-Kaliakoir.) Chatak 132/33 kV) Natore 132/33 kV) Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpu Bogra-Palashbari Dheramara end) Sylhet-Chatak 13 line Isolator of Syl Haripur-Meghnagt Meghnaghat end .) Bogra 132/33 kV maintenance work) Ashuganj # 5 was Aminbazar-Meghnagt at Meghnaghat end . Siddhirganj 335 M	2 kV T02 transforur 132 kV Ckt-2 132 kV Ckt-2 132 kV Ckt-1 132 kV Ckt-1 132 kV Ckt-2 was thet end . hat 230 kV Ckt-1 T3 transformer . k. v T3 transformer shut down aghat 230 kV C d. d. W Synch at 15:5	was under shut of as shut down fror was under shut of a under shut down fror 2 was under shut down as under shut down as under shut dor was under shut dor was under shut down at 13:01 due to kt-2 was shut down 33 on test purpos	m 06:50 to 16:18 for D/V down from 13:02 to 14:5 in from 09:28 to 11:18 for t down from 09:18 to 15:3 down from 09:35 to 10:56 down from 10:53 to 11:5 o gas pressure low. wn from 15:40 to 18:00 c	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop 38 for CB control circu tue to Isolator fault 20 due to gas pressure	About 25 MV from 09:35	to 10:56.	·		
) Mýmensingh 132/3 Bibiyana-Kaliakolir O Chatak 132/33 kV) Natore 132/33 kV) Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpu Bheramara-Faridpu Bheramara-end In Sylhet-Chatak 13 line Isolator of Syl Haripur-Meghnagi Meghnaghat end J Bogra 132/33 kV Teplacement wor) Tangail 132/33 kV Tangail 132/33 kV Naogaon 132/33 kV Naogaon 132/33 kV	2 kV T02 transforur 132 kV Ckt-2 V Ckt-2 132 kV Ckt-2 war 132 kV Ckt-1 (2 kV Ckt-2 was let end . hat 230 kV Ckt-1 T3 transformer v k. (1 kt-1 tansformer v k. (1 kt-1 tansformer	was under shut daas shut down from was under shut down from the summer shut down as under shut down as under shut down was under shut down was under shut down at 13:01 due to kt-2 was shut do	m 06:50 to 16:18 for D/M down from 13:02 to 14:5 in from 09:28 to 11:18 for t down from 09:18 to 15:30 down from 09:35 to 10:56 down from 10:53 to 11:50 gas pressure low. with from 15:40 to 18:00 c see and got tripped at 19:25:32 due to 33 kV PT but of the see and got tripped at 19:25 to 23 kV PT but of the see and got tripped at 19:25 to 23 kV PT but of the see and got tripped at 19:25 to 25 kV PT but of the see and got tripped at 19:25 to 25 kV PT but of the see and got tripped at 19:25 to 25 kV PT but of the see and got tripped at 19:25 to 25 kV PT but of the see and got tripped at 19:25 to 25 kV PT but of the see and got tripped at 19:25 to 25 kV PT but of the see and got tripped at 19:25 kV PT but	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop 38 for CB control circu due to Isolator fault 20 due to gas pressure urst and were switched	About 25 MV from 09:35 it abnormal. ori About 32 MV from 15:32	to 10:56. V power interruption oc to 17:05	curred under Naogaon	S/S areas	
) Mýmensingh 132/3 Bibiyana-Kaliakolir O Chatak 132/33 kV) Natore 132/33 kV) Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpu Bheramara-Faridpu Bheramara-end In Sylhet-Chatak 13 line Isolator of Syl Haripur-Meghnagi Meghnaghat end J Bogra 132/33 kV Teplacement wor) Tangail 132/33 kV Tangail 132/33 kV Naogaon 132/33 kV Naogaon 132/33 kV	2 kV T02 transforur 132 kV Ckt-2 V Ckt-2 132 kV Ckt-2 war 132 kV Ckt-1 (2 kV Ckt-2 was let end . hat 230 kV Ckt-1 T3 transformer v k. (1 kt-1 tansformer v k. (1 kt-1 tansformer	was under shut daas shut down from was under shut down from the summer shut down as under shut down as under shut down was under shut down was under shut down at 13:01 due to kt-2 was shut do	m 06:50 to 16:18 for D/M down from 13:02 to 14:5 in from 09:28 to 11:18 for the down from 09:18 to 15:3 fown from 09:35 to 10:56 down from 10:53 to 11:5 to gas pressure low, with from 15:40 to 18:00 cose and got tripped at 19:35 for Day from 15:40 to 18:00 cose and got tripped at 19:35 for Day	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop 38 for CB control circu due to Isolator fault 20 due to gas pressure urst and were switched	About 25 MV from 09:35 it abnormal. or About 32 MV from 15:32 About 32 MV	to 10:56. V power interruption oc to 17:05 V power interruption oc	curred under Naogaon	S/S areas	
) Mýmensingh 132/3 Bibilyana-Kaliakoir -) Chatak 132/33 kV) Natore 132/33 kV) Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpu Bheramara-Faridpu Bheramara end) Sylhet-Chatak 13 line Isolator of Syl Haripur-Meghnagh Meghnaghat end . Bogra 132/33 kV 17 Replacement wor 17 angail 132/33 kV waintenance work) Ashuganj # 5 was Aminbazar-Meghn. 13 kWaganj # 5 was Aminbazar-Meghn. 13 kWaganj # 5 was Aminbazar-Meghn. 13 kWaganj # 5 was Aminbazar-Meghn. 13 kWaganj # 5 was 14 kWaganj # 5 was 15 kWaganj # 5 was 16 kWaganj # 5 was 17 kWaganj # 5 was 17 kWaganj # 5 was 18 kWaganj #	2 kV T02 transforur 132 kV Ckt-2 132 kV Ckt-2 132 kV Ckt-2 132 kV Ckt-1 132 kV Ckt-1 132 kV Ckt-1 132 kV Ckt-1 132 transformer 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	was under shut dawn from was under shut down from was under shut down from 2 was under shut down as under shut down was under shut down was under shut down at 13:01 due to kt-2 was shut down at 33 on test purpos former triped at 1 ansformer trip at	m 06:50 to 16:18 for D/N down from 13:02 to 14:5 in from 09:28 to 11:18 for t down from 09:18 to 15:3 lown from 09:35 to 10:56 down from 10:53 to 11:5 or gas pressure low. Win from 15:40 to 18:00 cose and got tripped at 19:215:32 due to 33 kV PT but 13:56 showing E/F relay	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop 338 for CB control circulue to Isolator fault 20 due to gas pressure arst and were switched on	About 25 MV from 09:35 it abnormal. or About 32 MV from 15:32 About 32 MV from 13:56	to 10:56. V power interruption oc to 17:05 V power interruption oc to 14:50	curred under Naogaon	S/S areas	
) Mýmensingh 132/3 Bibiyana-Kaliakoir. O Chatak 132/33 kV) Natore 132/33 kV) Natore 132/33 kV Baghabair 230/132 Bheramara-Faridpu Bheramara-Faridpu Bheramara-endi N Sylhet-Chatak 13. Iine Isolator of Syl Haripur-Meghnagi Meghnaghat end.) Bogra 132/33 kV maintenance work) Tangail 132/33 kV maintenance work) Ashuganj #5 was Aminbazar-Meghna di Syladia (132/33 kV) naintenance work) Siddhirganj 335 M Naoqaon 132/33 k') Cox's bazar 132/33	2 kV T02 transforur 132 kV Ckt-2 ur 132 kV Ckt-2 ur 132 kV Ckt-2 was thet end of the total transformer k. T3 transformer k. T3 transformer c. under shut dow aghat 230 kV Cd. W synch at 15:3 V T1 & T2 transformer 15:4 kV T1 & T2 transky V T1 &	was under shut was shut down from was under shut own from the shut down from the shut down as under shut down as under shut down was under shut down as under shut down at 13:01 due to kt-2 was shut down as shut do	m 06:50 to 16:18 for D/M down from 13:02 to 14:5 in from 09:28 to 11:18 for the down from 09:18 to 15:3 lown from 09:35 to 10:56 down from 10:53 to 11:5 og gas pressure low. Win from 15:40 to 18:00 cose and got tripped at 19:32 due to 33 kV PT but 13:56 showing E/F relay at 18:45 due to agoljara at 18:45 due to agoljara.	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop 38 for CB control circuitue to Isolator fault 20 due to gas pressure arst and were switched and were switched on 33 kV feeder fault and	About 25 MV from 09:35 it abnormal. on About 32 MV from 15:32 at About 32 MV from 13:56 were switched of	to 10:56. If power interruption oc to 17:05 If power interruption oc to 14:50 on at 18:53.	curred under Naogaon	S/S areas	
) Mýmensingh 132/3 Bibilyana-Kaliakoir -) Chatak 132/33 kV) Natore 132/33 kV) Natore 132/33 kV Baghabari 230/132 Bheramara-Faridpu Bheramara-Faridpu Bheramara-Faridpu Bheramara end) Sylhet-Chatak 13. Iine Isolator of Syl Haripur-Meghnagh Meghnaghat end .) Bogra 132/33 kV 1 Replacement wor 7 angail 132/33 kV 1 Replacement wor 7 angail 132/33 kV 3 At Meghnaghat end . Siddhirganj 335 M Naogaon 132/33 kV) Cox's bazar 132/33 Madaripur 132/33 At the same time E	2 kV T02 transforur 132 kV Ckt-2 ur 132 kV Ckt-2 ur 132 kV Ckt-2 ur 132 kV Ckt-1 2 tv Ckt-2 ur 132 kV Ckt-1 2 transformer k. 2 tv Ckt-1 3 transformer k. 2 tv Ckt-1 3 transformer k. 2 tv Ckt-1 2 transformer shut down aughat 230 kV Ckt-1 2 transformer 1 tv Ckt-1 2 transfor	was under shut dawn from was under shut down from was under shut down from 2 was under shut down as under shut down was under shut down was under shut down at 13.01 due to kt-2 was shut down as former triped at 1 ansformer triped at 1 ansformer triped a 5 P. Gopalganj per	m 06:50 to 16:18 for D/N down from 13:02 to 14:5 in from 09:28 to 11:18 for t down from 09:18 to 15:3 lown from 09:35 to 10:56 down from 10:53 to 11:5 or gas pressure low. Win from 15:40 to 18:00 cose and got tripped at 19:215:32 due to 33 kV PT but 13:56 showing E/F relay	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop 38 for CB control circuitue to Isolator fault 20 due to gas pressure arst and were switched and were switched on 33 kV feeder fault and	About 25 MV from 09:35 it abnormal. on About 32 MV from 15:32 at About 32 MV from 13:56 were switched of	to 10:56. If power interruption oc to 17:05 If power interruption oc to 14:50 on at 18:53.	curred under Naogaon	S/S areas	
) Mýmensingh 132/3 Bibiyana-Kaliakoir- () Chatak 132/33 kV) Natore 132/33 kV) Natore 132/33 kV Baghabari 320/132 Bheramara-Faridpu Bheramara-Faridpu Bheramara-end 1) Sylhet-Chatak 13. Iine Isolator of Syl Haripur-Meghnagi Meghnaghat end . 1) Bogra 132/33 kV 1 Replacement wor V Tangail 132/33 kV 1 maintenance work Ashuganj # 5 was Aminbazar-Meghn. 1) Cox's bazar 132/3 kV 1 () Cox's bazar 132/3 At the same time Synchronized at 20: Synchronized at 20: Synchronized at 20:	2 kV T02 transforur 132 kV Ckt-2 ur 132 kV Ckt-2 ur 132 kV Ckt-2 was thet end	was under shut dass shut down from was under shut down from the summer shut down from the summer shut down as under shut down was under shut down was under shut down at 13:01 due to kt-2 was shut down as on test purpos former triped at 1 ansformer triped at 1 stormer triped at 9. Gopalgani pet 9. Gopalgani pet 31 respectively.	m 06:50 to 16:18 for D/M down from 13:02 to 14:5 in from 09:28 to 11:18 for the down from 09:18 to 15:3 lown from 09:35 to 10:56 down from 10:53 to 11:5 og gas pressure low. Win from 15:40 to 18:00 cose and got tripped at 19:32 due to 33 kV PT but 13:56 showing E/F relay at 18:45 due to agoljara at 18:45 due to agoljara.	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop 38 for CB control circulue to Isolator fault 20 due to gas pressure urst and were switched and were switched on 33 kV feeder fault and tripped due to vollage.	About 25 MV from 09:35 it abnormal. on About 32 MV from 15:32 at About 32 MV from 13:56 were switched of fluctuation and	to 10:56. V power interruption oc to 17:05 V power interruption oc to 14:50 on at 18:53. were	curred under Naogaon	S/S areas	
Mymensingh 132/i Biblypan-48.liabipyan-48.li	2 kV T02 transforur 132 kV Ckt-2 transforur 132 kV Ckt-2 transformer 132 kV Ckt-2 transformer 132 kV Ckt-2 transformer 132 transformer 132 transformer 132 kV Ckt-13 transformer 132 kV Cd. transformer 132 kV T1 & T2 transformer 133 kV T1 & T2 transformer 132 kV T1 & T2 transformer 133 kV T1 & T2 transformer 133 kV T1 & T2 transformer 134 kV T1 & T2 transformer 135 kV T1	was under shut dawn from was under shut down from was under shut down from 2 was under shut down as under shut down was under shut down was under shut down at 13:01 due to kt-2 was shut down at 33 on test purpos former triped at 1 ansformer tripped at 19:21 show pped at 19:21 show pped at 19:21 show was under shut down was shut down was shown w	m 06:50 to 16:18 for D/M down from 13:02 to 14:5 in from 09:28 to 11:18 for t down from 09:18 to 15:30 to 10:56 down from 10:53 to 10:56 down from 10:53 to 11:50 gas pressure low. with from 15:40 to 18:00 c se and got tripped at 19:215:32 due to 33 kV PT but 13:56 showing E/F relay at 18:45 due to agoljara aking & Faridpur peaking owing PTAW,PTAS,PD3	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop 338 for CB control circulue to Isolator fault 20 due to gas pressure arst and were switched and were switched on 33 kV feeder fault and tripped due to voltage at Ghorasal end & DT,	About 25 MV from 09:35 it abnormal. on About 32 MV from 15:32 at About 32 MV from 13:56 were switched of fluctuation and L&B at Ishurdi e	to 10:56. If power interruption oc to 17:05 If power interruption oc to 14:50 on at 18:53. were	curred under Naogaon	S/S areas	
Mymensingh 132/ii Bibinyana-Kalisbinyana-Kal	2 kV T02 transforur 132 kV Ckt-2 transforur 132 kV Ckt-2 was thet end	was under shut was as shut down from was under shut was under shut own from the shut was under triped at 1 ansformer triped at 1 ansformer triped at 1 3 respectively, pped at 19:21 shut was under shut down as under shut was under shut down as under shut was under shut was under shut down as under shut was under shut was under shut was under shut down as under shut was under shut down as under shut was under shut was under shut down as under shut was under shut was under shut down as under shut do	m 06:50 to 16:18 for D/M down from 13:02 to 14:5 in from 09:28 to 11:18 for t down from 09:18 to 15:3 lown from 09:35 to 10:56 down from 10:53 to 11:50 gas pressure low. with from 15:40 to 18:00 c see and got tripped at 19:25 down from 15:40 to 18:00 the see and got tripped at 19:45 due to 33 kV PT but 13:56 showing E/F relay at 18:45 due to agoljara aking & Faridpur peaking aking & Faridpur peaking	9 for armouring at red hot maint at R pha 32 for DS maintenance for 33 kv loop 338 for CB control circulue to Isolator fault 20 due to gas pressure arst and were switched and were switched on 33 kV feeder fault and tripped due to voltage at Ghorasal end & DT,	About 25 MV from 09:35 it abnormal. on About 32 MV from 15:32 at About 32 MV from 13:56 were switched of fluctuation and L&B at Ishurdi e	to 10:56. If power interruption oc to 17:05 If power interruption oc to 14:50 on at 18:53. were	curred under Naogaon	S/S areas	

Sub Divisional Engineer Network Operation Division Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle