			POWER GRID COMPANY OF BANG								
			NATIONAL LOAD DESPATCH DAILY REPORT	CENTER							QF-LDC-
			DAILY REPORT					Reportin	a Date ·	21-Feb-18	Page -
Till now the maximum gen	eration is : -		9507 MW			19:3	0 Hrs	on 18-Oct-17	g Date .	21-1 60-10	
The Summary of Yesterday		20-Feb-18	Generation & Demand					ual Min Gen. & P	robable G	en. & Demand	
Day Peak Generation :		7364.8			: 12:00		Min. Gen. a		0		3 MW
Evening Peak Generation :		8553.0			: 19:00		Available Ma		:		5 MW
E.P. Demand (at gen end) :		8553.0			: 19:00		Max Demand				0 MW
Maximum Generation :		8553.0		Hour	: 19:00		Reserve(Ger	neration end)			5 MW
Total Gen. (MKWH) :			System Load Factor :		81.46%		Load Shed	:			0 MW
Export from East grid to West	rid Movingung	EX	PORT / IMPORT THROUGH EAST-WES		MW	at	7:00		Energy		MKWHR.
Import from West grid to East g			_	-700	MW	at	7.00		Energy		- MKWHR.
Water Level of Kaptai Lake at			21-Feb-18		10100	at			Energy		- MRWING
Actual		t.(MSL),	2110510	Rule curve		94.20	Ft.(MSL)				
Gas Consumed :	Total =	900.89	MMCFD.		Oil Con	sumed (PDB) :					
								HSD :			Liter
								FO :			Liter
Cost of the Consumed Fuel (PI		0	Tk84,290,039								
Cost of the Consumed Fuel (PL	B+PVI):	Gas Coal	Tk10,112,839			Oil	: Tk299,480,9	57	Total · Th	k393,883,834	
		Coar	1610,112,035			01	. 1K233,400,3	51	Total . In	\$333,003,034	
	Lo	ad Shedding	& Other Information								
Area	Yester	day					Today				
			Estimated Demand (S/S	end)			Estimated Sh	nedding (S/S end)		Rates of Shedding	
	MW		MW					MW	(C	On Estimated Dem	and)
Dhaka	0	0:00	2937 991					0		0% 0%	
Chittagong Area Khulna Area	0	0:00	991 887					0		0%	
Rajshahi Area	0	0:00	887 801					0		0%	
Comilla Area	0	0:00	724					0		0%	
Mymensingh Area	0	0:00	584					0		0%	
Sylhet Area	0	0:00	336					0		0%	
Barisal Area	0	0:00	151					0		0%	
Rangpur Area	õ	0:00	451					0		0%	
Total	0	0.00	7862					0		0,0	
	Informatio	on of the Gene	rating Units under shut down.								
		_									
	Planned Shut-	Down				Shut- Down		40) 4 1	·		
	Nil					pukuria ST: Uni ai Unit- 4,5	L- I	10) Ashuga 11) Bherar	anj ST: Uni noro 410 M	t- 2,3,4	
	INII					ai Unit- 4,5 na ST 110 MW	(04/11/14)	12) Bosila		avv.	
						asal Unit-1,3,5	(04/11/14)	13) Sylhet			
						abari 100 MW		10) Oyinot	100 10100		
					6) Tong						
						agong Unit-1,2					
						baha GT, ST					
						abari-71 MW					
	Additional Info	ormation of Ma	achines, lines, Interruption / Forced Load	sned etc.							
	De	scription			1	Con	nments on Pov	wer Interruption			
a) Dohazari-Cox's bazar 132 k			om 09:08 to 17:08 for A/M.		-	001					
 b) Dohazari-Sikalbaha 132 kV (
c) Sikalbaha 225 MW CCPP G											
			om 09:46 to 11:08 for C/M.								
d) Kabirpur 132/33 kV T2 trans											
d) Kabirpur 132/33 kV T2 trans e) Niamotpur 132/33 kV T2 trans			at 14:45 due to problem with gas booster								
 d) Kabirpur 132/33 kV T2 trans e) Niamotpur 132/33 kV T2 trans f) Chandpur CCPP GT was syr 	chronized at 14:	28 and tripped	at 14.40 due to problem with gas booster		1						
 d) Kabirpur 132/33 kV T2 trans e) Niamotpur 132/33 kV T2 trans f) Chandpur CCPP GT was syr and was synchronized at 20 	chronized at 14:2 25.										
 d) Kabirpur 132/33 kV T2 trans e) Niamotpur 132/33 kV T2 trans f) Chandpur CCPP GT was syr and was synchronized at 20 g) Ashuganj(S) 450 MW CCPP 	chronized at 14:2 25. GT was synchro	onized at 16:02	·								
d) Kabirpur 132/33 kV T2 trans e) Niamotpur 132/33 kV T2 tran f) Chandpur CCPP GT was syr and was synchronized at 20 g) Ashuganj(S) 450 MW CCPP h) Ashuganj(S) 450 MW CCPP	chronized at 14:2 25. GT was synchro ST was synchro	nized at 16:02 nized at 19:17	·								
d) Kabirpur 132/33 kV T2 trans e) Niamotpur 132/33 kV T2 tran f) Chandpur CCPP GT was syr and was synchronized at 20 g) Ashuganj(S) 450 MW CCPP h) Ashuganj(S) 450 MW CCPP i) Bhandaria-Barisal 132 kV Ck	chronized at 14:2 25. GT was synchro ST was synchro was shut down a	nized at 16:02 nized at 19:17 at 20:15 from I	Bhandaria to limit line load of								
d) Kabirpur 132/33 kV T2 trans e) Niamotpur 132/33 kV T2 tran f) Chandpur CCPP GT was syr and was synchronized at 20 g) Ashuganj(S) 450 MW CCPP h) Ashuganj(S) 450 MW CCPP i) Bhandaria-Barisal 132 kV Ck Ishwardi-Bheramara as red f	chronized at 14:2 25. GT was synchro ST was synchro was shut down a ot at maintenanc	onized at 16:02 nized at 19:17 at 20:15 from E ce at Y-phase li	·								
d) Kabirpur 132/33 kV T2 trans e) Niamotpur 132/33 kV T2 tran f) Chandpur CCPP GT was syr and was synchronized at 20 g) Astuganj(S) 450 MW CCPP h) Ashuganj(S) 450 MW CCPP i) Bhandaria-Barisal 132 kV CK Ishwardi-Bheramara as red I j) Tongi S/S-Tongi IP/S 132 kV	chronized at 14:2 25. GT was synchro ST was synchro was shut down ot at maintenand Ckt was switched	nized at 16:02 nized at 19:17 at 20:15 from f ce at Y-phase li d on at 20:10.	Shandaria to limit line load of ine isolator at Bheramara end.								
d) Kabirpur 132/33 kV T2 trans e) Niamotpur 132/33 kV T2 tran 10 Chandpur CCPP GT was syr and was synchronized at 20 g) Ashuganj(S) 450 MW CCPP h) Ashuganj(S) 450 MW CCPP i) Bhandaria-Barisal 132 kV CK Ishwardi-Bheramara as red I j) Tongi S/s-Tongi IP/S 132 kV	chronized at 14:2 25. GT was synchro ST was synchro was shut down ot at maintenand Ckt was switched	nized at 16:02 nized at 19:17 at 20:15 from f ce at Y-phase li d on at 20:10.	Bhandaria to limit line load of								
d) Kabirpur 132/33 kV T2 trans e) Niamotpur 132/33 kV T2 tran 10 Chandpur CCPP GT was syr and was synchronized at 20 g) Ashuganj(S) 450 MW CCPP h) Ashuganj(S) 450 MW CCPP i) Bhandaria-Barisal 132 kV CK Ishwardi-Bheramara as red I j) Tongi S/s-Tongi IP/S 132 kV	chronized at 14:2 25. GT was synchro ST was synchro was shut down ot at maintenand Ckt was switched	nized at 16:02 nized at 19:17 at 20:15 from f ce at Y-phase li d on at 20:10.	Shandaria to limit line load of ine isolator at Bheramara end.								
d) Kabirpur 132/33 kV T2 trans e) Niamotpur 132/33 kV T2 tran 10 Chandpur CCPP GT was syr and was synchronized at 20 g) Ashuganj(S) 450 MW CCPP h) Ashuganj(S) 450 MW CCPP i) Bhandaria-Barisal 132 kV CK Ishwardi-Bheramara as red I j) Tongi S/s-Tongi IP/S 132 kV	chronized at 14:2 25. GT was synchro ST was synchro was shut down ot at maintenand Ckt was switched	nized at 16:02 nized at 19:17 at 20:15 from f ce at Y-phase li d on at 20:10.	Shandaria to limit line load of ine isolator at Bheramara end.								
d) Kabirpur 132/33 kV T2 trans e) Niamotpur 132/33 kV T2 tran 10 Chandpur CCPP GT was syr and was synchronized at 20 g) Ashuganj(S) 450 MW CCPP h) Ashuganj(S) 450 MW CCPP i) Bhandaria-Barisal 132 kV CK Ishwardi-Bheramara as red I j) Tongi S/s-Tongi IP/S 132 kV	chronized at 14:2 25. GT was synchro ST was synchro was shut down ot at maintenand Ckt was switched	nized at 16:02 nized at 19:17 at 20:15 from f ce at Y-phase li d on at 20:10.	Shandaria to limit line load of ine isolator at Bheramara end.	r			Supe	rintendent Engin	eer		