POWER GRID COMPANY OF BANGLADESH LTD. QF-LDC-08 NATIONAL LOAD DESPATCH CENTER Reporting Date : 27-Fe Notay's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at 5:00 Available Max Generation Max Demand (Evening) Max Demand (Evening) DAILY REPORT 27-Feb-18 Till now the maximum generation is: The Summary of Yesterday's Day Peak Generation: 9507 MW 3 Generation & Demand 6020.0 MW 8060.0 MW 5181 MW Evening Peak Generation E.P. Demand (at gen end) 19:30 19:30 9705 MW 8060.0 MW 8600 MW Maximum Ger 8060.0 MW 19:30 Reserve(Generation end) 1105 MW MKWHr System Load Factor : 72.24% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Total Gen. (MKWH) Load Shed 0 MW Export from East grid to West grid :- Maximum -620 MW MW MKWHR. Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on Energy MKWHR 27-Feb-18 Ft.(MSL), Rule curve Ft.(MSL) Actual: 95.17 93.60 Gas Consumed : Total = 844.85 MMCFD. Oil Consumed (PDB): HSD FO Cost of the Consumed Fuel (PDB+Pvt) : Tk72,230,392 Gas : Tk196,618,054 Total : Tk279,692,337 Coal Tk10,843,891 Oil Load Shedding & Other Information Today Estimated Shedding (S/S end) Rates of Shedding Estimated Demand (S/S end) MW 3041 (On Estimated Demand) 0:00 Dhaka Chittagong Area 0:00 0:00 0:00 0:00 0:00 0:00 1028 0% Chittagong Area Khulna Area Rajshahi Area Comilla Area Mymensingh Area Sylhet Area 919 830 751 606 347 156 0% 0% 0% 0% 0% 0% Barisal Area Rangpur Area Total 0:00 0% 8145 Information of the Generating Units under shut down Forced Shut-Down 1) Barapukuria ST: Unit-1 10) Ashuganj ST: Unit- 2,3,4 Nil 2) Kaptai Unit- 4,5 11) Katakhali Peaking 12) Bosila 108 MW 3) Khulna ST 110 MW (04/11/14) 3) Khulna ST 110 MW 4) Ghorasal Unit-3,4,5 5) Baghabari 100 MW 6) Tongi GT 7) Chittagong Unit-1,2 8) Sikalbaha GT, ST 9) Baghabari-71 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. a) After maintenance Ghorasal #7 was synchronized at 10:02. b) Haripur 230/132 kV T03 transformer was under Comments on Power Interruption b) Haripur 230/132 kV T03 transformer was under shut down from 11:25 to 15:00 for LA change. c) New Tongi 33 kV Bus under T-2 transformer was under shut down from 09:27 to 16:20 for C/M. About 10 MW Power interruption occurred under Tongi S/S area c) New Tongi 33 kV Bus under T-2 transformer was under shut down from 09:27 to 16:20 for C/M. d) After maintenance Siddirganj GT-1 was synchronized at 13:45. e) Ashuganj(South)-450 MW ST tripped at 14:11 showing boiler feed pump vibration high and was synchronized at 18:04. f) Sylhet-Fenchuganj 132 kV Ckt tripped at 17:16 showing dist.3-phase,Z-2 at Fenchuganj end and was switched on at 18:13. g) Baghabari-71 MW was synchronized at 20:25 and tripped at 20:48. h) After maintenance Bheramara-360 MW NWPGC GT was synchronized at 17:25 and shut down at 20:27 and aqain synchronized at 01:53(27/2718). from 09:27 to 16:20 and again synchronized at 01:53(27/2/18). and again syniation less at 01.35(21/21/6). Norsingdi-Haripur 132 kV Ckt was shut down at18:43 for red hot maintenance at Norsingdi end and switched on at 22:04. j) Hasnabad-Kamrangirchar 132 kV Ckt tripped at 20:39 showing dist.C-phase,Z-1 at Hasnabad end

Sub Divisional Engineer Network Operation Division

and was switched on at 20:46. k) Ashuganj-Kishorganj 132 kV Ckt-1 tripped at 14:01 showing from both dist.AB and was switched on

K) ASINGBHIP-INSTORGHIP 102 AV CNET impress at 1-0.2 in an instance of the strength of the st

Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle