

QF-LDC-08
Page -1

Page -1

19:30 Hrs on 19-Mar-18

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Actual : 87.68 Ft.(MSL)

Rule curve : 86.80 Ft.(MSL)

Oil Consumed (PDB):

Liter
Liter

Oil : Tk319,836,313 Total : Tk406,636,944

Load Shedding & Other Information

| | | | | |
|-------|---|------|---|----|
| Total | 0 | 8481 | 0 | 0% |
|-------|---|------|---|----|

Information of the Generating Units under shut down.

Forced Shut-Down

| | |
|-------------------------------|------------------------------|
| 1) Barapukuria ST: Unit-1 | 10) Ashugani ST: Unit- 2,3 |
| 2) Kaptai Unit- 5 | 11) Sylhet 20 MW |
| 3) Khulna S (04/11/14) | 12) Khulna 230 MW |
| 4) Ghorasal Unit-2,3,5 | 13) Ashugani (North)-ST |
| 5) Baghabari 100 MW | 14) Sylhet 150 MW |
| 6) Tongi GT | 15) Haripur GT-1,2 |
| 7) Chittagong Unit-1,2 | 16) Sirajgonj Unit-1 225 MW |
| 8) Baghabari-71 MW | 17) Shahajibazar 330 MW GT-1 |
| 9) Ashugani ST: Unit- 2,3 | |

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Comments on Power Interruption

About 160 MW Power interruption occurred under Mymensingh, Jamalpur, Sherpur S/S area from 08:11 to 08:17.

About 45 MW Power interruption occurred under Bottail S/S area from 07:09 to 12:17.

About 5 MW Power interruption occurred under Gallamari S/S area from 14:38 to 15:49.

Superintendent Engineer
Load Dispatch Circle