|   |   | IONAL LOA   | PANY OF BANGL<br>D DESPATCH (<br>LY REPORT   |  | LTD.  |  | Papar   | ting Date : 6-May              | QF-LDC<br>Pag      |
|---|---|---|--|--|---|--|---|--------------------------------|--------------------|
| Till now the maximum generation is : -  |   | 10137.0   |  |  | 21  | :00 Hrs oi   |   | ung Date . 0-iviay             | -10                |
|   | ay-18   |   | on & Demand  |  |   |  |   | able Gen. & Demand             |                    |
| Day Peak Generation :   | 7201.0  |   |  | 12:00  |   | Min. Gen. at   | 6:0   | 00                             | 5881 MW            |
| Evening Peak Generation :   | 8883.0  |   |  | 20:00  |   | Available Max G  |   | :                              | 10190 MW           |
| E.P. Demand (at gen end) :<br>Maximum Generation :  | 8883.0<br>8883.0  |   |  | 20:00<br>20:00   |   | Max Demand (E<br>Reserve(Genera  |   |                                | 9400 MW<br>790 MW  |
| Total Gen. (MKWH) :   |   | 9 System  | Load Eactor  | : 78.75%   | 6   | Load Shed  |   |                                | 0 MW               |
|   |   |   | H EAST-WEST  |  |   | Load Offed   |   |                                | 0 141 14           |
| Export from East grid to West grid :- Maximum<br>Import from West grid to East grid :- Maximum  |   |   |  | 0 MW<br>MW   | at  | 20:00  |   | Energy<br>Energy               | MKWHR.<br>- MKWHR. |
| Water Level of Kaptai Lake at 6:00 A M on   |   | 6-May-18  | -  | 14144  | a   | -  |   | Energy                         | - MRWIIK.          |
| Actual : 80.07 Ft.(MSL),  |   | , .   | Rule curve   | :  | 81.83   | Ft.( MSL )   |   |                                |                    |
| Gas Consumed : Total =  | 922.23  | 3 MMCFD.  |  | Oil Cor  | nsumed (PDB):   |  | HSD :<br>FO :   |                                | Liter<br>Liter     |
| Cost of the Consumed Fuel (PDB+Pvt) :   | Gas<br>Coal   | : Tk<br>:   | 82,619,616<br>Tk0  |  | Oil   | : Tk263,329,111  |   | Total : Tk345,948,7            | 27                 |
|   |   |   |  |  |   |  |   |                                |                    |
| Area Yesterday  |   | Estimater   | 1 Demand (S/S er   | nd)  |   | Today<br>Estimated Shedd   | ting (S/S end)  | Rates of S                     | nedding            |
| MW  |   | Louinated   |  | ia)  |   | Laundleu arleut  |   |                                |                    |
|   | :00   |   | 3312   |  |   |  |   |                                |                    |
|   |   |   | 1122   |  |   |  |   |                                |                    |
| Khulna Area 0 0   |   |   | 1004   |  |   |  | C   | 0%                             |                    |
|   |   |   | 907  |  |   |  |   |                                |                    |
|   |   |   |  |  |   |  |   |                                |                    |
|   |   |   |  |  |   |  |   |                                |                    |
|   |   |   |  |  |   |  |   |                                |                    |
|   |   |   | 510  |  |   |  |   |                                |                    |
| Total 0   |   |   | 8882   |  |   |  | 0   | )                              |                    |
| Information of the Generating   | Units under s   | shut down.  |  |  |   |  |   |                                |                    |
| Planned Shut- Down  |   |   |  | Forced   | Shut- Down  |  |   |                                |                    |
|   |   |   |  |  |   |  | 10) Ashuga  | anj ST: Unit- 2,4              |                    |
| Nil   |   |   |  | 3) Khul<br>4) Gho<br>5) Bag<br>6) Ton<br>7) Chitt<br>8) Bag  | na ST 110 MW<br>rasal Unit-2,4<br>habari 100 MW<br>gi GT<br>tagong Unit-1,2<br>habari-71 MW   | (04/11/14)<br>T  | 12) Sirajgo<br>13) Ashuga                             | nj Unit-1 225 MW<br>anj 225 MW |                    |
|   |   | erruption / I   | Forced Load she  | d etc.   |   |  |   |                                |                    |
| Descriptio  |   | d damage §  | V phase conduc   | tor conne  | Comm  | ients on Power Inter   | ruption   |                                |                    |
| replacement work.<br>e) Tongi-Kodda 230 kV Ckt was under shut down from 12:36 to 13:1<br>() Meghnaghat-APR Keraniganj P/S 230 kV Ckt shut down at 03:06<br>() Kodda-Kaliakoir 230 kV Ckt was switched on at 12:27.<br>() Haripur-Sidhiriganj 132 kV Ckt-4 tripped at 15:20 from both ends<br>on at 16:39.<br>() Gopalganj 132/33 kV T1 & T2 transformers tripped at 15:19 sl<br>() Gopalganj 132/33 kV T2 transformer was under shut down from 11<br>k) KPCL-2 tripped at 21:48 showing E/F and was synchronized at 22<br>() Bheramara NWPGCL CCPP tripped at 25:55 due to problem at D<br>() Bhat 132/33 kV T2 (New) transformer was energized at 22:10.<br>n) Bottail 132/33 kV transformer tripped at 22:55 from 33 kV side sh | nd showing 4<br>3 to 10:47 du<br>3 for CB test<br>due to O/L at<br>showing dist<br>adving DEF,<br>5:57 to 17:17<br>:08.<br>e-aretor con<br>owing O/C at   | dist Z1 R-ph<br>ue to 33 kV f<br>at Kodda e<br>nd was switc<br>R-phase al<br>DOC and w<br>for replacin<br>trol valve an<br>nd was switc | ase & O/C and wa<br>Muladi feeder jum<br>nd.<br>thed on at 16:48.<br>t both ends and w<br>ere switched on at<br>g the cover of trip<br>d was synchronize<br>thed on at 00:05(0 | as<br>pr About :<br>area fi<br>ras switch<br>t 1 About 4<br>area fi<br>c About 1<br>area fi<br>ed at 06:1<br>06 About 2<br>area fi | 30 MW Power inter<br>rom 09:16 to 10:47<br>ed<br>40 MW Power inter<br>rom 15:19 to 15:35,<br>8 MW Power interr<br>rom 16:57 to 17:17,<br>10.<br>20 MW Power inter<br>rom 22:55 to 00:05 | ruption occurred under<br>uption occurred under<br>ruption occurred under<br>(06/05/2018). | er Kamrangirchar<br>r Gopalganj S/S<br>er Bottail S/S | sis                            |                    |
| <ul> <li>switched on at 07:07.</li> <li>p) Jhenidah-Bottail 132 kV Ckt-1 &amp; 2 tripped at 01:39 (06/05/2018) fn on at 02:15 &amp; 02:16 respectively.</li> <li>q) Jhenidah-Jessore 132 kV Ckt-1 &amp; 2 tripped at 01:39(06/05/2018) no at 02:11 &amp; 02:12 respectively.</li> <li>r) Bheramara-Ishurdi 132 kV Ckt-1 tripped at 01:39 (06/05/2018) from and was switched on at 02:07.</li> <li>s) Jessore 132/3 kV T1 transformer tripped at 06:21(06/05/2018) from switched on at 06:24.</li> </ul>   | 92.23 MMCFD.         OI Consumed (PDB):         HSD ::         Liker           FO :         Liker           Cas ::         TR2619.616           Cas ::         TR2619.616           Cas ::         TR2619.616           Cas ::         TR2619.616           Estimated Demand (SIS ent)         Today           Estimated Demand (SIS ent)         Today           000         1122         0           000         122         0           000         122         0           000         122         0           000         122         0           000         122         0           000         122         0           000         122         0           000         770         0           000         770         0           000         770         0           000         770         0           000         770         0           10) Achagani ST Unit-1         10) Achagani ST Unit-1           11) Barpacitaria         11) Harpe Cit.12           12) Strangony Unit-1 22         11) Harpe Cit.12           13) Strangani ST Unit-1         10) Achag |   |  |  |   |  |   |                                |                    |
| Sub Divisional Engineer<br>Network Operation Division   |   |   |  | on   |   |  | :   |                                |                    |