

QF-LDC-08  
Page -1

Page -1

**21:00 Hrs on 24-Apr-18**

### EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

MKWHR.

- MKWHR.

4 Ft.( MSL )

Liter

Liter

Information of the Generating Units under shut down.

### Forced Shut-Down

1) Barapukuria ST: Unit-1	10) Ashuganj ST: Unit-2,4
2) Sylhet 20 MW	11) Haripur GT-1,2
3) Khulna S (04/11/14)	12) Sirajgonj Unit-1 225 MW
4) Ghorasal Unit-2,4	13) Ashuganj 225 MW
5) Baghabari 100 MW	
6) Tongi GT	
7) Chittagong Unit-1,2	
8) Baghabari-71 MW	
9) Siddhirganj 210 MW ST	

Description	Comments on Power Interruption
a) Hasnabad-Aminbazar 230 kV Ckt-1 was under shut down from 09:12 to 16:02 for C/M. b) Hasnabad-Shitalakya 132 kV Ckt-1 was under shut down from 08:44 to 16:54 for C/M. c) Hasnabad-Shyampur 132 kV Ckt was under shut down from 09:22 to 16:08 for D/W. d) Barisal-Bhandaria 132 kV Ckt-1 was under shut down from 10:26 to 11:24 for red hot at Bhandaria end. e) Aminbazar 132 kV bus B-phase PT burst at 11:58 so all the 132 kV lines were tripped and was switched on at 13:42.	About 389 MW Power interruption occurred under Mirpur,Savar,Uttara & Kallayanpur S/S areas from 11:58 to 13:42.
f) Khulna 225 MW GT synchronized at 11:08. g) Ashuganj Unit-4 was shut down at 20:07 for HP by pass system problem. h) B. Baria 132/33 kV T1 ,T2 & T3 transformers all tripped at 18:51 due to over voltage during bad weather and were switched on at 19:29 , 19:26 & 19:25 respectively. i) Manikganj 132/33 kV T2 & T4 transformers were under shut down from 08:03 to 15:12 & 15:23 to 18:46 (respectively) for tan(delta) test. j) Manikganj 132/33 kv T2 transformer again shut down from 18:57 to 20:06 for B-phase isolator red hot.	About 10 MW Power interruption occurred under Manikganj S/S S/S areas from 18:57 to 20:06 .
k) Ashuganj (S) 450 MW CCPP tripped at 20:26 due to GT Hardware problem of control system and GT & ST were synchronized at 01:00 & 03:51 respectively. l) After maintenance Bheramara 410 MW STG was synchronized at 15:18. m) Naogaon-Niamatpur 132 kV Ckt tripped at 00:27(16/05/2018) from Naogaon end showing trip relay and was switched on at 00:47 again tripped at 00:58 showing same relay and was switched on at 02:12. o) Haripur-Shyampur 132 kV Ckt was tripped at 04:14(16/05/2018) from Haripur end showing dist Z1 A-N and was switched on at 04:50 .Again tripped at 05:30 from Haripur end showing dist B-phase and was switched on at 05:50. p) Khulna(C )-Noapara 132 kV tripped at 06:31(16/05/2018) from both end showing inst E/F at Khulna(C ) end and C-phase Z1 at Noapara end and was switched on at 07:35. q) Noapara-Jessore 132 kV Ckt-1 tripped at 06:31(16/05/2018) from Jessore end showing dist relay and was switched on at 07:37.	About 30 MW Power interruption occurred under Naogaon S/S areas from 00:27 to 00:47 & 00:58 to 02:12 respectively.

**Superintendent Engineer**  
**Load Dispatch Circle**