

QF-LDC-08
Page -1

Page -1

21:00 Hrs on 28-May-18

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Energy	MKWHR.
Energy	- MKWHR.

Rule curve : 83.46 Ft.(MSL)

Oil Consumed (PDB) :

Liter
Liter

Oil : Tk452,900,654 Total : Tk558,702,622

Load Shedding & Other Information

Area	Yesterday		Estimated Demand (S/S end) MW	Today	
	MW			Estimated Shedding (S/S end) MW	Rates of Shedding (On Estimated Demand)
Dhaka	0	0:00	3487	0	0%
Chittagong Area	0	0:00	1183	0	0%
Khulna Area	0	0:00	1059	0	0%
Rajshahi Area	0	0:00	957	0	0%
Comilla Area	0	0:00	865	0	0%
Mymensingh Area	0	0:00	698	0	0%
Sylhet Area	0	0:00	394	0	0%
Barisal Area	0	0:00	180	0	0%
Rangpur Area	0	0:00	538	0	0%
Total	0		9360	0	

Information of the Generating Units under shut down.

Planned Shut- Down	Forced Shut- Down
Nil	1) Barapukuria ST: Unit-1 2) Khulina ST 110 MW 3) Ghorasal Unit-2,4,5 4) Baghabari 100 MW 5) Tongi GT 6) Chittagong Unit-1,2 7) Baghabari-71 MW 8) Siddhirganj 210 MW ST 9) Ashuganj unit-3 10) Ashuganj 55 MW 11) Haripur GT-1,2

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Comments on Power Interruption
a) Tongi-Bashundhara 132 kV Ckt-1 tripped at 08:43 from Bashundhara end showing 3-Phase to ground fault relay and was switched on at 09:02.	
b) Tongi-Bashundhara 132 kV Ckt-2 tripped at 08:43 from both ends showing main protection relay and was switched on at 09:09.	
c) Mirpur-Aminbazar 132 kV Ckt-1 was under shut down from 09:57 to 17:27 for red hot maintenance.	
d) Shahjibazar-Bibiyana 230 kV Ckt-2 was under shut down from 10:10 to 13:45 for development work.	
e) Chandpur 150 MW ST was under shut down from 16:34 to 17:05 for TG problem.	
f) Cox's bazar 132/33 kV T2 transformer was under shut down from 21:19 to 22:55 for red hot maintenance.	About 20 MW Power interruption occurred under Cox's bazar S/S area from 21:19 to 22:55.
g) Barapukuria Unit-2 was forced shut down at 23:38 due to super heater tube leakage.	
h) Ashuganj Unit-5 tripped at 00:59 (29/06/2018) due to HP bypass quick open and was synchronized at 03:57(29/06/2018).	
i) Kodda 132 kV Bus-1 & 2 were shut down at 06:11 (29/06/2018) for development work.	About 90 MW Power interruption occurred under Kodda S/S area from 06:11 to till now (29/06/2018).
j) Halishahar 132/33 kV T1 & T3 transformers were under shut down from 06:09 to 07:58 (29/06/2018) for corrective maintenance.	About 40 MW Power interruption occurred under Halishahar S/S area from 06:09 to 07:58 (29/06/2018).
k) Thakurgaon-Panchagar 132 kV Ckt was under shut down from 05:35 to 07:18 (29/06/2018) for corrective maintenance.	About 30 MW Power interruption occurred under Panchagar S/S area from 05:35 to 07:18 (29/06/2018).
l) Saidpur-Purbasadipur 132 kV Ckt-2 was under shut from 05:36 to 09:55 (29/06/2018) for corrective maintenance.	About 43 MW Power interruption occurred under Purbasadipur S/S area from 05:36 to 09:55 (29/06/2018).

Superintendent Engineer
Load Dispatch Circle