POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER QF-LDC-08 DAILY REPORT Reporting Date : 4-Sep-18 Fill now the maximum generation is : The Summary of Yesterday's
Day Peak Generation : 11387.0 Generation & Demand 8996.9 MW Available Max Generation Max Demand (Evening) : vening Peak Generation 11015.0 MW 19:30 19:30 12148 MW P. Demand (at gen end) 11015.0 MW 11500 MW 11015.0 MW 19:30 Reserve(Generation end) 648 MW otal Gen. (MKWH) 0 MW 218.8 System Load Factor : 82.75%

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR -830 MW MW export from East grid to West grid :- Maximum MKWHR. Energy Import from West grid to East grid :- Maximum

Water Level of Kaptai Lake at 6:00 A M on
Actual : 104.45 Energy MKWHR 4-Sep-18 Ft.(MSL), Rule curve Ft.( MSL ) 99.69 Gas Consumed : Total = 1188.54 MMCFD. Oil Consumed (PDB): HSD FO Cost of the Consumed Fuel (PDB+Pvt) : Tk101,354,665 Coal Tk0 Oil : Tk503,573,009 Total: Tk604,927,673 Load Shedding & Other Information Area Today Estimated Shedding (S/S end) Rates of Shedding Estimated Demand (S/S end) (On Estimated Demand) MW 4008 0:00 Dhaka Chittagong Area 0:00 1363 0% 0:00 0:00 0:00 0:00 0:00 1222 1104 998 805 450 Khulna Area 0% 0% 0% 0% 0% Rajshahi Area Comilla Area Mymensingh Area ylhet Area arisal Area 0:00 207 Rangpur Area 0:00 0% Information of the Generating Units under shut down Forced Shut-Down 1) Barapukuria ST: Unit-1,2,3 Planned Shut- Down 9) Fenchugani CCPP-2 Nil 2) Khulna ST 110 MW 10) Ashuganj Unit-4 3) Ghorasal Unit-4 4) Baghabari 100 MW 5) Tongi GT 6) Chittagong Unit-1,2 7) Baghabari-71 MW 8) Haripur GT-1 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Comments on Power Interruption a) Mymensingh RPCL CCPP GT-1 & ST tripped at 09:51 due to voltage fluctuation and GT-1 was synchronized at 10:46.
b) Khulna(S) Pherramara HVDC 230 KV Ckt-1 tripped at 10:12 from both ends showing SOTF
Dist 21 B-phase at Khulna(S) end & dist 21 b-phase at HVDC end and was switched on at 15:26.
c) Barisal-Bhandaria tripped at 10:25 from both ends showing dist A-phase ol/C at Barisal end & dist 21 a-phase at Bhandaria end and was switched on at 10:36.
d) Khulna(C) 132/33 kV 13 transformer tripped at 10:05 from both sides showing E/F at 33 kV side
& intertrip at 132 kV side due to 33 kV Chandoniomhoal fededer fault and was switched on at 10:12.
e) Khulna(C) 132/33 kV 172 k T3 transformers tripped at 10:55 from both sides showing E/F at 33 kV side
& intertrip at 132 kV side due to 33 kV Jorgaste feeder fault and was switched on at 10:12.
e) Khulna(C) 132/33 kV 172 k T3 transformers tripped at 10:55 from both sides showing E/F at 33 kV side
& intertrip at 132 kV side due to 33 kV Jorgaste feeder fault and was switched on at 10:12.
e) Khulna(C) 132/33 kV 172 k T3 transformers tripped at 10:55 from both sides showing E/F at 33 kV side
& intertrip at 132 kV side due to 33 kV Jorgaste feeder fault and was switched on at 11:12.
e) Khulna(C) 132/33 kV 172 k T3 transformers tripped at 10:55 from both sides showing E/F at 33 kV side
& intertrip at 132 kV side due to 33 kV Jorgaste feeder fault and was switched on at 11:12.
e) Khulna(C) 132/33 kV 172 k T3 transformers tripped at 10:05 from both sides showing E/F at 33 kV side
& intertrip at 132 kV side due to 33 kV Jorgaste feeder fault and was switched on at 11:12.
e) Kollonian(C) 132/33 kV 172 kT3 transformers tripped at 10:05 from both sides showing E/F at 33 kV side
& intertrip at 122 kV side due to 33 kV Jorgaste feeder fault and was switched on at 11:12.
e) Kollonian(C) 132/33 kV 172 kT3 transformer tripped at 10:05 from both sides showing E/F at 33 kV side
& intertrip at 122 kV side due to 33 kV Jorgaste feeder fault and was switched on at 11:12.
e) Kollonian(C) 122/24 a) Mymensingh RPCL CCPP GT-1 & ST tripped at 09:51 due to voltage fluctuation at Fenchuganj end.

1) Bhola CCPP GT-2 tripped at 01:04 (04/09/2018) and was synchronized at 03:15. I) Brolae CCPP G1-2 impeed at U1:04 (04/09/2018) and was synchronized at U3:15.

II) Jamalpur 132/33 kV T1 transformer was shut down at 06:03(4/09/2018) for up-gradation work.

I) Khulna(C) -Khulna(S) 132 kV Ckt-1 was shut down at 07:11 (04/03/2018) for C/M.

O) Bottail 132/33 kV T2 transformer was under shut down from 06:50 to 06:55 (04/09/2018) for energy meter checking.

p) Sylhet 150 MW GT was synchronized at 03:46(04/09/2018).

> Executive Engineer Network Operation Division

Superintendent Engineer Load Dispatch Circle

Sub Divisional Engineer Network Operation Division