			PO	WER GRID COMPANY OF BANGI NATIONAL LOAD DESPATCH DAILY REPORT							QF-LDC-08 Page -1
									Reporting Date	: 19-Sep-18	
Till now the maximum generative		18-Sep-18	11534.0 Generation & Der	wond			19:0		17-Sep-18	shable Can & Dan	nand
The Summary of Yesterday's  Day Peak Generation :	3	9440.1		nanu	Hour :	12:00	)	Min. Gen. at	8:00	bable Gen. & Den 8905	
Evening Peak Generation :		11363.0			Hour :	20:00		Available Max		12459	
E.P. Demand (at gen end) :		11363.0			Hour:	20:00		Max Demand (		11500	MW
Maximum Generation :		11363.0			Hour:	20:00		Reserve(Gene	ration end)	959	
Total Gen. (MKWH) :		243.2			System Load Factor	: 89.18	3%	Load Shed	:	0	MW
Export from East grid to West gr	rid : Maximum		EXPORT / I	MPORT THROUGH EAST-WEST	INTERCONNECTOR	-490 MW	at	4:00	Energ	n/	MKWHR.
Import from West grid to East gr			_			MW	at	-	Energ		MKWHR.
Water Level of Kaptai Lake			19-Sep-18							,	
Actual :	104.29	Ft.(MSL),			Rule ci	urve :	103.14	Ft.( MSL )			
0 0	T-4-1-	4407.50	MMOED			011.0	onsumed (P	DD).			
Gas Consumed :	Total =	1107.55	MMCFD.			Oil C	onsumeu (r	DB).	HSD :		Liter
									FO :		Liter
Cost of the Consumed Fuel (PD	B+Pvt):	Gas :		Tk104,337,756							
		Coal :		Tk15,994,296			Oil	: Tk650,552,667	7 Total	: Tk770,884,718	
		l oad Shedding &	Other Information	1							
		Load Officialing a	Other information	<u>-</u>							
Area	Yesterda	у						Today			
				Estimated Demand (S/S e	end)			Estimated She	dding (S/S end)	Rates of Shedd	
D	MW	2.00		MW					MW	(On Estimated D	emand)
Dhaka Chittagong Area	0	0:00 0:00		4045 1376					0	0% 0%	
Khulna Area	0	0:00		1233					0	0%	
Rajshahi Area	Ö	0:00		1114					0	0%	
Comilla Area	0	0:00		1007					0	0%	
Mymensingh Area	0	0:00		813					0	0%	
Sylhet Area	0	0:00		453					0	0%	
Barisal Area	0	0:00 0:00		209 627					0	0% 0%	
Rangpur Area Total	0	0.00		10878					0	076	
1000				100.0							
	Information	of the Generating I	Units under shut do	wn.							
							1.01.1.0				
Planned Shut- Down							ed Shut-Dov rapukuria ST		10) Siddhirgan	i 210 MW ST	
Nil							ulna ST 110 M		11) Kaptai #5	j 210 WW 31	
							norasal Unit-3			at CCPP 450 MW 0	ST 2
							ghabari 100	MW	13)Siddhirganj	CCPP-335 MW	
							ngi GT				
							nittagong Uni				
							ighabari-71 N huganj Unit-				
							aripur GT-1,2				
						1-7					
_											
A	dditional Inforn	nation of Machine	s, lines, Interrupti	on / Forced Load shed etc.							
		Description						Comments on	Power Interruption	on	
		2 ccciiption									
a) Bheramara HVDC-Khulna(S)	230 kV Ckt-2 w	as shut down at 10	1:11 for D/W.								
b) Comilla(S) 132/33 kV T3 trans		ler shut down from	10:21 to 20:50 due	to gas							
pressure low of 33 kV breaker.			10.001 11.101								
c) Manikganj 132/33 kV T3 transformer was under shut down from 10:26 to 11:12 for red hot maintenance at 33 kV Y-phase isolator.											
d) Ashuganj-Sirajganj 230 kV Ckt-1 tripped at 11:12 from both ends showing gen trip, Dist Z1 3-phase at											
Ashuganj end & gen trip,Dist Z											
e) Sikalbaha 225 MW ST was sy											
f) Bhola CCPP 225 MW GT-1 tripped at 14:21 due to bearing # 3 radial shaft displacement and was synchronized at 17:52.											
g) Chandpur 225 MW CCPP ST				7.1.1.1.10.05		١				3.070	
h) Tangail 132/33 kV T1,T2 & T3	3 transformers tr	ipped at 18:47 sno	wing O/C relay and	were switched on at 19:05.			from 18:47 t	ower interruption	occurred under 18	angali S/S	
i) Fani 132/33 kV T1 & T2 transfi	ormers tripped s	at 10:57 showing ∩	/C and were switch	ed on at 20:04				ower interruption	occurred under Fe	ani S/S	
<ol> <li>Feni 132/33 kV T1 &amp; T2 transformers tripped at 19:57 showing O/C and were switched on at 20:04</li> <li>20:08 respectively.</li> </ol>							area from 19:57 to 20:04.				
i)) Salkhira 132/33 kV T1 & T2 transformers tripped at 21:15 due to 33 kV Salkhira feeder fault and were switched							About 94 MW Power interruption occurred under Satkhira S/S				
on at 21:20.							area from 21:15 to 21:20.				
k) Jamalpur 132/33 kV T2 transformer tripped at 20:53 showing L/O due to 33 kV feeder fault and was switched on at 21:10.								wer interruption of	ccurred under Jan	nalpur S/S	
on at 21:10.   I) Aminbazar-Kallayanpur 132 kV Ckt-1,2 tripped at 23:20 from Kallyanpur end due to CVT fire of 132 kV main							from 20:53 to	o 21:10. ower interruption o	occurred under V	allyannur 9/9	
1) Aminbazar-Kailayanpur 132 kV Ckt-1,2 inpped at 23:20 from Kailyanpur end due to CVT life of 132 kV main bus and were switched on at 23:50.							from 23:20 to		Josuiteu ulluel Ka	anyanpun 3/3	
m) Barisal 132/33 kV T2 (New) t		switched on at 23:	40.			aica	20.20 (	0.00.			
n) Meghnaghat 450 MW GT-2 was shut down at 00:13(19/09/2018) for maintenance.											
o) Ghorasal P/S - Ghorasal Reg	ent 230 kV Ckt v	was shut down at 0	3:20 (19/09/2018)	due to sparking.							
Sub Divisional Engineer				Executive Engineer		1		Sune	rintendent Engin	eer	
Network Operation Division	ı			Network Operation Division	on					spatch Circle	