

19:30 Hrs on 19-Sep-18

Reporting Date : 21-Sep-18

Total Gen. (MW/HR)	2153	System Load (MW)	65.75%	Load shed		0 MW
<b>EXPORT / IMPORT THROUGH EAST-WEST INTERCONECTOR</b>						
Export from East grid to West grid :- Maximum		-340 MW	at	18:30	Energy	MKWHR.
Import from West grid to East grid :- Maximum	-	MW	at	-	Enerv	- MKWHR.

**EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR**

Water Level of Kaptai Lake at 6:00 A M on		21-Sep-18		
Actual :	104.14	Ft.(MSL) ,	Rule curve :	103.37
			Ft.( MSL )	

Load Shedding & Other Information

### Load Shedding & Other Information

Total	0	10/07	0
Information of the Generating Units under shut down.			

Information of the Generating Units under shut down.

	9) Hanpur G1-1,2	
--	------------------	--

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Comments on Power Interruption
<p>a) Bheramara HVDC-Ishurdi 230 kV Ckt-1 was under shut down from 09:51 to 10:25(21/09/2018) for DFDR work.</p> <p>b) Raozan #01 tripped at 10:39 due to Boiler tripped and was synchronized at 11:09.</p> <p>c) Sikalbaha 150 MW peaking was synchronized at 11:09 for fuel changing Gas to oil.</p> <p>d) Bakulia-Sikalbaha 132 kV Ckt-1 &amp; 2 were emergency shut down from 11:14 to 12:24 due to fire a house under the 132 kV line.</p> <p>e) Madaripur 132/33 kV T-3 transformer was shut down from 08:05 to 08:36 for red hot maint at 33 kV Tekerhat</p> <p>f) Bagerhat-Bhandaria 132 kV Ckt tripped at 13:25 from both end showing dist Z2,RST,E/F relay at Bagerhat end &amp; differential O/C relay at Bhandaria end and was switched on at 13:53.</p> <p>g) Khulna(c)-Noapara 132 kV Ckt-1 &amp; 2 tripped at 13:25 from Khulna(c) end showing E/F,O/L relay due to a coal carrying crane touch Jessore-Noapara 132 kV Ckt-2 and were switched on at 13:45.</p> <p>h) Khulna(S)-Khulna@ 132 kV Ckt-1 &amp; 2 tripped at 13:25 from Khulna(S) end showing E/F relay due to Jessore-Noapara Ckt-2 and were switched on at 13:45.</p> <p>i) Noapara-Jessore 132 kV Ckt-2 tripped at 13:25 from both end showing dist Z2 at Noapara end &amp; dist E/F relay at Jessore end and was switched on at 13:45 above the tripping KPCL-1,2,KZA,Khulna 225 MW machin's are also tripped.</p> <p>j) Naogaon 132/33 kV T1 transformer was shut down from 08:55 to 15:40 for A/M.</p> <p>k) Meghnaghat CCPG GT &amp; ST tripped at 16:14 and were synchronized at 00:41,02:08 respectively.</p> <p>l) Savar 132/33 kV T1 &amp; T2 transformer tripped at 22:15 from 33 kV side showing E/F relay and was switched on at 22:26.</p> <p>m) After maint Rampura 132 kV bus-2 was switched on at 06:59(21/09/2018).</p> <p>n) After maint Rampura 230/132 kV TR-2 transformer was switched on at 07:01(21/09/2018).</p> <p>o) Bogura-Sirajganj 230 kV Ckt-2 is under shut down since 07:01(21/09/2018) due to red hot maint at R-phase line isolator at Bogura end.</p> <p>p) Feni- Hathazari 132 kV Ckt-2 is under shut down since 06:48(21/09/2018) for D/W.</p> <p>q) Goalpara-Bagerhat 132 kV Ckt-2 is under shut down since 07:07(21/09/2018) for D/W.</p> <p>r) Saidpur-Barapukuria 132 kV Ckt-1 is under shut down since 07:01(21/09/2018) for D/W.</p> <p>s) Gopalganj 132 kV bus is under shut down since 06:42(21/9/2018) for C/M.</p> <p>t) Gallamari 132/33 kV T1 &amp; T2 transformer tripped at 04:54(21/09/2018) from both side showing O/C relay due to 33 kV feeder fault and were switched on at 05:12,05:14 respectively.</p>	<p>About 157 MW Power interruption occurred under Khulna@,Goalpara Bagerhat &amp; Mongla S/S area from 13:25 to 13:45</p> <p>About 100 MW Power interruption occurred under Savar S/S area from 22:15 to 22:26.</p> <p>About 30 MW Power interruption occurred under Purbasadipur, Thakurgaon,panchagor S/S area since 07:01.</p> <p>About 40 MW Power interruption occurred under Gopalganj S/S area since 06:42.</p> <p>About 40 MW Power interruption occurred under Gallamari S/S area from 04:54 to 05:12.</p>
<p><b>Sub Divisional Engineer</b> <b>Network Operation Division</b></p>	<p><b>Executive Engineer</b> <b>Network Operation Division</b></p>
	<p><b>Superintendent Engineer</b> <b>Load Dispatch Circle</b></p>