			POW	VER GRID COMPANY OF B	SANGLADESH LTD							
				NATIONAL LOAD DESPA							QF-LDC-08	
				DAILY REPO	RT						Page -1	
Till now the maximum	annaration in .		11623 MW				19:30	Hrs or	Reporting Date 19-Sep-18	e: 3-Nov-18		
The Summary of Yester		2-Nov-18	Generation &	Demand			19:30			Probable Gen. & D	Demand	
Day Peak Generation	:	6547.2		- Domana	Hour :	12:00		Min. Gen. at	4:00		1 MW	
Evening Peak Generation	:	8751.0			Hour:	19:00		Available Max	Generation	1170	2 MW	
E.P. Demand (at gen end)	:	8751.0	MW		Hour:	19:00		Max Demand		9500) MW	
Maximum Generation	:	8751.0			Hour:	19:00		Reserve(Gene	eration end)		2 MW	
Total Gen. (MKWH)	:	168.3			System Load Factor	: 80.11%	1	Load Shed	:) MW	
Export from East grid to We			EXPORT / IM	PORT THROUGH EAST-V		OR 10 MW	at	18:30	F		MKWHR.	
Import from West grid to Ea				_	-4	MW	at	18:30	Ener Ener		- MKWHR.	
Water Level of Kaptai Lak			3-Nov-18			14144	at		Liloi	93	- MICWING	
Actual		t.(MSL),			Rule curv	e: 108	.80	Ft.(MSL)				
		, , , ,										
Gas Consumed :	Total =	1112.76	MMCFD.			Oil Con	sumed	(PDB):				
									HSD :		Liter	
									FO :		Liter	
Cost of the Consumed Fue	I (DDD i Dut) .	Gas :		Tk97.463.448	,							
Cost of the Consumed Fide	T(FDBTFVI).	Coal :		Tk14,143,812		0	il ·	Tk111,228,49	5 Total	: Tk222,835,755		
				1111,110,012				11(111,220,10	- 10141			
	Lo	oad Shedding	& Other Inforn	<u>nation</u>								
Area	Yesterday	,						Todav				
,				Estimated Demand ((S/S end)			Estimated She	edding (S/S end) Rates of Shed	lding	
	MW			MW					MW	(On Estimated	Demand)	
Dhaka	0	0:00		3361					0	0%		
Chittagong Area	0	0:00		1139					0	0%		
Khulna Area	0	0:00 0:00		1019 921					0	0% 0%		
Rajshahi Area Comilla Area	0	0:00		832					0	0%		
Mymensingh Area	0	0:00		672					0	0%		
Sylhet Area	Ö	0:00		381					0	0%		
Barisal Area	0	0:00		173					0	0%		
Rangpur Area	0	0:00		518					0	0%		
Total	0			9016					0			
	Information of	of the Generatin	ng Units under:	shut down.								
							01.1					
	Planned Shut- Do	wn					Forced Shut- Down 1) Barapukuria ST: Unit-1,2 9) Kaptai #2					
	Nil							131. UIII-1,2 110 MW	9) Kaptai #2 10) Megnaghat-450 MW			
	1411					3) Ghor				Resent 108 MW		
						4) Bagh			12) Haripur 4	112 MW		
						5) Tong	i GT		13) Ashugan	j-4		
						6) Bagh				Í Max 78 MW		
						7) Harip				ar 330 MW GT-1		
						8) Sidd	hirganj	210 MW ST	16) Chattogr	am ST-1		
									I			
	Additional Inform	ation of Mach	ines, lines, Int	erruption / Forced Load sh	ned etc.							
Description							Comments on Power Interruption					
a) Khagrachori132/33 kV T2 transformer tripped at 09:32 operating PRD.												
b) Haripur 230/132 kV T1 transformer was under shut down from 09:04 to 12:36 for 132 kV 4-phase loop maintenance.												
c) Aminbazar-Bosila power plant Ckt was under shut down from 09:40 to 16:13 due to development work.												
 d) Ishwardi 230 kV bus-1 was shut down at 10:07 for development work. As a consequence 230/132 kV T3 transformer got shut down automatically. 												
e) Bhandaria 33 kV full bus was under shut down from 09:36 to 13:42 for corrective maintenance.							About 20 MW Power interruption occurred under Bhandaria S/S					
6) Manadana 30 kV Tun bas was ander shut down norm 05.30 to 10.42 for corrective maintenance.								6 to 13:42	aon occurred an	aor Briandana oro		
f) Siddhirganj Peaking (GT-	-1)-Siddhirganj 132 l	kV Ckt was un	der shut down	from 15:46 to 20:13 for DS r	maintenance.							
f) Siddhirganj Peaking (GT-1)-Siddhirganj 132 kV Ckt was under shut down from 15:46 to 20:13 for DS maintenance. g) Maniknagar 230/132 kV T1 transformer was shut down at 07:09(03/11/2018) for development work.												
h) Kabirpur-Tongi 132 kV Ckt-2 was shut down at 07:18(03/11/2018) for corrective maintenance.												
i) Bogura 132/33 kV T1 transformer was shut down at 07:50 (03/11/2018) for annual maintenance.												
j) Hathazari 230/132 kV T3 transformer was under shut down from 23:38 to 00:37(03/11/2018) for attend sparking at 132 kV neutral						al point.						
k) Shahjibazar 330 MW CCPP GT-1 was shut down at 22:43 for STG combined mode operation and was synchronized												
at 00:37(03/11/2018). I) Hathazari-Kaptai 132 kV	Ckt-1 was shut dow	n at 07:56/03/1	1/2018) for an	nual maintenance								
.,		07.00(30/1	5 10 / 101 0111									

Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle

Sub Divisional Engineer Network Operation Division