

QF-LDC-08  
Page -1

Reporting Date : 12-Aug-09

### EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Water Level of Kaptai Lake at 6:00 A M of

Cost of the Consumed Fuel (PDB) : Gas	: Tk56,288.378	Oil	: Tk15,952.800	Total	: Tk72,241.178
---------------------------------------	----------------	-----	----------------	-------	----------------

Area	Yesterday			Today			
	Actual Shedding (s/s end)			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	MW	fro	to				
Dhaka	273	(19:30 cont'd, gen. shortage)		1710	331	19%	
Chittagong Area	136	(19:30 cont'd, gen. shortage)		500	101	20%	
Khulna Area	115	(19:30 cont'd, gen. shortage)		440	92	21%	
Rajshahi Area	94	(19:30 cont'd, gen. shortage)		380	64	17%	
Comilla Area	71	(19:30 cont'd, gen. shortage)		282	60	21%	
Mymensing Area	60	(19:30 cont'd, gen. shortage)		230	28	12%	
Sylhet Area	24	(19:30 cont'd, gen. shortage)		185	39	21%	
Barisal Area	18	(19:30 cont'd, gen. shortage)		83	18	22%	
Rangpur Area	48	(19:30 cont'd, gen. shortage)		195	18	9%	
<b>Total</b>	<b>839</b>	<b>20:00</b>		<b>4005</b>	<b>751</b>		

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	7) Baghabari GT-2(02/07/09)
	8) Siddhirgonj Steam (05/08/09)
	9) Ashuganj CCPP St (07/08/09)
	10) Raozan -1 (08/08/09)
2) Kapital- 3 (19/04/08)	
3) Shajibazar- 2 (13/07/08)	
3) Shajibazar-4 (18/10/08)	
4) Ghorasal-1 (30/09/08)	
5) Khulna 110 (31/03/09)	
6) NEPC 1 unit is under S/D	

**Additional Information of Machines, lines, Interruption / Forced Load shed etc**

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 839 MW (20:00) of load shed was imposed over the whole area of the national grid .
b) Due to gas limitation, Raozan (180 MW), NEPC (95 MW), RPCL (175 MW), and Meghnaghat P.Ltd (450) were limited to 170 MW , 35 MW, 106 MW , 422 MW and 336 MW respectively.	
c) Due to gas limitation, Shahjibazar - 4 & 5, Haripur SBU GT-1, 2, 3 (96 MW) were under shut down.	
d) After maintenance Ashuganj unit-2 was synchronized at 01:15 (12/08/09)	
e) Faridpur - Madaripur 132 KV line-1& 2, Bogra - Naogaon 132 KV line1 Faridpur - Madaripur 132 KV line-2 & Rajshahi - Chapinawabganj 133 KV line-2 were under shut down from 08:08 to 13:08, 08:38 to 19:25, 12:35 to 17:58 and 13:13 to 17:50 due to NLDC project work.	
f) Chowmohoni 132/33 KV T-2 transformer was under shut down from 10:10 to 15:02 due to changing of 33 KV breaker pole.	
g) Sylhet 132/33 KV T-2 transformer was under shut down from 12:15 to 12:40 due to changing of O/C relay by SPMD.	partial power interruption occurred (7 MW) under Sylhet S/S areas from 12:15 to 12:40
	Due to generation shortage and MVAR problem, about 150 MW (09:00) of load shed has been running since morning (12/08/09) over the whole areas (except Sylhet ) of the national grid.

Deputy General Manager  
Load Despatch Circle