

QF-LDC-08  
Page -1

|                                   |     |   |              |  |     |   |              |  |       |   |              |
|-----------------------------------|-----|---|--------------|--|-----|---|--------------|--|-------|---|--------------|
| Cost of the Consumed Fuel (PDB) : | Gas | : | Tk57,501,980 |  | Oil | : | Tk16,850,336 |  | Total | : | Tk74,352,316 |
|-----------------------------------|-----|---|--------------|--|-----|---|--------------|--|-------|---|--------------|

| Area            | Yesterday                 |                               |    | Today                     |                              |  |  |
|-----------------|---------------------------|-------------------------------|----|---------------------------|------------------------------|--|--|
|                 | Actual Shedding (s/s end) |                               |    | Estimated Demand(s/s end) | Estimated Shedding (s/s end) | Rates of Shedding<br>(On Estimated Demand) |  |
|                 | MW                        | fro                           | to |                           |                              |  |  |
| Dhaka           | 212                       | (19:30-06:55, gen. shortage)  |    | 1684                      | 255                          | 15%  |  |
| Chittagong Area | 138                       | (19:30-07:05, gen. shortage)  |    | 490                       | 76                           | 16%  |  |
| Khulna Area     | 119                       | (19:30-cont'd, gen. shortage) |    | 430                       | 68                           | 16%  |  |
| Rajshahi Area   | 99                        | (19:30-cont'd, gen. shortage) |    | 370                       | 43                           | 12%  |  |
| Comilla Area    | 69                        | (19:30-06:40, gen. shortage)  |    | 265                       | 35                           | 13%  |  |
| Mymensing Area  | 57                        | (19:30-06:40, gen. shortage)  |    | 240                       | 31                           | 13%  |  |
| Sylhet Area     | 33                        | (19:30-06:00, gen. shortage)  |    | 185                       | 34                           | 18%  |  |
| Barisal Area    | 19                        | (19:30-cont'd, gen. shortage) |    | 83                        | 16                           | 19%  |  |
| Rangpur Area    | 48                        | (19:30-cont'd, gen. shortage) |    | 195                       | 12                           | 6%   |  |
| <b>Total</b>    | <b>794</b>                | <b>20:00</b>                  |    | <b>3942</b>               | <b>570</b>                   |  |  |

| Planned Shut- Down          | Forced Shut- Down                 |
|-----------------------------|-----------------------------------|
| 1) Khulna 60 MW (05/07/06)  | 7) Baghabari GT-2(02/07/09)       |
|                             | 8) Ashuganj CCPP St (07/08/09)    |
| 2) Shajibazar- 2 (13/07/08) | 9) Raozan -1 (08/08/09)           |
| 3) Shajibazar-4 (18/10/08)  | 10) Ashuganj CCPP GT-1 (12/08/09) |
| 4) Ghorasal-1 (30/09/08)    |                                   |
| 5) Khulna 110 (31/03/09)    |                                   |
| 6) NEPC 1 unit is under S/D |                                   |

| Description  | Forced load shaded / Interrupted Areas   |
|--|--|
| a) There was generation shortage in the evening peak hour yesterday.   | So about 794 MW (20:00) of load shed was imposed over the whole area of the national grid .  |
| b) Due to gas limitation, Raozan (180 MW), NEPC (95 MW), RPCL (175 MW), and Meghnaghat P.Ltd (450) were limited to 140 MW , 0 MW, 106 MW , 400 MW and 315 MW respectively.                                       |  |
| c) Due to gas limitation, Shahjibazar - 4 & 5, Haripur SBU GT-1, 2, 3 (96 MW) were under shut down.  |  |
| d) Ashuganj CCGT GT-1 was shut down at 10:10 due to combustion inspection.   |  |
| e) Haripur NEPC was shut down at 14:15 due to gas pressure low and was synchronized at 01:28 (13/08/09).   |  |
| f) Madaripur - Barisal 132 KV line -2, Naogaon - Bogra 132 KV line -2 and Thakurgaon 132/33 KV T2 transformers were under NLDC project work from 08:10 to 13:45, 09:25 to 20:25 and 09:25 to 14:05 respectively. |  |
| g) Sremongal 132/33 KV T1 & T2 transformers were under shut down from 12:49 to 15:25 and 12:49 to 15:26 respectively due to red -hot maintenance of 33 KV incoming isolator.                                     | partial power interruption occurred (12 MW) under Sremongal S/S area from 12:49 to 15:25.  |
| h) Ghorasal ( on DIST AB & remote protection failure) - Ashuganj (on DIST AB) 132 KV line -2 tripped at 06:26 (13/08/09) from both end. It is now under inspection.  |  |
|  | Due to generation shortage and MVAR problem, about 150 MW (09:00) of load shed has been running since morning (13/08/09) over the whole areas (except Sylhet and Mymensing ) of the national grid. |

Deputy General Manager  
Load Despatch Circle