

QF-LDC-08
Page -1

Page -1

Till now the maximum generation is : -

11623 MW

19:30

Hrs

on 19-Sep-18

on 19-Sep-18

The Summary of Yesterday's		22-Nov-18	Generation & Demand
----------------------------	--	-----------	---------------------

The Summary of Yesterday's	22-Nov-19	Utilization & Demand	Today's Actual min Gen	Probable Gen.	Demand
Day Peak Generation :	6838.9 MW	Hour :	12:00	Min. Gen. at 7:00	5107 MW
Evening Peak Generation :	8433.0 MW	Hour :	18:00	Available Max Generation	11727 MW
E.P. Demand (at gen end) :	8433.0 MW	Hour :	18:00	Max Demand (Evening) :	7900 MW
Maximum Generation :	8433.0 MW	Hour :	18:00	Reserve(Generation end)	3827 MW
Total Gen. (MKWH) :	157.5	System Load Factor :	77.84%	Load Shed	0 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR						
Export from East grid to West grid :- Maximum	-660	MW	at	20:00	Energy	MKWHR.
Import from West grid to East grid :- Maximum	-	MW	at	-	Energy	- MKWHR.

Water Level of Kaptai Lake at 6:00 A M on 23-Nov-18		Rule curve : 106.80 Ft (MSL)	
Actual :	100.71 Ft (MSL) ,		

Gas Consumed :	Total =	1063.50 MMCFD.	Oil Consumed (PDB) :		
				HSD :	Liter
				FO :	Liter

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk87,009,299			
	Coal :	Tk14,202,870	Oil	: Tk120,860,381	Total : Tk222,072,550

Load Shedding & Other Information

Area	Yesterday		Estimated Demand (S/S end)	Today	
	MW			Estimated Shedding (S/S end)	Rates of Shedding (On Estimated Demand)
Dhaka	0	0:00	2807	0	0%
Chittagong Area	0	0:00	946	0	0%
Khulna Area	0	0:00	846	0	0%
Rajshahi Area	0	0:00	764	0	0%
Cornilla Area	0	0:00	691	0	0%
Mymensingh Area	0	0:00	558	0	0%
Sylhet Area	0	0:00	322	0	0%
Barisal Area	0	0:00	144	0	0%
Rangpur Area	0	0:00	430	0	0%
Total	0		7508	0	

Information of the Generating Units under shut down.

Planned Shut- Down

Nil

Forced Shut-Down

- | | |
|-----------------------------|----------------------|
| 1) Barapukuria ST: Unit-1,2 | 9) Ashuganj (North) |
| 2) Khulna ST 110 MW | 10) Bheramara-410 MW |
| 3) Ghorasal Unit-2,3,5 | 11) Sirajganj Unit-2 |
| 4) Tongi GT | 12) Baghabari 100 MW |
| 5) Shajibazar 330 MW | 13) Siddirganj GT-1 |
| 6) Haripur 412 MW CCPST | 14) Sylhet-150 MW |
| 7) Haripur Unit-1, 2 | |
| 8) Siddhirganj ST 210 MW | |

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description

- a) Kulshi-Modern steel 132 kV Ckt was under shut down from 09:26 to 15:06 for A/M.
- b) Tongi-Kabarpur 132 kV Ckt-1 was under shut down from 09:03 to 15:45 for A/M.
- c) Haripur-Bhulta 230 kV Ckt-1 was under shut down from 09:06 to 20:07 for A/M.
- d) Meghnaghat-Cumilla(N) 230 kV Ckt-1 was under shut down from 08:57 to 13:28 for A/M.
- e) Kishorganj-Mymensing 132 kV Ckt-2 was under shut down from 09:53 to 20:10 for A/M.
- f) Fenchuganj 132/33 kV T-1 transformer was under shut down from 09:30 to 15:42 for A/M.
- g) Chataak 132/33 kV T-1 transformer was under shut down from 08:35 to 15:18 for A/M.
- h) Shahjibazar 132/33 kV T-2 transformer was under shut down from 10:50 to 16:57 for A/M.
- i) Rampura-Bhulta 230 kV Ckt-4 was under shut down from 09:40 to 14:32 for A/M.
- j) Tongi 132 kV Bus-1 was under shut down from 12:25 to 14:38 for A/M.
- k) Chuadanga 132/33 kV T-2 transformer was under shut down from 08:31 to 15:29 for A/M.
- l) AES Haripur-360 MW was shut down at 09:02 for maint. and GT & ST were synchronized at 17:29 & 19:20.
- m) Razoon Z was shut down at 12:58 due to gas shortage.
- n) Siddirganj peaking GT-2 was synchronized at 20:26.
- o) Chandraghona-Khagrachori 132 kV Ckt tripped at 21:16 showing dist.ZZ from Chandraghona end and was switched on at 21:28.
- p) Rangamat-Khagrachori 132 kV Ckt tripped at 21:16 showing dist.ZZ,R-phase and was switched on at 21:27.
- q) Sylhet-150 MW was shut down at 21:49 due to chimney maintenance.
- r) After maintenance Ashuganj-Sirajganj 230 kV Ckt-1 was switched on at 17:15.
- s) After maintenance Sikabaha 230/132 kV TR-2 transformer was switched on at 14:06.
- t) Sikabaha-225 MW CCPP tripped at 06:20(23/11/18) due to gas pressure low.
- u) Meghnaghat-450 MW is under shut down at 06:29(23/11/18) for substation maintenance.
- v) Rajshahi 132 kV main Bus is under shut down at 06:37(23/11/18) for C/M.

Comments on Power Interruption

About 10 MW Power interruption occurred under Khagrachori S/S area from 21:16 to 21:28.

About 65 MW Power interruption occurred under Rajshahi S/S area since 06:37(23/11/18).

**Sub Divisional Engineer
Network Operation Division**

**Executive Engineer
Network Operation Division**

Superintendent Engineer
Load Dispatch Circle