POWER GRID COMPANY OF BANGLADESH LTD. QF-LDC-0 NATIONAL LOAD DESPATCH CENTER
DAILY REPORT Reporting Date : 23-Dec-18 Fill now the maximum generation is :The Summary of Yesterday's
Day Peak Generation : 11623 MW Generation & Demand 4810 MW vening Peak Generation 8296.0 MW 19:00 Available Max Generation 12065 MW E.P. Demand (at gen end) 8296.0 MW 19:00 Max Demand (Evening) 8600 MW 8296.0 MW
148.4 System Load Factor : 74.52%

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR
-690 MW at
MW at Reserve(Generation end) 3465 MW otal Gen. (MKWH) export from East grid to West grid :- Maximum Energy Import from West grid to East grid :- Maximum

Water Level of Kaptai Lake at 6:00 A M on MKWHR 23-Dec-18 Ft.(MSL) Actual : 98.87 Rule curve 103.90 Ft.(MSL) Gas Consumed : Total = 1078.08 MMCFD. Oil Consumed (PDB): HSD FO Cost of the Consumed Fuel (PDB+Pvt) Tk88,337,829 Gas Coal Tk20,249,174 Oil : Tk77,028,566 Total: Tk185,615,569 Load Shedding & Other Information Area Today Estimated Shedding (S/S end) Rates of Shedding Estimated Demand (S/S end) MW 3019 MW (On Estimated Demand) 0:00 Dhaka Chittagong Area 0 0:00 1020 0% 0:00 0:00 0:00 0:00 0:00 0% 0% 0% 0% 0% 0% Khulna Area 913 824 745 601 345 155 0 0 0 Rajshahi Area Comilla Area Mymensingh Area ylhet Area arisal Area 0:00 Rangpur Area 0:00 0% Information of the Generating Units under shut down Forced Shut- Down 1) Barapukuria ST: Unit-1,2 2) Khulna ST 110 MW Planned Shut- Down 9) Bhagabari 71 MW Nil 10) Raozan # 01 3) Ghorasal Unit-2.3.4 11) Sirajganj Unit-1,3,4 3) Ghorasal Unit-2,3,4 4) Tongi GT 5) Haripur GT-1,2 6) Baghabari 100 MW 7) Siddhirganj ST 210 MW 8) Summit Bibiyana-2 Additional Information of Machines, lines, Interruption / Forced Load shed etc Description Comments on Power Interruption a) Bibiyana GT was synchronized at 09:54 b) Ghorasal Unit-4 was synchronized at 09:55.
c) Sonargaon 132/33 kV T1 & T2 transformers tripped at 11:26 from 33 kV sides showing O/C due to About 30 MW Power interruption occurred under Sonargaon S/S c) Sonargaon 132/33 kV 11 & 12 transformers bripped at 11:26 from 33 kV sides snowing 01/20 due to Y-phase Post insulator of bus coupler got burst and were switched on at 11:59 & 12:00 respectived d) Cumilla(N)-Daudkandi 132 kV Ckt-2 tripped at 08:03 from both ends showing Dist 3-phase, SOTF at Cumilla(N) end and Dist C-phase at Daudkandi end and was switched on at 14:44. e) Aminbazar 230/132 kV T3 transformer was under shut down from A/M. f) Tongi 230/132 kV T2 transformer was under shut down from 08:50 to 14:36 for A/M. g) Kishoregani-Ashugani 132 kV Ckt-2 was under shut down from 09:22 to 16:46 for A/M. area from 11:26 to 11:59. g) Risnoreganj-Asnuganj 132 kV Ckt-2 was under shut down from 08:12 to 16:46 for A/M.
h) Jamalpur-Mymensingh 132 kV Ckt-2 was under shut down from 08:12 to 16:49 for A/M.
j) Mymensingh S/S-Mymensingh RPCL 132 kV Ckt-2 was under shut down from 09:46 to 16:44 for A/M.
j) Rampura 230/132 kV T2 transformer was under shut down from 08:31 to 14:02 for A/M.
k) Narinda-Maniknagar 132 kV Ckt-1 was under shut down from 09:53 to 17:35 for A/M.
j) Kulaura 132 kV bus-2 was under shut down from 09:41 to 14:48 for A/M.
m) Haripur-Sonargaon 132 kV Ckt-1 was under shut down from 12:13 to 16:03 for protection test.
n) Netrokona 132/33 kV T3 transformer was under shut down from 08:15 to 10:15 for A/M.
o) Shiblakkhva 132/33 kV T3 transformer was under shut down from 08:15 to 10:15 for A/M. n) Netrokona 132/33 kV T3 transformer was under shut down from 08:15 to 10:15 for A/M.

o) Shitalakhky 132/33 kV T2 transformer was under shut down from 10:44 to 13:38 for A/M.

p) Natore-Bogura 132 kV Ckt-1 was under shut down from 08:29 to 09:26 for A/M.

r) Bogura-Sirajganj 132 kV Ckt-1 was under shut down from 09:27 to 09:52 for A/M.

r) Bogura-Sirajganj 132 kV Ckt-1 was under shut down from 10:20 to 10:40 for A/M.

s) Bogura 132/33 kV T3 transformer was under shut down from 10:42 to 11:20 for A/M.

u) Sirajganj-Baghabani 230 kV Ckt-2 was under shut down from 10:00 to 10:38 to 16:32 for A/M.

y) Bogura 132/38 kV bus-1 was under shut down from 09:38 to 16:32 for A/M.

w) Goalpara-Khulna (C) 132 kV Ckt-2 was under shut down from 08:14 to 13:44 for A/M. W) Goalpara-RNUnat (C) 132 KV Ckt-2 was under shut down from 08:20 to 16:22 for A/M.

y) Barisal-Barisa((N) 132 kV Ckt-1 was under shut down from 08:20 to 16:22 for A/M.

y) Lalmonirhat 132/33 kV T1 transformer was switched on at 11:22.

z) Lalmonirhat 132/33 kV T3 transformer was under shut down from 10:25 to 12:18 for tan delta test.

a) Lalmonirhat 132/33 kV T2 transformer was under shut down from 11:29 to 12:28 for tan delta test.

ab) Guishan 132/33 kV T2 transformer was under shut down from 08:07 to 13:33 for A/M.

ac) Bhutla-Ashugani 400 kV Ckt-1 was under shut down from 13:45 to 16:20 due to sparking was found at Ashugani end. found at Ashuganj end.
ad) Bheramara-Faridpur 132 kV Ckt-1 tripped at 13:56 due to B-phase LA burst at Bheramara end
and SPS operated at Faridpur end and was switched on at 17:03.
ae) Ghorasal Unit-5 tripped at 15:35 due to unit transformer bushing problem.
af) Sonargaon-Haripur 132 kV Ckt-2 was under shut down from 16:11 to 16:45 for protection testing.
ag) Bogura(New)-Bogura(Old) 132 kV Ckt-2 was under shut down from 14:21 to 15:35 for A/M.
ah) Siddhirgani-Manikganj 230 kV Ckt-2 with 230/132 kV T02 transformer were shut down
at 07:39 (23/12/2018) for A/M.

Executive Engir

Network Operation Division

Sub Divisional Engineer

Network Operation Division

Superintendent Engine

Load Dispatch Circle