

Reporting Date : 8-Jan-19

Load Shedding & Other Information

Information of the Generating Units under shut down.

Forced Shut- Down

- 1) Barapukuria ST: Unit-1,2
- 2) Khulna ST 110 MW
- 3) Ghorasal Unit-1,5,7
- 4) Tongi GT
- 5) Haripur GT-1,2
- 6) Siddhirganj ST 210 MW
- 7) Bhagabari 71 MW

8) Raozan # 01
9) Sirajganj Unit-2,3,4
10) Ashuganj #3
11) Ashuganj North 360MW
12) Chandpur 150 MW

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Comments on Power Interruption
<p>a) Hathazari-Baraulia 132 kV Ckt-2 was under shut down from 09:18 to 14:45 for A/M.</p> <p>b) Joydevpur 132 kV Bus was under shut down from 10:59 to 14:30 for A/M.</p> <p>c) Ghorasal-Ishurdi 230 kV Ckt-2 was under shut down from 08:07 to 20:09 for A/M.</p> <p>d) Kallyanpur 132/33 kV T-3 transformer was under shut down from 09:22 to 16:07 for A/M.</p> <p>e) Rampura-Bhulta 230 kV Ckt-1 was under shut down from 09:09 to 17:23 for A/M.</p> <p>f) Aminbazar-Kaliakoir 230 kV Ckt-2 was under shut down from 09:45 to 16:31 for A/M.</p> <p>g) Aminbazar-Mirpur 132 kV Ckt-2 was under shut down from 09:01 to 13:33 for A/M.</p> <p>h) Cumilla(N) 230/132 kV TR-1 transformer was under shut down from 10:20 to 17:27 for A/M.</p> <p>i) Hasnabad 230/132 kV TR-3 transformer was under shut down from 07:35 to 14:44 for A/M.</p> <p>j) Srimongal-Fenchuganj 132 kV Ckt-2 was under shut down from 09:48 to 16:26 for A/M.</p> <p>k) Bibiyana-Shahjibazar 230 kV Ckt-2 was under shut down from 08:30 to 16:19 for A/M.</p> <p>l) HVDC-NW 230 kV Ckt-2 was under shut down from 08:10 to 20:16 for A/M.</p> <p>m) Orion power-Bagerhat 132 kV Ckt-2 was under shut down from 08:31 to 15:27 for A/M.</p> <p>n) Khulna(C) 132/33 kV T-3 transformer was under shut down from 010:41 to 12:30 for oil level indicator maintenance.</p> <p>o) Barapukuria 230/132 kV TR-2 & line were shut down at 12:50 for A/M.</p> <p>p) Siddirganj Peaking GT-2 was synchronized at 17:33.</p> <p>q) Khulna(S)-Satkhira 132 kV Ckt-2 was shut down at 17:56 for oil leakage from B-phase CT at Satkhira end.</p> <p>r) Feni-Chowmuhoni 132 kV Ckt-2 was under shut down from 08:53 to 16:28 for A/M.</p> <p>s) Bheramara-Ishurdi 132 kV Ckt-1 was under shut down from 13:01 to 15:33 for C/M.</p> <p>T) Shahjibazar-330 MW GT-1 is under shut down since 22:39 for filter replacement.</p> <p>u) Ghorasal #7 was shut down at 23:50 for maintenance.</p> <p>v) Aminbazar-Kaliakoir 230 kV Ckt-1 & 2 tripped at 23:20 due to B-phase LA of Ckt-2 at Kaliakoir end burst and Ckt-1 was switched on at 23:53.</p> <p>w) Bogura new-Bogura old 132 kV Ckt Bogura old 132 kV main Bus and all 230/132 kV transformer of Bogura new was shut down at 07:14(8/1/19) due development work and was switched on at 08:20(8/1/19).</p> <p>x) Dohazari-Sikalbaha 132 kV Ckt-2 is under shut down since 07:42(8/1/19) for D/W.</p> <p>y) Chowmuhoni-Ramganj 132 kV Ckt-2 tripped at 07:47(8/1/19) showing dist.ABC,Z1.</p> <p>z) Rangpur zone black out due to Bogura-Rajshahi both Ckt & Barapukuria auto transformer tripped at 07:55(8/1/19) showing no signal and was switched on at 08:12(8/1/19).</p>	<p>About 340 MW Power interruption occurred under Rangpur zone from 07:47 to 08:12(8/1/19).</p>
<p>Sub Divisional Engineer Network Operation Division</p>	<p>Executive Engineer Network Operation Division</p>
	<p>Superintendent Engineer Load Dispatch Circle</p>