

QF-LDC-08
Page -1

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk80,398,010		
	Coal :	Tk14,051,172	Oil : Tk170,941,141	Total : Tk265,390,324

Area	Yesterday		Estimated Demand (S/S end)	Today	
	MW			Estimated Shedding (S/S end)	Rates of Shedding (On Estimated Demand)
Dhaka	0	0:00	3048	0	0%
Chittagong Area	0	0:00	1030	0	0%
Khulna Area	0	0:00	922	0	0%
Rajshahi Area	0	0:00	832	0	0%
Cornilla Area	0	0:00	752	0	0%
Mymensingh Area	0	0:00	607	0	0%
Sylhet Area	0	0:00	348	0	0%
Barisal Area	0	0:00	157	0	0%
Rangpur Area	0	0:00	468	0	0%
Total	0		8164	0	

Planned Shut- Down

Forced Shut-Down

Nil

1) Barapukuria ST: Unit-1,2	9) Sirajganj Unit-1,2,4
2) Khulna ST 110 MW	10) Ashuganj #3
3) Ghorasal Unit-1,5,7	11) Ashuganj North 360MW
4) Tongi GT	12) Chandpur 150 MW
5) Haripur GT-1,2	13) Raozan # 02
6) Siddhirganj ST 210 MW	
7) Bhagabari 71 MW, 100 MW	
8) Sikalbhaha 150MW Peaking	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Comments on Power Interruption
<p>a) Chowmohani 132 kV Ckt-1 was under shut down from 08:48 to 15:50 for A/M.</p> <p>b) Jamalpur 132/33 kV T3 transformer was under shut down from 09:48 to 11:43 for A/M.</p> <p>c) B.Baria S/S -B.Baria P/S 132 kV Ckt was under shut down from 09:59 to 15:39 for A/M.</p> <p>d) Fenchuganj S/S-Kulaura 132 kV Ckt was under shut down from 09:27 to 16:36 for A/M.</p> <p>e) Khulna(S)-Satkhira 132 kV Ckt-2 was under shut down from 09:44 to 15:23 for A/M.</p> <p>f) Jhenaidah-Jessore 132 kV Ckt-1 was under shut down from 08:21 to 16:56 for A/M.</p> <p>g) Jessore-Noapara 132 kV Ckt-1 was under shut down from 09:30 to 11:09 for C/M.</p> <p>h) Ghorasal-Ishurdi 230 kV Ckt-2 was under shut down from 09:15 to 17:20 for A/M.</p> <p>i) Netrokona-Mymensingh 132 kV Ckt-2 was under shut down from 08:40 to 14:20 for A/M.</p> <p>j) Fenchuganj 230/132 kV AT2 transformer was under shut down from 08:40 to 19:32 for A/M.</p> <p>k) Chattak 132/33 kV T3 transformer was under shut down from 09:10 to 11:45 for C/M.</p> <p>l) Hasnabad-Kamrangirchar, Hasnabad-Lalbag 132 kV Ckt-5 were under shut down from 08:46 to 17:15 for D/W.</p> <p>m) Rangpur-Saidpur 132 kV Ckt-1,2 both tripped at 08:22 showing inst O/C and were switched on at 08:27.</p>	<p>About 124 MW power interruption occurred under Thakurgaon,Ponchagoar Purbasadipur S/S areas from 08:22 to 08:27.</p>
<p>n) Ghorasal Unit-5 was shut down at 10:38 for gas shortage.</p> <p>o) Ghorasal Unit-4 was shut down at 10:40 for gas shortage.</p> <p>p) Siddhirganj 335 MW was shut down at 11:06 for gas shortage.</p> <p>q) Ghorasal # 07 GT & ST were synchronized at 08:37 & 10:07 respectively and was shut down at 14:42 due to gas shortage.</p> <p>r) Shyampur 132/33 kV GT4 tripped at 11:44 showing Diff O/C and was switched on at 17:18.</p> <p>s) Bhulta 400/230 kV ART-1 transformer was shut down at 12:12 for fire lightning system testing work.</p> <p>t) Noapara 132/33 kV T1& T2 transformers tripped at 10:30 showing no signal and were switched on at 12:02 .</p> <p>u) After maintenance Ullon-Rampura 132 kV cable-1 was switched on at 15:23.</p> <p>v) After maintenance Kodda 132/33 kV T3 transformer was switched on at 15:50.</p> <p>w) Mymensingh-Jamalpur 132 kV Ckt-2 was under shut down from 13:30 to 20:09 for A/M.</p> <p>x) Bhulta 400/230 kV T01 transformer was under shut down from 12:02 to 20:14 for A/M.</p> <p>y) Bogura(Old)-Bogura (N) 132 kV Ckt-1 along with Bogura (Old) 132 kV Reserve bus were under shut down from 07:08 to 10:09(16/01/2019) for D/W.</p> <p>z) Bogura(N) 132 kV main bus along with 230/132 kV T01, T02 & T03 transformer were shut down at 06:56 (16/01/2019) for D/W and 132 kV main bus, T02 & T03 transformers were switched on at 10:07.</p> <p>aa) Maniknagar 132/33 kV Gt-2 transformer was shut down at 07:09 (16/01/2019) for A/M.</p> <p>ab) Hasnabad-Kamrangirchar 132 kV Ckt was shut down at 07:35 (16/01/2019) for D/W.</p> <p>ac) Hasnabad-Lalbag 132 kV Ckt was shut down at 07:33 (16/01/2019) for D/W.</p>	<p>About 11 MW power interruption occurred under Noapara S/S area from 10:30 to 12:02.</p> <p>About 50 MW power interruption occurred under Bogura (Old) S/S area from 07:08 to 10:09(16/01/2019).</p> <p>About 54 MW power interruption occurred under Bogura (New) S/S area from 06:56 to 10:07(16/01/2019).</p>
<p>Sub Divisional Engineer Network Operation Division</p>	<p>Executive Engineer Network Operation Division</p>
	<p>Superintendent Engineer Load Dispatch Circle</p>