

| | | | | | | |
|---------------------------------------|---------------|--------------|-----|-----------------|-------|-----------------|
| | | | | | P.O. | Liter |
| Cost of the Consumed Fuel (PDB+Pvt) : | Gas : | Tk86,037,392 | | | | |
| | Coal : | Tk14,137,250 | | | | |
| | | | Oil | : Tk142,949,539 | Total | : Tk243,124,181 |

| Area | Yesterday | | Estimated Demand (S/S end) | Today | | Rates of Shedding (On Estimated Demand) |
|-----------------|-----------|------|----------------------------|------------------------------|----|--|
| | MW | | | Estimated Shedding (S/S end) | MW | |
| Dhaka | 0 | 0:00 | 3136 | 0 | 0% | |
| Chittagong Area | 0 | 0:00 | 1061 | 0 | 0% | |
| Khulna Area | 0 | 0:00 | 949 | 0 | 0% | |
| Rajshahi Area | 0 | 0:00 | 857 | 0 | 0% | |
| Cornilla Area | 0 | 0:00 | 775 | 0 | 0% | |
| Mymensingh Area | 0 | 0:00 | 625 | 0 | 0% | |
| Sylhet Area | 0 | 0:00 | 357 | 0 | 0% | |
| Barisal Area | 0 | 0:00 | 161 | 0 | 0% | |
| Rangpur Area | 0 | 0:00 | 482 | 0 | 0% | |
| Total | 0 | | 8404 | 0 | | |

| | | |
|--------------------|--|---|
| Planned Shut- Down | Forced Shut- Down | |
| Nil | 1) Barapukuria ST: Unit-1,2 2) Khulna ST 110 MW 3) Ghorasal Unit-1,4,5 4) Tongi GT 5) Hanpur GT-1,2 6) Siddhirganj ST 210 MW 7) Bhagaban 71 MW, 100 MW 8) Sikalbaha 150MW Peaking | 9) Sirajganj Unit-1,4 10) Ashuganj #3 & 5 11) Raozan # 02 12) Sikalbaha 225 MW 13) Shikalbaha 330 MW GT-1 & ST 14) Bhola CCPP GT-1,2 |

| Description | Comments on Power Interruption |
|-------------|--------------------------------|
|-------------|--------------------------------|

| | |
|---|---|
| <p>a) Bibiyana-Kaliakoir 230 Kv Ckt-2 was under shut down from 09:10 to 14:42 for A/M.</p> <p>b) Ghorasal 230/132 kv AT2 transformer was under shut down from 08:40 to 16:29 for C/M.</p> <p>c) Rampura-Bashundhara 132 kv Ckt-1 was under shut down from 09:19 to 13:46 for A/M.</p> <p>d) Joydevpur-Ghorasal 132 kv Ckt-1 was under shut down from 08:34 to 12:50 for A/M.</p> <p>e) Aminbazar-Kaliakoir 230 kv Ckt-1 was under shut down from 09:50 to 16:31 for A/M.</p> <p>f) Chandpur-Rupgonj 132 kv Ckt-2 was under shut down from 08:30 to 13:52 for A/M.</p> <p>g) Munshiganj 132/33 kv T1 transformer was under shut down from 09:14 to 13:31 for A/M.</p> <p>h) Dohazari 132 kv main bus was under shut down from 08:30 to 13:59 for D/W.</p> <p>i) Maniknagar 132/33 kv GT1 transformer was under shut down from 11:02 to 15:59 for maintenance by DPDC.</p> <p>j) Hathazari-BSRM 230 kv Ckt-1 was under shut down from 08:08 to 13:50 for C/M.</p> <p>k) Ghorasal 230/132 kv AT2 transformer was under shut down from 08:40 to 16:29 for C/M.</p> <p>l) Kishoreganj 132 kv bus-B was under shut down from 08:20 to 12:18 for C/M.</p> <p>m) Kishoreganj-Mymensingh 132 kv Ckt-1 was under shut down from 08:18 to 12:36 for C/M.</p> <p>n) Kaliakoir-Tongi 230 kv Ckt-2 was under shut down from 09:51 to 16:32 for A/M.</p> <p>o) Mirpur-Aminbazar 132 kv Ckt-1,2 were under shut down from 10:16 to 21:31 for C/M.</p> <p>p) Ashuganj-Sirajganj 230 kv Ckt-2 tripped at 11:13 from both ends showing Dist Z1 ,RST at both ends and was switched on at 11:26.</p> <p>q) Khulna(S) 230/132 kv T1 transformer was under shut down from 09:20 to 16:51 for A/M.</p> <p>r) Bheramara-Kustia 132 kv Ckt-1 was under shut down from 08:32 to 15:21 for A/M.</p> <p>s) Ashuganj 225 MW GT & ST were synchronized at 12:28 & 15:26 respectively.</p> <p>t) Joldhaka 132/33 kv T2 transformer was switched on at 15:55 without load.</p> <p>u) Shyampur 230 kv S/S-Brammangaon 132 kv Ckt tripped at 16:02 from Shyampur end showing L/O and was switched on at 18:56.</p> <p>v) Bakulia 132/33 kv T1 transformer was switched on at 13:55.</p> <p>w) Bhola CCPG GT-1 tripped at 18:40 due to gas pressure low and was synchronized at 20:36.</p> <p>x) Ashuganj-Shahjibazar 132 kv Ckt-3 was switched on at 20:38.</p> <p>y) Ashuganj-Kishoreganj 132 kv Ckt-1 was switched on at 20:38.</p> <p>z) Madaripur 132/33 kv T3 transformer tripped at 21:03 due to R-phase LA burst at 33 kv side and was switched on at 21:44.</p> <p>aa) Sreemongal 132/33 kv T2 & T3 transformers were shut down at 07:29(27/01/2019) for bay extension work by PBS.</p> <p>ab) Shyampur(New)-Shyampur(Old) 132 kv Ckt-1 & 2 were shut down at 07:07(27/01/2019) for D/W.</p> <p>ac) Barisal-Patuakhali 132 kv Ckt was shut down at 07:09(27/01/2019) for C/M.</p> <p>ad) Raozan Unit-1 tripped at 06:31(27/01/2019) due to failure of DEH and was synchronized at 09:28.</p> | <p>Comments on Power Interruption</p> <p>About 50MW Power interruption occurred under Shyampur S/S area from 16:02 to 18:56.</p> <p>About 3MW Power interruption occurred under Sreemongal S/S area from 07:29 (27/01/2019) to till now.</p> <p>About 140MW Power interruption occurred under Shyampur S/S area from 07:07(27/01/2019) to till now.</p> <p>About 20 MW Power interruption occurred under Patuakhali S/S area from 07:09 (27/01/2019) to till now.</p> |
|---|---|

Superintendent Engineer
Load Dispatch Circle