## POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC.DHAKA. DAILY REPORT

Oil Consumed (PDB):

QF-LDC-08 Page -1

Reporting Date: 27-Aug-09 Till now the maximum generation is: - MW at 4200.5 The Summary of Yesterday's ( ) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Min Gen. at 3112 MW Day Peak Generation MW 11:00 3790.0 Hour 8:00 Evening Peak Generation MW 3961.5 20:00 Max Generation 4000 MW Hour E.P. Demand (at gen end) 4800.0 MW Hour 20:00 Max Demand 4700 MW Maximum Generation 4162.0 MW Hour 5:00 Shortage 700 MW Total Gen. (MKWH) 88.53 92.35% Load Shed 570 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum 500 MW at 2:00 Energy 8892500 KWHR. Import from West grid to East grid :- Maximum MW Energy KWHR.

Water Level of Kaptai Lake at 6:00 A M of 27-Aug-09 Actual: 98.85 Ft.(MSL) Rule curve

MMCFt.

97.35 Ft.( MSL )

HSD 436122 Liter 0 Liter FO

Cost of the Consumed Fuel (PDB): Gas

## Load Shedding & Other Information

774.41

Gas Consumed: Total

Area	Yesterday				Today	
	Actual Shedding (s/s end)		end)	Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	MW	fro	to	MW	MW	(On Estimated Demand)
Dhaka	199	(19:30-01:50	, gen. shortage)	1670	150	9%
Chittagong Area	112	(19:30-01:46	, gen. shortage)	493	103	21%
Khulna Area	88	(19:30-01:10	, gen. shortage)	385	80	21%
Rajshahi Area	79	(19:30-01:49	, gen. shortage)	327	68	21%
Comilla Area	65	(19:30-01:47	, gen. shortage)	290	60	21%
Mymensing Area	50	(19:30-01:39	, gen. shortage)	214	44	21%
Sylhet Area	41	(19:30-23:29	, gen. shortage)	185	11	6%
Barisal Area	10	(19:30-01:10	, gen. shortage)	83	17	20%
Rangpur Area	39	(19:30-01:49	, gen. shortage)	180	37	21%
Total	683	2	0:00	3827	570	

Information of the Generating machines under maintenance

Planned Shut- Down		Forced Shut- Down	
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	9) RPCL ST- 22/08/09	
	2) Shajibazar- 2 (13/07/08)	10) Kaptai -2(26/08/09)	
	3) Shajibazar-4 (18/10/08)		
	4) Khulna 110 (31/03/09)		
	5) RPCL GT-4 (06/06/09)		
	6) NEPC 1 unit is under S/D		
	7) Baghabari GT-2(02/07/09)		
	9) Characal 2 (12/09/00)		

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Forced load shaded / Interrupted Areas

- a) There was generation shortage in the evening peak hour yesterday.
- b) Due to gas limitation, Raozan (360 MW), RPCL (105 MW), Tongi (105 MW), HPL (360 MW),
- and MPL (450 MW) were limited to 200 MW ,59 MW, 25 MW, 297 and 420 MW respectively. c) Due to gas limitation, Shahjibazar - 4 & 5, Haripur SBU GT- 1, 2, 3 (96 MW) were under shut down.
- d) Haripur NEPC tripped at 16:55 due to gas pressure low and was synchronized at 04:07 (27/08/09)
- e) After maintenance, Ashuganj CCPP St was synchronized at 20:28 but it was forced shut down at 04:30 (27/08/09) due to steam generator excitation fault . It may be synchronized before evening peak hour today.
- f) Aminbazar Savar 132 KV line -1 & 2 were under development work from 10:05 to 17:00.
- g) Serajganj 132/33 KV T1 transformer was under annual maintenance from 11;14 to 14:05
- h) Chapainababganj 132/33 KV T1 transformer was under shut down from 12:05 to 13:05 due to breaker maintenance.
- i) Bogra 132/33 KV T1 transformer was under shut down from 12:51 to 17:37 due to connection of metering instrument by EAU Bogra.
- j) After maintenance, Hasnabad 132/33 KV T2 transformer was switched on at 14:12.
- k) Barisal 132 KV S/S Barisal GT P/S 132 KV line was under NLDC project work from 15:45 to 18:56.

So about 683 MW (20:00) of load shed was imposed over the whole area of the national grid

Deputy / Asstt. Manager Load Despatch Division Manager Load Despatch Division Deputy General Manager Load Despatch Circle