a) Barisa(o(d) 132/33 kV T1 and T2 transformers tripped at 00:27(23/5/2019) showing O/C, E/F relay and v switched on at 00:33.

am) Baghabari 71 MW was shut down at 05:12(23/5/2019) due to filter replacement.

an) HVDC B

Executive Engineer Network Operation Division Superintendent Engineer Load Despatch Circle