## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT QF-LDC-08 Page -1 Reporting Date: 23-Sep-19 Hrs on 29-May-19 Today's Actual Min Gen. & Probable Gen. & Demand 15-Con at 8:00 7991 MW Till now the maximum generation is: -12893 MW The Summary of Yesterday's Day Peak Generation 22-Sep-19 Generation & Demand 9866.3 MW 12:00 Evening Peak Generation E.P. Demand (at gen end) Available Max Generation 11378 0 MW 19:00 15485 MW 11378.0 MW 11378.0 MW 19:00 19:00 Max Demand (Evening) : Reserve(Generation end) 11900 MW 3585 MW Total Gen. (MKWH) 285.5 vstem Load Factor 104.55% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum -150 MW MW MKWHR. Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on MKWHR 23-Sep-19 Actual: 104.48 Ft.(MSL) Rule curve : 104.08 Ft.( MSL ) Total = 1321.27 MMCFD. Oil Consumed (PDB) Gas Consumed : HSD FO Cost of the Consumed Fuel (PDB+Pvt) : Tk187.922.863 Tk25,663,114 Oil : Tk458,541,617 Total : Tk672,127,593 Load Shedding & Other Information

Area	Yesterday		Today		
		•	Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	4252	0	0%
Chittagong Area	0	0:00	1448	0	0%
Khulna Area	0	0:00	1298	0	0%
Rajshahi Area	0	0:00	1173	0	0%
)	0	0:00	1060	0	0%
Mymensingh Area	0	0:00	855	0	0%
Sylhet Area	0	0:00	475	0	0%
Barisal Area	0	0:00	220	0	0%
Rangpur Area	0	0:00	660	0	0%
Total	0		11441	0	

Information of the Generating Units under shut down

Planned Shut- Down

Forced Shut-Down 1) Barapukuria S 7) Ashuganj #5 2) Khulna ST 110 8) Chattogram TPP-2 3) Sikalbaha ST (9)Sirajganj Unit-3 4) Siddhirganj S1 10) Ghorasal Unit-5 5) Ashuganj #4 11) Barapukuria Unit-1 6) Baghabari 100 MW, 71 MW

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description

Comments on Power Interruption

- a) Sylhet 150 MW was shut down at 08:01 for problem of Cooling system and was synchronized at 15:05.
- b) Sirajganj unit-3 GT synchronized at 09:30 and ST was synchronized at 12:27 again Sirajganj unit-3 was shut down at 12:45 for gas shortage.
- c) Raozan unit-1 tripped at 10:00 for problem of Boiler and was synchronized at 10:50.
- d) Baghabari 71 MW was shut down at 10:27 for Gas shortage.
- e) Hathazari-Raozan 230 kV Ckt-2 tripped at 09:54 from ends showing distance relay at 3-Phase and was switched on at 11:32. It is closed from Hathazari end.
- f) Ishurdi-Baghabari 132 kV Ckt was under shut down from 11:34 to 12:45 for R/H maintenance at isolator of
- g) Siddhirganj GT-1 was shut down at 11:06 for gas shortage.
- h) Ishurdi-Natore 132 kV Ckt-2 tripped at 11:36 from Ishurdi end showing dist. at B-phase and was switched on at 11:41 and Ckt-1 was switched on at 14:38.
- i) Amnura 132 kV Bus closed at 13:02.
- j) Ghorasal-Bhulta 230 kV Ckt-2 was switched on at 17:44.
- k) Ishurdi-Ruppur 132 kV Ckt-2 was switched on at 14:49.
- I) Bogura-Sirajganj 132 kV Ckt-2 was in/out at 14:40 at Sherpur s/s and Sherpur(Bogura) 132/33 kV T-2 transformer was charged at 16:12.
- m) Siddirganj 335 MW STG synchronized at 14:21.
- n) Tangail 132/33 kV T-2 transformer was under shut down from 16:37 to 17:36 for protection test.
- o) Purbasadipur 132/33 kV T-2 transformer was under shut down from 15:25 to 16:36 for R/H maintenance at CB connector nut of 33 kV feeder
- p) Khulna(s)-Satkhira 132 kV Ckt-1 tripped at 16:46 from both ends showing dist. Z1 at A,B,C-phase and was
- q) Noapara 132/33 kV T-1 transformer tripped at 17:10 showing inst. E/F relay and was switched on at 17:54.
- r) Madaripur 132/33 kV T-3 transformer was under shut down from 19:15 to 08:09(23/9/19) for fire at 33 kV under ground cable.
- s) Meghnaghat-Shaympur 230 kV Ckt-1 was under shut down from 06:08(23/9/19) to 11:40 for R/H maintenance at Meghnaghat end.
- t) Khulna(s) 132 kV capacitor bank tripped at 07:10(23/9/2019) showing unbalance current.
  u) Chowmohoni 132/33 kV T-2 transformer along with T-2 33 kV bus was under shut drawn from 07:06/23/8/191

to 08:25 for R/H maint. at Noakhali sadar PBS feeder.

out 14 MW power interruption occurred under Chowmohoni S/S area from 07:05(23/9/19) to 08:25.

v) Chandpur 132 kV Ckt, 3352 mid CB was switched off at 07:00(23/9/19) due to low gas pressure.

from 07:35(23/9/19) to 10:16.

Superintendent Enginee

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division

Load Despatch Circle