Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2019 | Day : **Friday** | Date : **27.09.19**

Probable Maximum Demand : 10700 MW | **Probable Maximum Generation :** 14730 MW

Water Level of Kaptai Lake at 06:00 AM | Yesterday = **104.70** ft | Today = **104.73** ft. | Rule Curve = **105.04** ft.

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.09.19 (Yesterday) Actual Peak Generation (MW)		27.09.19 (Today) Probable Peak Generation (MW)		26.09.19 (Yesterday) Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
											Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
							Day	Evening	Day	Evening				
(A)	**Plants in operation:**													
1	a) Ghorasal TPP (Unit-1&2)	Gas	(PDB)	2 x 55	110	85	**73**	**73**	**73**	**73**				
	b) Ghorasal Repowered CCPP Unit-3	Gas	(PDB)	1 x 210	210	170	**233**	**218**	**210**	**210**			On Test	
	c) Ghorasal Repowered CCPP Unit-4	Gas	(PDB)	1 x 210	210	180	**0**	**0**	**0**	**0**			On Test (Gas Shortage)	
	d) Ghorasal TPP Unit-5	Gas	(PDB)	1 x 210	210	190	**0**	**0**	**0**	**0**	**190**		Gas Shortage	
2	Ghorasal 365 MW CCPP Unit-7	Gas	(PDB)	1x 254+1x 126	365	365	**280**	**310**	**280**	**320**	**55**		Gas Shortage	
3	Ghorashal 108MW PP (Regent)	Gas	(IPP)	34x3.35	108	108	**0**	**0**	**0**	**0**	**108**		Gas Shortage	
4	Ghorashal 78.5 MW PP(MAX)	Gas	(QRPP)	2x40	78	78	**0**	**0**	**0**	**0**	**78**		Gas Shortage	
5	Tongi 80 MW GTPP	Gas	(PDB)	1 x 105	105	105	**0**	**0**	**0**	**0**	**105**		Gas Shortage	
6	Haripur GTPP	Gas	(PDB)	2 x 32	64	40	**0**	**0**	**0**	**0**	**40**		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas	(IPP)	1x235+1x125	360	360	**300**	**352**	**350**	**350**				
8	Meghnaghat 450 MW CCPP(MPL)	Gas	(IPP)	2x140+1x170	450	450	**380**	**370**	**450**	**450**				
9	210 MW Siddhirgonj TPP	Gas	(PDB)	1 x 210	210	115	**0**	**0**	**0**	**0**	**115**		Gas Shortage	
10	Haripur 412 MW CCPP	Gas	(EGCB)	1x273+1x139	412	412	**356**	**355**	**350**	**412**				
11	Siddhirgonj 2*120 MW GTPP	Gas	(EGCB)	2 x 105	210	210	**0**	**0**	**0**	**0**	**210**		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas	(EGCB)	1 x 217	217	217	**0**	**0**	**0**	**0**		**217**	Under Maintenance	01.10.2019
13	Siddhirganj 100 PP(Dutch Bangla)	HFO	(QRPP)	12x8.9	100	100	**0**	**50**	**100**	**100**				
14	Meghnaghat CCPP(Summit)	GAS	(IPP)	2x110+1x110	305	305	**120**	**150**	**150**	**150**				
15	Meghnaghat 100 MW(IEL)	HFO	(QRPP)	12x8.9	100	100	**0**	**50**	**100**	**100**				
16	Madanganj 102 PP(Summit)	HFO	(QRPP)	6x17	102	100	**0**	**15**	**80**	**80**				
17	Madanganj-55 MW PP(Summit)	HFO	(IPP)	5x17.08+1x11.3	55	55	**0**	**25**	**55**	**55**				
18	Keraniganj 100 MW PP (Powerpac)	HFO	(QRPP)	8x13.45	100	100	**0**	**10**	**100**	**100**				
19	Gagnagar 102 MW PP (Digital Pow	HFO	(IPP)	12x8.924	102	102	**48**	**58**	**100**	**100**				
20	Narshingdi 22 MW PP (Doreen)	Gas	(SIPP, REB)	8x2.90	22	22	**16**	**16**	**22**	**22**				
21	Summit Power,(Madhabdi+Ashulia)	Gas	(SIPP, REB)	6x3.67+7x8.73	80	80	**56**	**50**	**57**	**57**				
22	Maona 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73	33	33	**33**	**33**	**33**	**33**				
23	Rupganj 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73	33	33	**33**	**33**	**33**	**33**				
24	Gazipur 52 MW PP	HFO	(RPCL)	6x8.90	52	52	**43**	**43**	**40**	**43**				
25	Gazipur 100 MW PP	HFO	(RPCL)	6x18.415	105	105	**102**	**105**	**105**	**105**				
26	Kodda 150MW PP	HFO	(BPDB-RPCL)	9x17.06	149	149	**116**	**149**	**149**	**149**				
27	Katpotti 52 MW PP (Sinha)	HFO	(IPP)	7x7.90	51	51	**6**	**6**	**40**	**40**				
28	Kamalaghat 54 MW PP (Banco Energy)	HFO	(IPP)	3x18.69	54	54	**53**	**53**	**54**	**54**				
29	Kodda 300 MW PP Unit-2 (Summit)	HFO	(IPP)	18x17.076	300	300	**0**	**95**	**200**	**300**				
30	Kodda 149 MW PP Unit-1 (Summit)	HFO	(IPP)	8x18.415+1x8.97	149	149	**0**	**119**	**149**	**149**				
31	Keranigonj 300 MW PP (APR)	HSD	(IPP)	256x1.4	300	300	**0**	**0**	**200**	**300**				
32	Bramhangoan 100 MW PP (Aggreko)	HSD	(IPP)	23x0.85+91x.959	100	100	**0**	**0**	**0**	**100**				
33	Aurahati 100MW PP (Aggreko)	HSD	(IPP)	23x0.85+91x.959	100	100	**0**	**0**	**0**	**100**				
34	Nababganj 55 MW PP (Southern pc	HFO	(IPP)	3x19.3	55	55	**17**	**55**	**55**	**55**				
35	Manikganj 55 MW PP (Northern)	HFO	(IPP)	3x19.3	55	55	**35**	**55**	**55**	**55**				
36	Bosila 108MW PP(CLC)	HFO	(IPP)	12x8.775+1x3.5	108	108	**69**	**69**	**70**	**72**				
	Dhaka Zone Total				**5929**	**5693**	**2369**	**2917**	**3660**	**4167**	**901**	**217**		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro	(PDB)	2x40, 3x50	230	230	**90**	**177**	**180**	**180**				
38	a) Chattogram TPP-1	Gas	(PDB)	1 x 210	210	180	**75**	**75**	**75**	**75**				
	b) Chattogram TPP-2	Gas	(PDB)	1 x 210	210	180	**0**	**0**	**0**	**0**		**180**	Under Maintenance	02.10.2019
39	Kaptai 7 MW Solar PP	Solar	(PDB)		7	7	**0**	**0**	**4.4**	**0**				
40	Raozan 25 MW PP	HFO	(RPCL)	3x8.9	25	25	**0**	**25**	**25**	**25**				
41	Teknaf 20MW PP (Solartech)	Solar	(IPP)	1x20	20	20	**7.87**	**0**	**20**	**0**				
42	Patenga 50MW PP (Baraka)	HFO	(IPP)	8x6.89	50	50	**19**	**46**	**50**	**50**				
43	Sikalbaha 105 MW PP (Baraka Sika	HFO	(IPP)	6x18.415	105	105	**0**	**17**	**50**	**100**				
44	Shikalbaha Peaking GT	Gas	(PDB)	1 x 150	150	150	**146**	**130**	**130**	**130**				
45	Sikalbaha 225 MW CCPP	Gas	(PDB)	1 x 150+1 x 75	225	225	**208**	**204**	**210**	**210**				
46	Anwara 300 MW PP (United)	HFO	(IPP)	17x17.076+ 3x8.04	300	300	**127**	**106**	**230**	**260**				
47	Juldah 100 MW Unit-1 (Acorn)	HFO	(QRPP)	8x13.45	100	100	**10**	**10**	**100**	**100**				
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO	(IPP)	8x13.45	100	100	**70**	**100**	**100**	**100**				
49	Dohazari -Kalaish 100 MW Peaking	HFO	(PDB)	6x17.0	102	102	**0**	**68**	**90**	**102**				
50	Hathazari 100 MW peaking PP	HFO	(PDB)	11x8.9	98	98	**0**	**0**	**0**	**0**				
51	Barabkunda 22 MW PP (Regent)	Gas	(SIPP, PDB)	8x2.90	22	22	**16**	**16**	**22**	**22**				
*	Malancha, Ctg.EPZ (United)	Gas		5x8.73+3x9.34			**3**	**25**	**10**	**20**				
52	Chattogram 108 MW PP (ECPV)	HFO	(IPP)	16x7.00	108	108	**0**	**48**	**90**	**90**				
53	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO	(IPP)	3x18.55+1x3.6	54	54	**0**	**52**	**54**	**54**				
54	Karnaphuli Power Ltd.	HFO	(IPP)	6x18.41+1x6.4	110	110	**0**	**17**	**113**	**113**				
	Chattogram Zone Total				**2226**	**2166**	**771.87**	**1116**	**1553.4**	**1631**	**0**	**180**		
55	a) Ashuganj TPP Unit- 3	Gas	(APSCL)	1 x 150	150	135	**0**	**0**	**0**	**0**	**135**		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas	(APSCL)	1 x 150	150	129	**0**	**0**	**0**	**0**	**129**		Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas	(APSCL)	1 x 150	150	134	**80**	**100**	**100**	**100**				
56	Ashuganj 50 MW PP	Gas	(APSCL)	14x3.968	53	45	**27**	**27**	**33**	**33**				
57	Ashuganj 225 MW CCPP	Gas	(APSCL)	1×142+1*75	221	221	**192**	**181**	**0**	**0**				
58	Ashuganj 450 MW CCPP(South)	Gas	(APSCL)	1x360	360	360	**305**	**270**	**360**	**360**				
59	Ashuganj 450 MW CCPP(North)	Gas	(APSCL)	1x361	360	360	**375**	**300**	**360**	**360**				
60	Ashuganj 55 MW PP (Precision)	Gas	(RPP)	15*4	55	55	**10**	**54**	**55**	**55**				
61	Ashuganj 195MW PP (APSCL-	Gas	(IPP)	20*9.73+1*16	195	195	**8**	**8**	**8**	**8**				
62	Ashuganj 51 MW PP (Midland)	Gas	(IPP)	6x9.34	51	51	**35**	**35**	**43**	**43**				
63	Ashuganj 150MW PP (Midland)	HFO	(IPP)	23x7.015	150	150	**0**	**63**	**150**	**150**				
64	Titas 50 MW Peaking PP	HFO	(PDB)	6x8.92	52	52	**0**	**0**	**0**	**50**				
65	Chandpur 150 MW CCPP	Gas	(PDB)	1X106+1x57	163	163	**0**	**95**	**100**	**100**				
66	Chandpur 200MW (Desh energy)	HFO	(IPP)	12x18.415	200	200	**57**	**145**	**180**	**180**				
67	Feni 22MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	**22**	**22**	**0**	**22**				
68	Feni 11 MW PP (Doreen)	Gas	(SIPP, REB)	4x2.90	11	11	**8**	**5**	**11**	**11**				
69	Jangalia 33MW PP (Summit)	Gas	(SIPP, PDB)	4x8.73	33	33	**13**	**33**	**33**	**33**				
70	Jangalia 52 MW PP (Lakdanavi)	HFO	(IPP)	6x8.92	52	52	**8**	**45**	**52**	**52**				
71	Cumilla 25 MW PP (Summit)	Gas	(SIPP, REB)	3x3.67+2x6.97	25	25	**15**	**20**	**20**	**20**				
72	Daudkandi 200 MW PP (B.Trac)	HSD	(IPP)	9x1.4+40x1.515+15x1.05	200	200	**0**	**0**	**0**	**200**				
**	Impoprt (Tripura)		India		160	160	**130**	**160**	**137**	**189**				
	Cumilla Zone Total				**2813**	**2753**	**1285**	**1563**	**1642**	**1966**	**264**	**0**		
73	RPCL 210MW CCPP	Gas	(IPP)	4x35+1x70	210	202	**107**	**109**	**110**	**110**				
74	Tangail 22 MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	**20**	**22**	**22**	**22**				
75	Jamalpur 95 MW PP(Powerpac)	HFO	(IPP)	12x8.924	95	95	**2**	**91**	**95**	**95**				
76	Jamalpur 115 MW PP (United)	HFO	(IPP)	12x9.87	115	115	**106**	**115**	**115**	**115**				
77	Mymensingh 200 MW PP (United)	HFO	(IPP)	21x9.780	200	200	**0**	**140**	**200**	**200**				
78	Sarishabari 3 MW Solar Plant	Solar	(IPP)	12x8.924	3	3	**1.4**	**0**	**1.6**	**0**				
	Mymensing Zone Total				**645**	**637**	**236.4**	**477**	**543.6**	**542**	**0**	**0**		

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.09.19 (Yesterday) Actual Peak Generation (MW)		27.09.19 (Today) Probable Peak Generation (MW)		26.09.19 (Yesterday) Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
79	Fenchugonj CCPP Phase-1	Gas	(PDB)	2x32+1x33	97	70	59	60	60	60				
80	Fenchugonj CCPP Phase-2	Gas	(PDB)	2x35+1x35	104	90	41	41	40	40				
81	Fenchugonj 51 MW PP (Barakatull	Gas	(RPP)	19x2.90	51	51	44	50	51	51				
82	Fenchuganj 44MW (Energyprima)	Gas	(RPP)	12x3.3+5x2.0	44	44	43	46	44	44				
83	Kushiara 163 MW CCPP (KP)	Gas	(IPP)	1x109+1x54	163	163	130	130	163	163				
84	Hobiganj 11MW PP Cofidence-E	Gas	(SIPP, REB)	4x2.90	11	11	8	8	11	11				
85	Shahjibazar GTPP Unit- 8 & 9	Gas	(PDB)	2x35	70	66	64	67	66	69				
86	Shajibazar 330 MW CCPP	Gas	(PDB)	2x110+2x110	330	330	195	192	210	210				
87	Shahjibazar 86MW PP (Shahjibaza	Gas	(RPP)	32x2.90	86	86	55	78	79	80				
88	Shahjibazar 50MW PP (EPL)	Gas	(RPP)	27x2.0	50	50	45	47	47	47				
89	Sylhet 150 MW CCPP	Gas	(PDB)	1x142	142	142	123	85	120	130				
90	Sylhet 20 MW GTPP	Gas	(PDB)	1 x 20	20	20	18	18	18	18				
91	Sylhet 50MW PP (EPL)	Gas	(RPP)	27x2.0	50	50	42	45	42	42				
92	Sylhet 10MW PP (Desh)	Gas	(RPP)	6x1.95	10	10	10	10	10	10				
93	Shahjahanulla 25 MW PP	Gas	(CIPP, REB)	3x9.34	25	25	16	24	24	24				
94	Bibiana-II 341 MW CCPP (Summit)	Gas	(IPP)	1x222+1x119	341	341	300	265	335	335				
95	Bibiyana-III 400 MW CCPP	Gas	(PDB)	1x285	285	285	421	428	400	400				
	Sylhet Zone Total				**1879**	**1834**	**1614**	**1594**	**1720**	**1734**	**0**	**0**		
96	Bheramara GTPP Unit-1,2 & 3	HSD	(PDB)	3 x 20	60	46	0	0	0	30				
97	Bheramara 360 MW CCPP	Gas	(NWPGCL)	1 x 278+1 x 132	410	410	300	300	350	410				
98	Faridpur 50 MW Peaking PP	HFO	(PDB)	8x6.98	54	54	0	45	0	40				
99	Gopalganj 100 MW Peaking PP	HFO	(PDB)	16x6.98	109	109	0	55	0	75				
100	Khulna 225 MW CCPP	HSD	(NWPGCL)	1 x 150+1x75	230	230	0	0	200	200				
101	Khulna 115 PP MW (KPCL-2)	HFO	(QRPP)	7x17	115	115	0	83	115	115				
102	Noapara 100 MW PP (Bangla Trac)	HSD	(IPP)	70x1.4+7x1.515	100	100	0	0	80	100				
103	Noapara 40 MW PP (Khanjahan Ali	HFO	(QRPP)	5x8.5	40	40	0	40	40	40				
104	Rupsha 105 MW PP (Orion rupsha)	HFO	(IPP)	6x18.445	105	105	0	53	105	105				
105	Madhumati 100 MW PP	HFO	(NWPGCL)	6x18.415	105	105	17	85	100	100				
**	Bheramara (HVDC)		India		1000	1000	910	915	0	929				
	Khulna Zone Total				**2328**	**2314**	**1227**	**1576**	**990**	**2144**	**0**	**0**		
106	Barisal GT PP Unit-1& 2	HSD	(PDB)	2 x 20	40	30	0	0	0	30				
107	Barisal 110 MW PP (Summit)	HFO	(IPP)	7 x 17.076	110	110	0	64	70	110				
108	Bhola 33 MW PP (Venture)	Gas	(RPP)	1x34.50	33	33	21	28	33	33				
109	Bhola 225 MW CCPP	Gas	(PDB)	2x63+1x68	194	194	136	116	180	183				
110	Bhola 95 MW PP (Aggreko)	Gas	(QRPP)	1.1x96	95	95	52	95	95	95				
	Barishal Zone Total				**472**	**462**	**209**	**303**	**378**	**451**	**0**	**0**		
111	a) Baghabari 71 MW GTPP	Gas	(PDB)	1 x 71	71	71	0	0	55	55				
	b) Baghabari 100 MW GTPP	Gas	(PDB)	1 x 100	100	100	0	0	0	0		100	Under transformer Maint.	10.10.19
112	Baghabari 50 MW Peaking PP	HFO	(PDB)	6x8.9	52	52	0	50	0	50				
113	Baghabari 200 MW PP (Paramount	HSD	(IPP)	135x1.6	200	200	0	0	200	200				
114	Bera 70 MW Peaking PP	HFO	(PDB)	9x8.29	71	71	0	38	0	45				
115	Amnura 50 MW PP(Sinha)	HFO	(QRPP)	7x7.79	50	50	0	18	18	18				
116	Chapainawabganj 100 MW Peaking	HFO	(PDB)	12x8.924	104	104	0	79	80	80				
117	Katakhali 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	43	46	46				
118	Katakhali 50 MW PP (Northern)	HFO	(QRPP)	6x8.9	50	50	0	42	50	50				
119	Santahar 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	28	0	35				
120	Sirajgonj 225MW CCPP Unit-1	Gas	(NWPGCL)	1x150+1x75	210	210	163	173	214	214				
121	Sirajgonj 225MW CCPP Unit-2	Gas	(NWPGCL)	1x150 + 1x75	220	220	179	169	200	210				
122	Sirajgonj 225MW CCPP Unit-3	Gas	(NWPGCL)	1x141+1x79	220	220	0	0	0	0				
123	Sirajgonj 400 MW CCPP Unit-4	Gas	(IPP)	1x282+1x132	414	414	384	326	300	400				
124	Bogra 22 MW PP (GBB)	Gas	(RPP)	6x4.0	22	22	21	22	22	22				
125	Bogura 20 MW PP (Energyprima)	Gas	(RPP)	5x3.3+5x2.0	20	10	16	17	20	20				
126	Ullapara 11 MW PP (Summit)	Gas	(SIPP, REB)	4x2.90	11	11	8	11	11	11				
127	Natore 52 MW PP (Rajlanka)	HFO	(IPP)	6x8.92	52	52	0	52	52	52				
128	Bagura 113 MW PP (Confidence)	HFO	(IPP)	6x18.55	113	113	35	112	113	113				
	Rajshahi Zone Total				**2080**	**2070**	**806**	**1180**	**1381**	**1621**	**0**	**100**		
129	a) Barapukuria TPP Unit-1	Coal	(PDB)	1 x 125	125	85	70	70	65	65				
	b) Barapukuria TPP Unit-2	Coal	(PDB)	1 x 125	125	85	0	0	0	0		85	Under Maintenance	05..10.19
130	Barapukuria 275 MW TPP Unit-3	Coal	(PDB)	1 x 274	274	274	275	275	280	280				
131	Rangpur 20 MW GTPP	HSD	(PDB)	1 x 20	20	20	0	17	0	16				
132	Rangpur 113 MW PP (Confidence)	HFO	(IPP)	7*16x 2*3	113	113	34	113	113	113				
133	Saidpur 20 MW GTPP	HSD	(PDB)	1 x 20	20	20	0	18	0	0				
134	Majipara, Tatulia 8 MW Solar PP (Sympa	Solar	(IPP)	1 x 8	8	8	7.4	0	8	0			On Test	
	Rangpur Zone Total				**685**	605	**386**	**493**	**466**	**474**	**0**	**85**		
	Sub-total: Plants in operation				**19057**	**18534**	**8905**	**11219**	**12334**	**14730**	**1165**	**582**		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							**8571**	**10484**	**11872**	**14179**				
(B) Contract expired power plants														
135	Ashuganj 53MW PP (United)	Gas	(QRPP)	14x4.00	53	53	0	0	0	**0**			Contract expired	
136	Brahmanbaria 85 MW PP (Aggreko)	Gas	(QRPP)	86x1.10	85	85	0	0	0	**0**			Contract expired	
	Sub-Total: Plants under long term maintenance				138	138	0	0	0	0				
	Gross Total				**19195**	**18672**	**8905**	**11219**	**12334**	**14730**	**1165**	**582**		

(C)	**Actual data of 26.09.19 (Yesterday) Thursday :**			
01.	Max. Demand (Generation end)	:	**11219.00**	MW, at = **21:00:00 hrs**
02.	Max. Demand (Sub-station end)	:	**10484.00**	MW, at = **21:00:00 hrs**
03.	Highest Generation (Generation end)	:	**11219.00**	MW, at = **19:00 hrs**
04.	Minimum Generation (Generation end)	:	**7344.00**	MW, at = **6:00 hrs**
05.	Day-peak Generation (Generation end)	:	**8904.67**	MW, at = **11:00 hrs**
06.	Evening-peak Generation (Generation end)	:	**11219.00**	MW, at = **21:00:00**
07.	Evening Peak Load-shed (Sub-station end)	:	**0.00**	MW, at = **21:00:00 hrs**
08.	Actual Minimum Generation up to 8:00 hrs.	:	**6957.10**	MW
09.	Generation shortfall at evening peak due to :	:		
	a) Gas limitation	:	**1165**	MW
	d) Coal supply Limitation	:	**0**	MW
	b) Low water level in Kaptai lake	:	**0**	MW
	c) Plants under shut down/ maintenance	:	**582**	MW
10.	Total Energy (Generation + India Import)	:	**217.17**	MKWh
	By Gas = 149.071 MKWH		By Oil =	30.898 MKWh
	By Coal = 8.296 MKWH		By Hydro =	3.822 MKWh
	By Solar= 0.126 MKWH			
11.	Total Gas Supplied	:	**1250.40**	MMCFD

12. **Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :**

Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
Dhaka	**4037**	**4037**	**0**	Mymensingh	**911**	**911**	**0**
Chattogram	**1151**	**1151**	**0**	Sylhet	**479**	**479**	**0**
Khulna	**1153**	**1153**	**0**	Barishal	**304**	**304**	**0**
Rajshahi	**1153**	**1153**	**0**	Rangpur	**304**	**304**	**0**
Cumilla	**992**	**992**	**0**				
				Total	**10484**	**10484**	**0**

13.	Fuel cost :	(a) Gas = **139108358** Taka		(c) Coal = **37615423**	Taka
		(b) Oil = **262084683** Taka		Total = **176723781**	Taka
14.	Maximum Temperature in Dhaka was :	**31.2° C**			
15.	Export through East-West interconnections :				
	At evening peak-hour	:	**106**	MW, at	**21:00:00 hrs PM**
	Maximum	:	**-16**	MW, at	**18:30 hrs**
	Energy	:	**0.0245**	MKWh	

(D)	**Forecast of 27.09.19 (Today) Friday :**				
01.	Maximum Demand	:	**10700**	MW	(Generation end)
02.	Maximum Generation	:	**14730**	MW	(Generation end)
03.	Maximum Shortage	:	**-4030**	MW	(Generation end)
04.	Maximum Load-shed	:	**0**	**MW**	At evening peak (Sub-station end)
05.	Total Generation	:	**207.13**	**MKWh**	
06.	Probable Max. Temperature in Dhaka :		**31.6° C**		

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(MONIRUZZAMAN)
Deputy Secretary, Generation