| POWER GRID COMPANY OF BANGLADESH LTD. | | | | | | | Revis | |
|---|-------------------|---------------|--|---|---------------|---|------------------------------|-------------------|
| NATIONAL LOAD DESPATCH CENTER | | | | | | | | QF-LDC-08 |
| | | | DAILY REPORT | | | Reporting | Date · 1 | -Oct-19 |
| Till now the maximum g | eneration is : - | | 12893 MW | | 21:00 | Hrs on 29-May | | -00(-15 |
| The Summary of Yesterd | | 30-Sep-19 | Generation & Deman | d | | Today's Actual Min Ge | | ble Gen. & Demand |
| Day Peak Generation : | | 8470.7 | 7 MW | 12:00 | | Min. Gen. at 7:0 | | 6953 MW |
| Evening Peak Generation : | | 10426.0 | | 19:30 | | Available Max Generation | on | 14965 MW |
| E.P. Demand (at gen end) : | | 10426.0 | | 19:30 | | Max Demand (Evening) | | 10700 MW |
| Maximum Generation : | | 10426.0 | | 19:30 | | Reserve(Generation end | d) | 4265 MW |
| Total Gen. (MKWH) : | EVEO | | | 82.17% | | Load Shed | : | 0 MW |
| Export from East grid to We | | | THROUGH EAST-WES |) MW | at | 20:00 E | Energy | MKWHR. |
| Import from West grid to Ea | | | -30 | MW | at | | Energy | - MKWHR. |
| Water Level of Kaptai | | | 1-Oct-19 | | at | | nergy | - Mix White |
| | ual: 104.49 | Ft.(MSL), | Rule curve : | | 106.00 | Ft.(MSL) | | |
| | | | | | | | | |
| Gas Consumed : | Total = | 1238.50 | MMCFD. | Oil Cons | umed (PDB): | | | |
| | | | | | | HSD | : | Liter |
| | | | | | | FO | : | Liter |
| | (222 2 4) | | T I 400 000 000 | | | | | |
| Cost of the Consumed Fuel | (PDB+Pvt) : | Gas | / / | | 0.1 | TL 170 100 000 T | | 7 550 070 |
| | | Coal | : Tk38,136,561 | | Oil : | Tk172,430,806 T | otal : Tk34 | 7,556,973 |
| | | l oad Shoddin | g & Other Information | | | | | |
| | | | | | | | | |
| Area Yesterday | | | | | | Today | | |
| | | | Estimated Demand (S/S | end) | | Estimated Shedding (S/ | Send) Rat | es of Shedding |
| | MW | | MW | | | MŴ | | Estimated Demand) |
| Dhaka | 0 | 0:00 | 3798 | | | 0 |) | 0% |
| Chittagong Area | 0 | 0:00 | 1290 | | | 0 | | 0% |
| Khulna Area | 0 | 0:00 | 1156 | | | 0 | | 0% |
| Rajshahi Area | 0 | 0:00 | 1045 | | | 0 | - | 0% |
|) | 0 | 0:00 | 944 | | | 0 | - | 0% |
| Mymensingh Area Sylhet Area | 0 0 | 0:00 0:00 | 762 427 | | | 0 | - | 0% 0% |
| Barisal Area | 0 | 0:00 | 196 | | | 0 | | 0% |
| Rangpur Area | 0 | 0:00 | 587 | | | 0 | | 0% |
| Total | 0 | 0.00 | 10206 | | | 0 | | 070 |
| Information of the Generating Units under shut down. Planned Shut- Down Forced Shut- Down | | | | | | | | |
| | Fianned Shut- | DOWIT | | | | 7) Ghorasal Unit-1,4 | 8.5 | |
| | | | | 2) Khuln 3) Sikalb 4) Siddh 5) Ashug | a ST 110 MW | 8) Chattogram TPP-/ 9)Sirajganj Unit-3 | | |
| Additional Information of Machines, lines, Interruption / Forced Load shed etc. | | | | | | | | |
| Description | | | | | _ ^ ^ / | Comments on Pov | ver Interri | uption |
| a) Ishurdi-Ruppur 132 kV Ckt-1 was under shut down from 09:45 to 18:01 for D/W. | | | | | | | | |
| b) Mymensingh-Jamalpur 132 kV Ckt-2 was under shut down from 08:05 to 11:18 for C/M. | | | | | | | | |
| c) Madaripur 132 kV B-bus was under shut down from 09:58 to 16:58 for for D/W. | | | | | | | | |
| d) Tangail 132/33 kV T2 transformer was under shut down from 08:48 to 09:43 for C/M. | | | | | | | | |
| e) Kulaura 132/33 kV T2 transformer was under shut down from 11:48 to 13:56 for C/M. | | | | | | | | |
| f) Kulaura 132/33 kV T1 transformer was under shut down from 08:57 to 11:47 for C/M. g) Barishal 132/33 kV T1 transformer tripped at 00:18 (01/10/2019) from both end showing lock out relay at 132 kV side & E/F & O/C relay at 33 kV side due to 33 kV Bakerganj PBS feeder fault and was switt | | | | | | About 15 MW power interruption occurred under Barishal S/S area from 00:18 to 00:23 (01/10/2019). | | |
| 00:23 (01/10/2019). | | | | | | | | |
| h) Faridpur-Madaripur 132 kV Ckt-1 was shut down at 06:31 (01/10/2019) for D/W. | | | | | | | | |
| | | | | | | | | |
| i) Chandpur CCPP GT was shut down at 05:49 (01/10/2019) due to problem with gas booster. j) Dhamrai 132/33 kV T2 transformer was shut down at 07:52 (01/10/2019) for red hot maintenance at 33 kV bus | | | | | | | | |
| j) Dhamrai 132/33 kV 1 by PBS. | 2 transformer was | s shut down | at 07:52 (01/10/201 | 9) for re | d hot mainter | nance at 33 kV bus | | |
| by FDO. | | | | | | | | |
| Sub Divisional Englished | | | Excention Frank | | | | noriet 1 | Engineer |
| Sub Divisional Engineer Network Operation Division | | | Executive Engineer Network Operation Division | on | | | perintendent bad Despatch | |
| | | | | | | | a D copaton | |