

QF-LDC-08  
Page -1

The Summary of Yesterday's ( 6-Aug-08 ) Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	3335.0	MW Hour :	9:00	Min Gen. at 7:00	3249 MW
Evening Peak Generation :	3391.6	MW Hour :	19:30	Max Generation :	3402 MW
E.P. Demand (at gen end) :	4400.0	MW Hour :	19:30	Max Demand :	4400 MW
Maximum Generation :	3391.6	MW Hour :	19:30	Shortage	998 MW
Total Gen. (MKWH) :	77.50	System L / Factor :	95.22%	Load Shed	858 MW

Export from Ghorasal to Ishurdi :-	Maximum	240 MW	at 1:00	Energy	4422000 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	at -	Energy	- KWHR.
Water Level of Kaptai Lake at 6:00 A M of		7-Aug-08			
Actual :	78.62 Ft.(MSL) ,	Rule curve :	90.92	Ft.( MSL )	

Cost of the Consumed Fuel (PDB) : Gas	:	Tk47,804,249	Oil	:	Tk15,280,252	Total	:	Tk63,084,501
---------------------------------------	---	--------------	-----	---	--------------	-------	---	--------------

Area	Yesterday		Today			
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)		Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from	18:30 05:53				
Dhaka	247		1600		284	18%
Chittagong Area	141		470		128	27%
Khulna Area	99		450		121	27%
Rajshahi Area	97		352		95	27%
Comilla Area	83		275		67	24%
Mymensing Area	57		198		52	26%
Sylhet Area	47		155		41	26%
Barisal Area	21		80		22	28%
Rangpur Area	75		190		48	25%
<b>Total</b>	<b>867</b>	<b>19:30</b>	<b>3770</b>		<b>858</b>	

Planned Shut-Down	Forced Shut-Down
1) Khulna 60 MW (05/07/06)	8) Shajibazar-2 (13/07/08)
2) Ashuganj CCPP ST-(20/10/07)	9) Ashuganj -5 (03/08/08)
3) Kaptai- 3 (19/04/08)	10) Tongi GT (04/08/08)
4) Raozan -2 (02/07/08)	
5) Ashuganj -3 (13/05/08)	
6) Ghorasal -1 (22/06/08)	
7) 4 units of KPCL	

Description	Forced load shaded / Interrupted Areas
-------------	--

So about 867 MW (19:30) of load shed was imposed over the whole area of the national grid.

Deputy General Manager  
Load Despatch Circle