

QF-LDC-08  
Page -1

The Summary of Yesterday's (	14-Oct-08	) Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	3273.6	MW	Hour :	11:00	Min Gen. at 7:00	3069 MW	
Evening Peak Generation :	3724.9	MW	Hour :	20:00	Max Generation :	3725 MW	
E.P. Demand (at gen end) :	4350.0	MW	Hour :	20:00	Max Demand :	4350 MW	
Maximum Generation :	3724.9	MW	Hour :	20:00	Shortage	625 MW	
Total Gen. (MKWH) :	79.83	System L/ Factor :		89.30%	Load Shed	532 MW	

Export from Ghorasal to Ishurdi :-	Maximum	324 MW	at	18:00	Energy	6204000 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	at	-	Energy	- KWHR.
Water Level of Kaptai Lake at 6:00 A M of		15-Oct-08				
Actual :	87.33 Ft.(MSL) ,	Rule curve :		10.80	Ft.(MSL )	

Cost of the Consumed Fuel (PDB) : Gas	: Tk50,773,953	Oil	: Tk16,328,719	Total	: Tk67,102,672
---------------------------------------	----------------	-----	----------------	-------	----------------

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from	17:30 5:45			
Dhaka	136		1605	146	9%
Chittagong Area	90		478	89	19%
Khulna Area	101		426	79	19%
Rajshahi Area	69		339	62	18%
Comilla Area	27		260	48	18%
Mymensing Area	24		197	36	18%
Sylhet Area	18		157	28	18%
Barisal Area	21		78	14	18%
Rangpur Area	46		165	30	18%
<b>Total</b>	<b>532</b>	<b>20:00</b>	<b>3705</b>	<b>532</b>	

Planned Shut-Down	Forced Shut-Down
1) Khulna 60 MW (05/07/06)	8) Haripur SBU GT-1(12/10/08)
2) Kaptai- 3 (19/04/08)	9) Haripur SBU GT-2(12/10/08)
3) Raosan -1 (17/09/08)	10) Haripur SBU GT-3(08/10/08)
3) Sikalbaha St- (19/06/08)	11) NEPC - 7(13/10/08)
4) Shajibazar-2 (13/07/08)	
5) Shajibazar-4 (27/09/08)	
6) Ghorasal-1 (30/09/08)	
7) Barapukuria-2 (05/10/08)	

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 532 MW (20:00) of load shed was imposed over the whole areas of the national grid.
b) Due to gas limitation, Ghorasal ( 780 MW ), NEPC (110 MW), Siddhirganj (190 MW) and RPCL (210 MW) were limited to 695 MW, 75 MW, 160 MW and 112 MW respectively	
c) Due to gas limitation, Raozan -1, Sikalbaha Steam, Haripur SBU GT1, GT2 & GT3 and Shahjibazar -2, are under shut down.	
d) After maintenance, Baghabari WMPL unit -1 was synchronized at 14:36. But it tripped again at 23:04 due to vibration high. It may be synchronized before evening peak hour today	
e) After maintenance, Kaptai unit - 5 was synchronized at 18:12.	
f) Ishurdi - Pabna 132 KV line was under annual maintenance from 08:30 to 17:02.	
g) Hasnabad 132/33 KV T1 transformer tripped at 12:30 showing ' Tap changer gear oil surge' . It is now under inspection and maintenance.	
h) Khulna Central 132/33 KV T2 transformer tripped at 17:50 showing ' Buchholtz and Lockout relay'. It is now under inspection and maintenance.	Due to generation shortage, about 200 MW of load shed has been running since morning (15/10/08) over the whole area of the national grid.

Deputy General Manager  
Load Despatch Circle