POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER, LDC,DHAKA DAILY REPORT

QF-LDC-08 Page -1

				Reporting Date :	19-Oct-08
Till now the maximum generatio	n is : - MW at	4130.0	20:00	17-Sep-07	
The Summary of Yesterday's (18-Oct-08) Generation & Demand	Toda	y's Actual Min Gen. & Probat	ble Gen. & Demand
Day Peak Generation :	3181.0	MW Hour :	10:00 Min (Gen. at 7:00	3015 MW
Evening Peak Generation :	3834.2	MW Hour :	20:00 Max	Generation	3800 MW
E.P. Demand (at gen end) :	4250.0	MW Hour :	20:00 Max	Demand :	4350 MW
Maximum Generation :	3834.2	MW Hour :	20:00 Shor	tage	550 MW
Total Gen. (MKWH)	78.82	System L/ Factor :	85.66% Load	d Shed	480 MW
	EXI	PORT/IMPORT THROUGH EAST	WEST INTERCONNECTOR		
Export from Ghorasal to Ishurdi :-	Maximum		252 MW at 19:30	0 Energy	3828000 KWHR.
Import from Ishurdi to Ghorasal:- N	Maximum	-	MW at -	Energy	- KWHR.
	Water Level of Kapt	ai Lake at 6:00 A M of	19-Oct-08		
Actual : 86.40	Ft.(MSL) ,		Rule curve : 107.70 Ft.	(MSL)	
Gas Consumed : Total	654.69	MMCFt.	Oil Consumed (PI	DB): SKO : HSD : FO :	0 Liter 253718 Liter 709675 Liter

 Cost of the Consumed Fuel (PDB):
 Gas
 :
 Tk48,388,138
 Oil
 :
 Tk14,937,702
 Total
 :
 Tk63,325,840

Load Shedding & Other Information

Area	Yesterday Actual Shedding (s/s end), MW		Today			
			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding	
	fr tom 17:30	2:25	MW	MW	(On Estimated Demand)	
Dhaka	67		1645	124	8%	
Chittagong Area	65		489	81	17%	
Khulna Area	65		436	72	17%	
Rajshahi Area	60		347	57	16%	
Comilla Area	30		267	45	17%	
lymensing Area	25		202	34	17%	
Sylhet Area	15		161	26	16%	
Barisal Area	8		80	13	16%	
Rangpur Area	28		169	28	17%	
Total	363	20:00	3796	480		

Information of the Generating machines under maintenance

Planned Shut- Dowr	Forced Shut- Down		
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	7) Haripur SBU GT-1(12/10/08)	
	2) Raozan -1 (17/09/08)	8) Haripur SBU GT-2(12/10/08)	
	3) Sikalbaha St- (19/06/08)	9) Haripur SBU GT-3(08/10/08)	
	4) Shajibazar-2 (13/07/08)	10) NEPC - 7(13/10/08)	
	5) Shajibazar-4 (27/09/08)	11) Tongi GT (17/10/08)	
	6) Ghorasal-1 (30/09/08)	12) Bheramara GT2 (17/10/08)	

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description		Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yes	•	So about 363 MW (20:00) of load shed was imposed over the whole areas of the national grid.
 b) Due to gas limitation, Ghorasal (780 MW), NEPC (110 N (210 MW) were limited to 690 MW, 92 MW, 160 MW and c) Due to gas limitation, Raozan -1, Sikalbaha Steam, Haripur S are under shut down. d) Hasnabad - shyampur 132 KV line was shut down at 09:1 at 14:08. Again it was shut down at 14:55 and closed fror opened from Shyampur end at 16:23 and closed at 21:55 	145 MW respectively BU GT1, GT2 & GT3 and Shahjibazar -2,4 4 due to protection test and was switched or m Shyampur side only at 14:58. Again it was	
Deputy / Asstt. Manager Load Despatch Division	Manager Load Despatch Division	Deputy General Manager Load Despatch Circle