

QF-LDC-08
Page -1

Description	Forced load shaded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Due to low gas pressure Tongi 105 MW and RPCL (210 MW) were limited to 45 MW and 108 MW respectively.</p> <p>c) Madanhat-Kaptai 132kV line-1 was under shut down from 07:55 to 16:53 due to annual maint.</p> <p>d) Ghorasal-Ashuganj 230kV line-1 was under shut down from 07:55 to 17:59 due to annual maint.</p> <p>e) Aminbazar-Hasnabad 230kV line-1 was under shut down from 08:33 to 16:52 due to annual maint.</p> <p>f) Kabirpur-Tangail 132kV line-1 was under shut down from 08:35 to 17:25 due to annual maint.</p> <p>g) Comilla(N)-Feni 132kV line-2 was under shut down from 08:46 to 16:04 due to annual maint.</p> <p>h) Bogra-Naogaon 132kV line-1 was under shut down from 09:50 to 16:40 due to annual maint.</p> <p>i) Haripur-Comilla(N) 132kV line-2 was under shut down from 09:34 to 12:44 due to annual maint.</p> <p>j) Jessore-Jhenidah 132kV line-1 was under shut down from 08:36 to 16:36 due to annual maint.</p> <p>k) Jamalpur 33kV bus was under shut down from 09:55 to 13:02 due to annual maintenance.</p>	<p>So about 282 MW (20:00) of load shed was imposed over the whole areas of the national grid .</p>
<p>l) Fenchuganj 132/33kV T2 X-former was under shut down from 11:34 to 13:28 due to annual maintenance.</p> <p>m) Baghabari WMPL #1 was under shut down from 12:15 to 15:19 due to filter cleaning.</p> <p>n) Baghabari 100 MW tripped at 00:51(19/12/10) due to problem of gas control valve and was synchronized at 06:20(19/12/10). It again tripped at 06:45(19/12/10) due to same reason.</p> <p>o) Baghabari WMPL #2 tripped at 05:14(19/12/10) due to voltage regulator problem and was synchronized at 08:01(19/12/10).</p>	<p>Power interruption occurred (about 10 MW) under Jamalpur S/S areas from 09:55 to 13:02.</p> <p>Power interruption occurred (about 5 MW) under Fenchuganj S/S areas from 11:34 to 13:28.</p>

Deputy / Asstt. Manager

Network Operation Division

Manager

Network Operation Division

Deputy General Manager

Load Despatch Circle